Date Received

MECK COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH
RECEIVED
JUN 3 0 1977

APT No. 1234
PO
T. C. No. 021-013-04

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Belk (LAST) Andy (FIRST) B (MIDDLE)

2) ADDRESS OF OWNER 5600 Hickory Grove Rd ZIP

3) PHONE NO Home Chtt, N.C. Office 535-4552

4) LOCATION OF PROPERTY East Field Road (STREET OR COUNTY ROAD) Huntersville N.C.


5) SUBDIVISION LOT NO BLOCK NO

MAP BOOK NO PAGE NO

6) DEED REFERENCE DEED BOOK fee Contract PAGE NO

545-3992

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Andy Belk
OWNER

EHD-5-76

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

APP 12814
PC 021-013-04

(Ground Absorption Sewage Disposal)

OWNER: Judy B. Bell
ADDRESS: 5600 Mallory Creek Rd
COUNTY: Charlotte
LOCATION OF SITE: "Fairfield" Rd

DATE REQUESTED: _____
PLAT NO.: _____
LOT SIZE: 26 Acres

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) 2-6% PS U	S 2-6% PS U	S PS — U	(S) 2-8% PS U +
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S 2:1 PS Loam/Clay (U) Clay	S 2:1 PS Loam/Clay (U) Clay	S PS — U	S (PS) clay U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S PS Massive (U)	S PS Massive (U)	S PS — U	S (PS) Blo-Ky U
4. SOIL DEPTH (In.)	S 24-36" PS (U)	S 24-36" PS (U)	S PS — U	(S) 40" PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, Rock)	S PS U	S PS U	S PS — U	S PS — U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	S Seasonal Perched PS High water (U) Table	S Seasonal Perched PS High water (U) Table	S Seasonal Perched PS High water (U) Table	(S) 24-36" To PS Water Table U
7. SOIL PERMEABILITY (Percolation Rate)	S 61-120 PS > 120 Min. (U)	S 61-120 PS > 120 Min. (U)	S Subject PS To Flooding (U)	S Moderate (PS) 60 Min. U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	unsuitable	unsuitable	unsuitable	Provisionally suitable
SOIL SERIES	Iredell	Iredell	Chewacla	Cecil

S - Suitable PS - Provisionally Suitable U - Unsuitable


* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc)

Recommendations/Comments: Based on this investigation, an adequate area provisionally suitable soil for the installation of a septic tank system. System design should be based on percolation rate of 61 min. and system location in area provisionally suitable for

Described By: William A. Marlin

Title: Soil Scientist Date: July 29, 1977

DHS Form 2601 (2/77)
Sanitation


Pipeline
Helena
Central
Lewis
Chancellor
Wilkes
Ingalls
Eastfield Rd

Serial No. 1124

PTR No. 12814

T C No P.0.021-013-04

Date Issued July 27, 1977

Map Date _____


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Belk (LAST) Andy (FIRST) B. (MIDDLE)

ADDRESS OF OWNER 5600 Hickory Grove Road, Charlotte, NC ZIP _____

LOCATION OF PROPERTY Eastfield Road (STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO _____ BLOCK NO _____



PLOT PLAN

This is to certify that a soil and site investigation was made by the Mecklenburg County Department of Environmental Health on the above described property. This investigation was conducted in accordance with the rules and regulations governing the disposal of sewage and the above property is classified as **Provisionally Suitable**

The said lot is approved for the installation of an individual sewage treatment and disposal system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A system shall be installed on the above described property in accordance with the Mecklenburg County Department of Environmental Health Regulations governing the disposal of sewage and the wastewater treatment system shall be approved by the Mecklenburg County Department of Environmental Health prior to the issuance of a building permit.
2. The size of the system and the amount of the area which must be installed will be determined by the Mecklenburg County Department of Environmental Health at the time application for a building permit is made and will be in accordance with the terms of this report contained above and in the regulations governing the disposal of sewage.
3. _____
4. The Mecklenburg County Department of Environmental Health shall be notified when the site is ready for system installation. Percolation tests shall be performed on the lot when the system is installed. The Mecklenburg County Department of Environmental Health shall determine the suitability of the lot as indicated as acceptable for the system and at that time shall issue the permit for installation of the system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules and regulations been in effect on the issue date.

William B. Marlow
EHD 5-76 **Soil Scientist**

John L. Atkisson
Environmental Health Director or Authorized Section Head

Environmental Health Department's Copy