Date Received 4/29/75

APT No. 9255

T C No

Map Date

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER Bob McLemore & Co., Inc.
(LAST / FIRST / MIDDLE)

2) ADDRESS OF OWNER 7204 Matthews-Mint Hill Rd. ZIP 28212

3) PHONE NO Home Office 545-6111


4) LOCATION OF PROPERTY XXXXXXXX Mountain Apple Dr.
(STREET OR COUNTY ROAD)

5) SUBDIVISION Apple Creek LOT NO 11 BLOCK NO B

MAP BOOK NO 17 PAGE NO 366

6) DEED REFERENCE DEED BOOK PAGE NO

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

OWNER

FORM NO. E-1-9-1-72

HEALTH DEPARTMENT'S COPY

Serial No. [illegible]

PTR No 0255

Date Issued May 6, 1975

T C No 135-362-09

Map Date 2/21/75

Do Not Issue A Building Permit Based On This Form

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION


PERCOLATION TEST REPORT

NAME OF OWNER Bob McLemore & Company, Inc.

ADDRESS OF OWNER 7204 Matthews-Mint Hill Road ZIP 28212

LOCATION OF PROPERTY Mountain Apple Drive

SUBDIVISION Apple Creek SECT NO 11 BLOCK NO B



[illegible] #6 Min./In. [illegible]

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina State Board of Health and the Mecklenburg County Board of Health which were in effect on the date of issuance and is void if at any time in the future prior to the completion of the system, these laws, rules, and regulations are changed such that this type of soil would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

*Results determined by soil analysis

W. Edward Cooper Jr.
Soil Scientist

John M. Johnson
Director, Environmental Health Division or
Authorized Section Head

FORM NO E-2-9-1-72

HEALTH DEPARTMENT'S COPY

SEE INSTRUCTIONS ON BACK

Date Received 4/29/75

ICAR(S) Application No 9255

T C No

Map Date


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

Application for an
Installation, Construction, Alteration, and/or Repair Permit
Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The [illegible] applies to the Mecklenburg County Health Department [illegible] a permit for:

[illegible] Alter or Repair an individual septic tank wastewater treatment system [illegible] subsurface soil absorption effluent discharge



3 PLOT PLAN ACCURATELY DRAWN AND DIMENSIONED

3

Map No

Yes No

Yes No

Yes No

Yes No

13 NAME OF OWNER [illegible] LAST [illegible] FIRST [illegible] MIDDLE

14 ADDRESS OF OWNER [illegible]

15 PHONE NO Home [illegible] Office [illegible]

16 LOCATION OF SYSTEM [illegible] STREET OR COUNTY ROAD

17 SUBDIVISION [illegible] Lot No 11 Block No 2

Map Book No [illegible] Page No 346

18 DEED REFERENCE — DEED BOOK [illegible] AT PAGE [illegible]

19 HAS A PERCOLATION TEST BEEN RUN? YES ____ NO DATE RUN ____

20 PTR NUMBER (See Instructions ____

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

DATE OF APPLICATION

Adrian Smith
OWNER

FORM NO [illegible]

HEALTH DEPARTMENT'S COPY

Serial No. 4927

LA No 9255

Date Issued May 8, 1975

T C No 135-362-09

Map Date 2/21/75

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE SOIL ABSORPTION EFFLUENT DISCHARGE

NAME OF OWNER (LAST) Bob McLemore & Company, Inc. (FIRST) (MIDDLE)

ADDRESS OF OWNER 7204 Matthews-Mint Hill Road ZIP 28212

LOCATION OF LOT Mountain Apple Drive (STREET OR COUNTY ROAD)

SUBDIVISION Apple creek LOT NO 11 BLOCK NO B

MAP BOOK NO PAGE NO

The above specified lot is approved by the Mecklenburg County Health Department for the installation of an individual septic tank system with subsurface soil absorption effluent discharge based on the percolation test results which indicated a percolation rate of 60 min./in. on the date of inspection. The lot and the intended use are described in the Application for an Installation, Construction, Alteration and/or Repair Permit number 9255. This approval is subject to the following terms and conditions:

1. That the absorption field be installed, constructed, altered, and/or repaired in the same area where the percolation test was run.
2. That an Installation, Construction, Alteration, and/or Repair Permit be issued and in full force and effect when the system is installed, constructed, altered, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the Application for an Installation, Construction, Alteration, and/or Repair Permit is not correct or is untrue or that the septic tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

Richard Hartman
Environmentalist

John R. Hankinson
Director, Environmental Health Division or Authorized Section Head

FORM NO E-3-9-1-72

HEALTH DEPARTMENT'S COPY

Date Issued 8 July 75 Serial No. ICAR(S) Permit No 9255

T C No

Map Date


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct Alter or Repair the individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 9255 dated and this permit shall be void and of no effect if the information provided in the application is not true as represented. All work shall be completed on or before 8 July 75 after which date this permit shall be null and void.



PLOT OF SYSTEM

Percolation Rate 60

Liquid Capacity of Tank 1500 gal

Tank Construction precast concrete

Absorption System

Trench 600' & 150'

Number @ 5' x 100'

Distance 10'

Distance 10'

Distance 100'

NAME OF OWNER Bob McLemore

LOCATION OF PROPERTY Mountain Apple Dr.

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Board of Health which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Health Director before any system can be covered up or otherwise rendered uninspectable or can be used.

Comments washer 7½' x 50'

aeration pit 2½' x 7' x 4' stone

Division or Section Head

G. M. Reynolds
Environmentalist

If this permit is for the installation or construction of a new system it must be signed by the division or a section head of the Environmental Health Division in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

Form E-S-S-1-72

C of A No 9255

Date Issued 28 July 75 Serial No.

T C No 135-362-09

Map Date 2-21-75

CERTIFICATE OF COMPLETION

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner McKenmore Co, Bob
LAST FIRST

Location of Property Willie Mt Cipple Dr. Lot 11-B

Application Number 9255 Permit Number 9255

Inspection Date:

Liquid Capacity of Tank 1500 Tank Material Precast Concrete

Total Length of Drain Tile 600' & 150' Number of Lines 6 15'x100'

Depth of Filter Material 17" Cover Depth 48"

Water Supply Source Community Distance from Water Source 100'

Excavation Inspected 28 July 75 Tank Inspected 28 July 75
DATE DATE

Notification Field Inspected 28 July 75
DATE

Washing Machine Line Inspected if Applicable 28 July 75
DATE

This construction authorization is for a Septic Tank System with subsurface soil absorption and effluent discharge and it has been ✓ constructed in accordance with the permit issued and the regulations governing Mecklenburg County in effect on the date of issuance of the permit. This approval of this Certificate is predicated upon the assumption that this system will be operated properly and will not create any nuisance or health hazard. Nothing in this Certificate shall relieve any person owning such system from any liability resulting from the operation of the system. This Certificate of Approval is issued subject to those restrictions and requirements noted in addition to those listed below under comments. This Certificate of Approval shall be void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments Acceptance pit C.K

E. M. Reynolds
Environmentalist

FORM NO E-6-9-1-72