

2001 BELMEADE DR

05303221

5/28/08

marliwr

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

05303201

Mecklenburg County
Health Department

December 10, 1996

Ms. Elaine Moss
2001 Belmeade Drive
Charlotte, NC 28214

Dear Ms. Moss,

This is to acknowledge the application for an alteration to your property at 2001 Belmeade Drive. Your request was to increase your residence from a two bedroon to a three bedroom residence. The residence had also burned and was in need of total renovation. At that time, a site visit was conducted by Jeremy Moss and myself. Mr. Moss had designed an additional bedroom out of the back of the house.

Our existing records indicate that there was an ongoing complaint concerning your septic system prior to your home burning down. Some work had been done on this septic system without the knowledge of the health dept. but this did not eliminate the sewage on top of the ground. It was also determined that the washing machine discharged on the surface of the ground.

Due to the soil conditions on this lot, I do not deem it possible for the addition of further bedrooms or water usage to this residence. In order to renovate this house using the two existing bedrooms, repairs of the septic system and washing machine wastes would be required prior to any issuance of a building permit.

If you have any questions or need any further assistance, please feel free to contact me at 704/336-5572.

SIncerely,

Toni Higgins Burney R.S.

Toni Higgins Burney, R.S.
Environmental Health Specialist