

OLD POTTERS ROAD 043-045-08

5/10/2007

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

APPLICATION FOR SOIL INVESTIGATION

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 3807A

TC: PO 043-045-08

☐ PC ☐ REPT

MECK COUNTY DEPARTMENT OF
RECEIVED
AUG 13 1987
ENVIRONMENTAL HEALTH

JOB LOCATION

① ADDRESS: Old Potters Rd.

② SUBDIVISION: _____ ③ LOT: B. ④ BLOCK: _____

⑤ PARCEL REFERENCE: BOOK NO.: 043-045-08 PAGE NO.: _____ PARCEL NO.: _____

⑥ DEED REFERENCE: BOOK NO.: 2134- 386 PAGE NO.: _____

OWNER


⑦ NAME: Larry E + Anna S Clive
(FIRST) (MIDDLE) (LAST)

⑧ MAILING ADDRESS: 8924 Old Potters Rd.

⑨ CITY: Charlotte ⑩ STATE: N.C. ⑪ ZIP: 28213

⑫ PHONE: (WORK) 597 8723 (HOME) 597 8829

⑬ Accurately diagram and dimension lot.



⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: Larry E Clive
Anna S. Clive

Date: _____

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER'S COPY

MECKLENBURG COUNTY

Department of Environmental Health

August 19th, 1987

Larry E. & Anna S. Cline
8924 Old Potters Road
Charlotte, NC 28213

RE: Property located at Old Potters Road
FILE: 3807A
PARCEL: 04304508 PO

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. Results of the investigation revealed that the lot contains soils which have been classified as PROVISIONALLY SUITABLE in accordance with the provisions of 10 NCAC 10A .1900. A copy of the Site Evaluation Report (Serial Number 11671) deliniating the soil types and their respective classifications is enclosed.

While this classification indicates the site is acceptable for the installation of a septic tank system, no specific system or plans have been approved. The area available for such an installation may impose limitations on the size and/or type construction permitted on the lot. Specific plan approval will be provided upon submission of an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems and determination that the area is adequate to accomodate the proposed construction.

Please note that this classification may be revoked if any filling, grading or construction (including the drilling of a well) is performed on the lot which in the opinion of this Department renders any area previously designated suitable for system installation, unsuitable. Futhermore, this approval may be revoked should any changes occur in the regulations under which it was granted, if such changes would have prevented its approval had they been in effect on the date of issuance.

If there are any questions concerning this matter, do not hesitate to contact me.

Sincerely,

Sylvia D. Daniel, R.S.
Environmental Health Supervisor
Environmental Resources Division

enclosure

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 11671

File: 38074 Action 4

Parcel: P.O. 043-045-08 ☐ PC

Location: Old Potters Road

Subdivision:


Lot: Block: Acres: 1

Owner: Larry E. & Anna S. Cline
Address: 8924 Old Potters Road
Charlotte, N. C. 28213

Comments:

Described by: W. B. Ramsey

Date: 8-19-87



***** EVALUATION KEY *****

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	S (PS) U 4-10	S PS (U) Complex slopes	S PS U	S PS U	S PS U	S PS U
Texture	S (PS) U	S (PS) U	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U	S (PS) U	S PS U	S PS U	S PS U	S PS U
Drainage	S (PS) U	S (PS) U	S PS U	S PS U	S PS U	S PS U
Depth	S (PS) U 40-48	S PS (U) Various	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U	S (PS) U	S PS U	S PS U	S PS U	S PS U
Available Space	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IVa Cecil	IVe Eroded Cecil				
Area Classification	S (PS) U	S PS (U)	S PS U	S PS U	S PS U	S PS U