Date Received 5/1/78

APT No. 1380

T. C. No. 89-009-0105

Map Date 3-22-78

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Mc[illegible] [illegible] A1
LAST FIRST MIDDLE

2) ADDRESS OF OWNER [illegible] Box [illegible] Hickory NC ZIP [illegible]

3) PHONE NO. Home [illegible] Office [illegible]


4) LOCATION OF PROPERTY Highway 73
STREET OR COUNTY ROAD

5) SUBDIVISION [illegible] LOT NO. 0.583 BLOCK NO. [illegible]

MAP BOOK NO [illegible] PAGE NO [illegible]

6) DEED REFERENCE DEED BOOK 4053 PAGE NO 0318

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual dual septic tank wastewater treatment system with subsurface soil absorption effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

[illegible]
OWNER

EHD-5-76

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION
(Ground Absorption Sewage Disposal)

4 1380

OWNER: Hooker, Howard
ADDRESS: RT 3 Box 190 Hickory 28601
COUNTY:
LOCATION OF SITE: Hwy 73

DATE REQUESTED:
PLAT NO.: P.O. Oct 01 05
LOT SIZE: 20,340 Sq ft

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S PS 35% U	S PS 10% U	S PS U	S PS U +
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S PS CLAY U	S 2:1 Expanding clay PS U	S PS U	S PS U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S PS BLOCKY U	S PS massive U	S PS U	S PS U
4. SOIL DEPTH (In.)	S PS 45" U	S PS 48" U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Imprevious Strata, Rock)	S 36" to PS Rock U	S 36" to PS Rock U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	S 36" to PS water U	S Perched PS water U @ 24"	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S PS MOD U	S PS V. SLOW U. Perched water	S PS U	S PS U
8. OTHER (Specify)	S moderate PS Slo U	S PS None U	S PS U	S PS U
9. SITE CLASSIFICATION	→ Marginal	Un Suitable		
SOIL SERIES	Cec	Enon		


S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc)

Recommendations/Comments:

Described By: Phil Reynolds
Title: Environmentalist Date: 10 May 78

DHS Form 2601 (2/77)
Sanitation


99
200
292
40'
134
Hwy #73

Serial No. 1962

PTR No. 13808

T C No. P.O. 009-011-05

Date Issued 5/12/78

Map Date 3-22-78


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Mo ney (LAST) Howard (FIRST) M. (MIDDLE)

ADDRESS OF OWNER Rt. 2, Box 190 Hickory , N. C. ZIP 28601

LOCATION OF PROPERTY Highway 73 (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO .583 Ac. BLOCK NO.



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated in the above plot **PROVISIONALLY SUITABLE**

The permeability rate determined by the investigation was The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions

1. A permit application must be prepared by a qualified person and submitted to the Mecklenburg County Department of Environmental Health prior to the beginning of construction of any part of the wastewater treatment system on the said lot
2. The size of the septic tank and/or treatment system which must be installed will be determined by the Mecklenburg County Department of Environmental Health at the time of application for permit, the rate obtained above, and on the size and type of building to be constructed thereon
3. The approval of soil and site conditions as indicated on this invalidates any and all prior approvals issued for system installation on the above plot
4. This approval is based upon the soil and site conditions encountered including the boring and percolation tests performed on the lot which is the property of the Mecklenburg County Department of Environmental Health and is valid only for the area indicated as acceptable for system installation. Any substantial deviation in the construction of the system from that approved by this agency will invalidate this approval.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

EHD-5-76

Environmentalist

Environmental Health Director or Authorized Section Head

Environmental Health Department's Copy

Date Received 5/17/76

ICAR (S) Application No. 13806

T C No. 76111.5


Map Date 3 22 76

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) Construct Install or Construct 2) ___ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ___ Yes ___ No
Residence ✓ Yes ___ No
4 No. of Bedrooms 3
5 Business Use Max No Employees ___
6 Washing Machine ✓ Yes ___ No
7 Garbage Disposal ___ Yes ✓ No
8 Dishwasher ___ Yes ✓ No
9 Water Supply
A Individual Well ✓
B Governmental System ___
C Community System
Well source ___
2 Governmental source ___
10 Sewage System
House located within 200 feet of public sewer ___ Yes ✓ No
House located within 200 feet of community sewer ___ Yes ✓ No
11 FHA Case No ___
12 VA Case No ___

13) NAME OF OWNER Mercy (LAST) Howard (FIRST) M (MIDDLE)

14) ADDRESS OF OWNER RT 2 Box 190 Hickory NC 28601

15) PHONE NO Home 256 2255 Office ___

16) LOCATION OF SYSTEM Front yard US 23 (STREET OR COUNTY ROAD)

17) SUBDIVISION ___ Lot No 0.583 A/C Block No. ___

Map Book No ___ Page No. ___

18) DEED REFERENCE — DEED BOOK 4053 AT PAGE 631

19) HAS A SOIL INVESTIGATION BEEN RUN? YES ___ NO ___ DATE RUN ___

20) PTR NUMBER (See Instructions) ___

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

5-15-76
DATE OF APPLICATION

Howard M Mercy
OWNER

EHD-5-76

Environmental Health Department's Copy

LA No. 13808

Serial No. 1829

P.O. 009-011-05

Date Issued 5-15-78

T. C. No. 3-22-78

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

IMPROVEMENT PERMIT
TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Money (LAST) Howard (FIRST) M. (MIDDLE)

ADDRESS OF OWNER Route 2, Box 190 Hickory, N. C. ZIP 28601

LOCATION OF LOT Highway 73 (STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO 0.583 A/c BLOCK NO. _____

MAP BOOK NO. _____ PAGE NO. _____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 13808. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altred, and/or repaired and that the system be installed in accordance with same

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit

J. M. Reynolds
Environmentalist

John R. Adkisson
Environmental Health Director, or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

Date Received 3/3/78

APT No. [redacted]

P.C. No. 017-122-06

Thomas L. Ward
Box 428
Huntersville NC 28078

Map Date 4-1977

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Kerr (LAST) Fred (FIRST) T (MIDDLE)

2) ADDRESS OF OWNER P.O. Box 764 Huntersville NC ZIP 28078

3) PHONE NO Home 333-1151 Office


4) LOCATION OF PROPERTY Nottingham Dr. (STREET OR COUNTY ROAD)

5) SUBDIVISION Sherwood Forest LOT NO. 1 BLOCK NO. A

MAP BOOK NO PAGE NO

6) DEED REFERENCE DEED BOOK PAGE NO

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

OWNER

Thomas L. Ward

EHD-5-76

Environmental Health Department's Copy

13807

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

(Ground Absorption Sewage Disposal)

OWNER: KERR Farm
ADDRESS: P.O. Box 764 Hendersonville 28793
COUNTY: Polk
LOCATION OF SITE: NOTTINGHAM DR Lot A

DATE REQUESTED: —
PLAT NO.: P.O. 017-183-06
LOT SIZE:

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS 5-10% U	S PS U	S PS U	S PS U +
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	(S) PS CLA-1 U	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	(S) PS BLOCKY U	S PS U	S PS U	S PS U
4. SOIL DEPTH (In.)	(S) PS 48" U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Imprevious Strata, Rock)	(S) PS 76' to U Rock	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	(S) PS >6' to U water	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	(S) PS MOD U	S PS U	S PS U	S PS U
8. OTHER (Specify)	(S) PS adequate area U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	PRIV SUITABLE			
SOIL SERIES	cecil			


S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc)

Recommendations/Comments: —

Described By: J.M. Reynolds
Title: Environmentalist Date: 17 April 78

DHS Form 2601 (2/77)
Sanitation


160
cecil
128
200
160
NOTTINGHAM