C of A (s) No. 2999

Date Issued 16 Nov 79 Serial 3240 T C. No. 213-027-04

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Trapp (LAST) William (FIRST) L. (MIDDLE)

Location of Property 512 Hunsgate Rd.

Application Number _____ Permit Number 2999

Inspection Data:

Liquid Capacity of Tank 1500 gal Tank Material PC Conc.

Total Length of Drain Tile 495', 125' Number of Lines 5 & 4

Depth of Filter Material 17" Cover Depth 18"

Water Supply Source well Distance from Water Source 50'+

Excavation Inspected — (DATE) Tank Inspected 16 Nov (DATE)

Nitrification Field Inspected 14 Nov (DATE)

Washing Machine Discharge Inspected If Applicable 14 Nov (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ✓ installed or constructed altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments Oaks -

Environmentalist

EHD-S-76

Environmental Health Department's Copy