Date Received 5-16-73

APT No 6309

T. C No.

Map Date

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER EDWARDS (LAST) LUMBER (FIRST) COMPANY (MIDDLE)

2) ADDRESS OF OWNER P. O. Box 15155 CHARLOTTE, N.C. ZIP 28210

3) PHONE NO. Home 364-8506 Office 523-1912


4) LOCATION OF PROPERTY Old Monroe Rd. (STREET OR COUNTY ROAD)

5) SUBDIVISION _____ LOT NO. _____ BLOCK NO. _____

MAP BOOK NO. _____ PAGE NO _____

6) DEED REFERENCE: DEED BOOK 3192 PAGE NO. 457

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

OWNER

FORM NO. E-1-9-1-72

HEALTH DEPARTMENT'S COPY

SEE INSTRUCTIONS ON BACK

Date Received 5-16-73

ICAR(S) Application No. 6309

T C No. MM-21A-01

Map Date 5-25-71


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that or parts described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to

1) ✓ Install or Construct 2) ___ Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption, effluent discharge



4) No. of bedrooms ___

5) Business Use: Yes ___ No ___
Employees 35

6) Washing Machine: Yes ✓ No ___

7) Garbage Disposal: Yes ✓ No ___

8) Dishwasher: Yes ✓ No ___

9) Water Supply:
A) Individual Well ___
B) Government ___
C) Community System:
1) Well ___
2) Government ___

10) Sewage System:
House located within 200 feet of public sewer: Yes ___ No ___
House located within 200 feet of community sewer: Yes ___ No ___

11) FHA Case No. ___

12) VA Case No. ___

31) PLOT PLAN (ACCURATELY DIMENSIONED)

13) NAME OF OWNER EDWARDS Lumber Co
LAST FIRST MIDDLE

14) ADDRESS OF OWNER P.O. Box 15155 CHARLOTTE, NC 28210

15) PHONE NO Home 364-8506 Office 523-1912

16) LOCATION OF SYSTEM OLD MONROE RD
STREET OR COUNTY ROAD

17) SUBDIVISION ___ Lot No. ___ Block No. ___

Map Book No ___ Page No. ___

18) DEED REFERENCE — DEED BOOK 3192 AT PAGE 457

19) HAS A PERCOLATION TEST BEEN RUN? ___ YES ___ NO DATE RUN ___

20) PTR NUMBER (See Instructions) ___

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

MAY 16, 1973
DATE OF APPLICATION

Tim Edwards V.P.
OWNER

FORM NO. E-4-9-1-72

HEALTH DEPARTMENT'S COPY

MECKLENBURG COUNTY HEALTH DEPARTMENT
INTER-OFFICE COMMUNICATION

DATE: June 21, 1973

TO: John Adkisson

FROM: Everette Lynn
W. E. L.

SUBJECT: Edwards Lumber Company

Old Monroe Road
Edwards Lumber Company construction site at McAlpine Creek

Findings - The soils in the areas of concern have undergone extreme disturbance. In the majority of areas considered for septic tank systems, the soil has been cut down to weathered rock material which has poor structural development and slow permeability or percolation. The other areas considered were fill material to considerable depths. This fill material was found to be high in clay and extremely compacted. Permeability or percolation was slow. All of the soils in the area exhibit a great deal of compaction resulting from grading operations. Based on these observations, the soils are unsuitable for septic tank systems.