10429
#9004
20 JUN '17 AM10:25

MECKLENBURG COUNTY
HEALTH DEPARTMENT

APPLICATION FOR APPROVAL TO USE AN EXISTING ON-SITE WASTEWATER TREATMENT & DISPOSAL SYSTEM / WATER SUPPLY WELL

APPLICATION TYPE: ○ SEPTIC ONLY ○ WELL ONLY ● SEPTIC & WELL
○ ADDITION OR RENOVATION WITH OCCUPANCY INCREASE
○ ADDITION OR RENOVATION WITH NO OCCUPANCY INCREASE
○ EXCHANGE MOBILE HOME (SAME # BEDROOMS)
● COMMERCIAL OR INDUSTRIAL

PERSON FILING APPLICATION:
NAME: LeNell C. Grier
ADDRESS: 205 Silver Cliff
CITY: Mt Holly NC.
STATE: NC. ZIP: 28120
PHONE: 704-201-0411
ALTERNATE PHONE: 704-822-0966
E-MAIL: FAIRYLANDIEL@yahoo.com

PROPERTY OWNER: ☐ SAME AS PERSON FILING APPLICATION
NAME: Mt Olive Church
ADDRESS: 5125 Mt Olive Church Rd
CITY: Charlotte,
STATE: NC ZIP: 28278
PHONE: 704-394-8814
ALTERNATE PHONE: 704-201-0411
E-MAIL:

JOB LOCATION INFORMATION
TAX PARCEL #: 11337101
STREET ADDRESS: 5125 Mount Olive Road
CITY: Charlotte, N.C
STATE (NC) ZIP: 28278

SUBDIVISION OR MOBILE HOME PARK NAME: Mt. Olive Life Center
LOT #:

WATER SUPPLY:
○ MUNICIPAL ● PRIVATE WELL ○ PUBLIC WELL ○ SHARED WELL ○ OTHER Septic Tank

RESIDENTIAL PROPERTY TYPE: ○ N/A
○ HOUSE ○ MODULAR HOME ○ MULTIPLE FAMILY
○ SINGLE MOBILE HOME ○ DOUBLE WIDE
○ OTHER Life Center - Church

OCCUPANCY (both fields are required):
NUMBER OF BEDROOMS:
NUMBER OF OCCUPANTS:

COMMERCIAL / INDUSTRIAL PROPERTY TYPE: ☐ N/A
TYPE OF BUSINESS: Church
EMPLOYEES PER SHIFT: 5
OF SHIFTS: 1

INDUSTRIAL WASTES? ○ YES ○ NO
UNDERGROUND STORAGE TANKS? ● YES ○ NO

ADDITION/RENOVATION TYPE ATTACHED TO EXISTING STRUCTURE:
☐ BEDROOM ☐ BATHROOM ☐ KITCHEN ☐ DINING ROOM ☐ LIVING ROOM ☐ DEN
☐ GARAGE ☐ SUNROOM ☐ PORCH ☐ DECK ☐ OTHER Day Care

ADDITION/RENOVATION TYPE DETACHED FROM EXISTING STRUCTURE:
☐ DETACHED GARAGE ☐ DETACHED GARAGE WITH PLUMBING ☐ POOL HOUSE ☐ SHOP ☐ BARN
☐ STORAGE SHED ☐ DETACHED PORCH / DECK ☐ OTHER

*The undersigned, owner, or legal agent for the owner, of the property described above as the "Job Location" has read the foregoing application, acknowledges that the contents of same are true, and authorizes the Mecklenburg County Health Department to enter onto the property for the purpose of processing this request.

LeNell C. Grier — Owner's/Agent's Signature
6/13/2017 — Date

A PROPOSED PLOT PLAN (see page 2) is required to be submitted with each application.

MECKLENBURG COUNTY – GROUNDWATER & WASTEWATER SERVICES
700 N. TRYON ST. SUITE 211 CHARLOTTE, NC 28202, OFFICE: ~~704-336-5103~~ 980-314-1680, FAX: 704-336-6894


Revised on: 01/03/11

File #:_____

PROPOSED PLOT PLAN

A drawing showing the locations of the following items is required: existing and proposed property lines with dimensions, easements or right-of-ways, proposed building pad(s) or existing building footprint(s), all appurtenances (garage, driveway, deck, pool, etc.), location of existing or proposed well(s), location of existing or proposed sewer lines and sewage disposal systems, surface water bodies, and any aboveground or underground storage tanks. Provide names for all roads that adjoin the property.

Street Address: Mt Olive Presby Church Tax Parcel #:_____ Please inspect.
Life Center - Mt Faith Center



*The undersigned, an authorized agent of the Mecklenburg County Health Department, certifies that the Department has approved the Request for the "Job Location" contained in this document. This approval is granted in accordance with the provisions of Laws and Rules for Sanitary Sewage Collection, Treatment, and Disposal and Water Supply Wells in effect at the time of issuance of the permit and is subject to the following provisions:

- No work shall be conducted on the septic tank system until an installation, construction, alteration and/or repair approval is granted by this Department.
- This permit is not transferable.
- Addition/Renovation approval valid 1 year from issuance date
- Mobile home exchange approval valid 6 months from issuance date

Daycare approved for 75 students
See note in file for justification

REHS Signature 7/2/17 Date
Bradley W. Hallman

MECKLENBURG COUNTY – GROUNDWATER & WASTEWATER SERVICES
700 N. TRYON ST. SUITE 211 CHARLOTTE, NC 28202, OFFICE: 704-336-5103, FAX: 704-336-6894

Revised on: 01/03/11

MECKLENBURG COUNTY
Health Department

E. Winters Mabry, MD
Director

(704) 432-3199

Addendum to Application for
New Well or Septic System Installation
Abandonment or Repair of Existing Well or Septic System

Your signature below confirms the following:

1. The information on the application is true, complete and accurate.
2. Authorized county and state officials are granted right of entry to conduct necessary inspections to determine compliances with applicable laws and rules.
3. I acknowledge that Lenell Grier is acting as my legal representative (agent) in the submittal of the application for a water supply well or septic permit located at

5125 Mt Olive Church Rd Charlotte 28273
Number Street Town
(Or Parcel Number)

Ellen Young
Property Owner (print name)

Ellen Young
Property Owner (signature)

6-22-2017
Date

Note to File

Mt Olive Presbytarian Church Flow Justification G/P/D:
300 seats X 5g/p/d = 1500 Gal
Daycare: 75 students X 15g/p/d = 1125 Gal

Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday
1500 gal	1125 gal	1125 gal	1875gal	1125 gal	1125 gal	1500 gal

Monday/Tuesday:Daycare only
Wednesday: Based on 1/2 seats for church and Daycare
Thursday/Friday: Daycare only
Saturday: Base on miscellaneous event

Total amount does not exceed 1875 Gal per day which corresponds with system design

Bradley W. Hallman

7/3/17

MECKLENBURG COUNTY
LAND USE AND ENVIRONMENTAL SERVICES
Payment Receipt

Receipt Information

Date:	06/20/17	**Amount:**	100.00
Receipt #:	106345	**Tendered:**	100.00
Check / Auth #:	VISA 801944	**Returned:**	0.00
Received By:	ABDUSAI		

Account Information

Account #:	200000
Contractor:	GRIER, LENELL
Attn:	
Address:	205 SILVER CLIFF DR
Address:	
City/State/Zip:	MOUNT HOLLY, 28120

Item	Description	Permit#	Quantity	Unit Price	Total Price
0705	Use Existing System 5125 MOUNT OLIVE CHURCH		1	100.00	100.00

----------Outstanding Balances----------

Month-To-Date	Prior Month	30 Days	60 Days	90 Days	Balance

MECKLENBURG COUNTY
LAND USE AND ENVIRONMENTAL SERVICES
Payment Receipt

Receipt Information

Date:	06/20/17	**Amount:**	100.00
Receipt #:	106345	**Tendered:**	100.00
Check / Auth #:	VISA 801944	**Returned:**	0.00
Received By:	ABDUSAI		

Account Information

Account #: 200000
Contractor: GRIER, LENELL
Attn:
Address: 205 SILVER CLIFF DR
Address:
City/State/Zip: MOUNT HOLLY, 28120

Item	Description	Permit#	Quantity	Unit Price	Total Price
0705	Use Existing System 5125 MOUNT OLIVE CHURCH		1	100.00	100.00

----------Outstanding Balances----------

Month-To-Date	Prior Month	30 Days	60 Days	90 Days	Balance

Payment Receipt

Mecklenburg County POS

Environmental Health
700 N. Tryon Street
Charlotte, NC 28202
Phone: 704-336-5100

Enter Account # or Customer Name Here: LENELL GRIER

Bill To:

LENELL GRIER
205 SILVER CLIFF DR

Mount Holly, NC 28120

Single Payment

Transaction Date: 06/20/2017 7:01 AM Pacific Time
Pay Method: VISA **********0013
Approval #: 801944
Trace Number: e5ad9372-24d4-488e-bdd1-d21949348c2b
Amount: $100.00

Payment Amount: $100.00

Total: $100.00

Thank you for your payment.

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR APPROVAL

Project # 956 96 5082


HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON ST., SUITE 211
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 10429 DATE: 6/8/01

TC: 113-371-01 ☒ L

SERIAL Nº 18654

Permission is hereby given to ✓ (Install) or Construct, _____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 9-11-00. All work shall be completed on or before 7/8/01, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 15A NCAC 18A. 1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Health Department before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank 3,000 gallons

Liquid Capacity of Dosing Tank 3,000 gallons

Tank Construction AC

Trench Depth 30"

Absorption and/or Nitrification Lines:

Trench Width 3' feet

Trench Walls Scored and Porous yes

Total Line Length 1650 feet

Number of Lines 13

Depth of Stone 12" inches

Distance from House >5' feet

Distance from Property Line >10' feet

Distance from Well >100' feet

2,000 Gallon Grease Trap

NOTICE: This system shall not be installed while soils are in a wet condition.

NAME OF OWNER Mt. Olive Presbyterian Church (Rev. Shackleford)

LOCATION OF PROPERTY 5125 Mt. Olive Church Road

Comments: Church Multi-Purpose Building w/ Day Care

Install 13 lines of varying length w/ flow Dividers (1650 TLF)

Type IIIb pump to Conventional System

Jeremy P. Mecklenburg RS

Environmental Health Specialist

WHITE - HEALTH DEPARTMENT's COPY • CANARY - E.H.S. COPY • PINK - OWNER OR AGENT's COPY

Mt. Olive Church
Life Center

CHURCH

Grass

Parking Lot

House

(Septic tank)

Surface pipes

Well

FAMILY LIFE Center

Door

GYM Door

Door