

Rowan Way

1/29/08

thomatc

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

Date Received 2-8-84

RECEIVED
FEB 8 1984
ENVIRONMENTAL HEALTH

SIR No. 20596

T. C. No 059-145-10

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Ammons (LAST) Michael (FIRST) Douglas (MIDDLE)

2) ADDRESS OF OWNER 5723 Rowan Way ZIP 28214

3) PHONE NO. Home 392-0941 Office _____


4) LOCATION OF PROPERTY Rowan Way (STREET OR COUNTY ROAD)

5) SUBDIVISION _____ LOT NO. 28-30 BLOCK NO. 145

MAP BOOK NO 59 PAGE NO. 14

6) DEED REFERENCE: DEED BOOK 4241 PAGE NO. 435

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

x Michael D. Ammons
OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

DEPARTMENT OF
ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 20546

T.C. NO. 054-145-10

(Ground Absorption Sewage Disposal)

OWNER: Michael D. Simmons
ADDRESS: 5723 Rowan Alley
Charlotte, N.C. 28214
LOCATION OF SITE: Rowan Alley

PLAT NO: Lots 29-30
LOT SIZE: 13,350

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS 2-8% U	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S (PS) clay U	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) Blocky U	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	S (PS) 36-40" U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S >36" (PS) U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	(S) 48" to PS ground U water	S PS U	S PS U	S PS U
7. OTHER (Specify)	S Restricted PS Area (U)	S PS U	S PS U	S PS U
8. SOIL GROUP	1UA			
9. SITE CLASSIFICATION	unsuitable			
10. SOIL SERIES	Cecil-Urban			

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)


Recommendations/Comments:

Described by: William A. Marlin
Title: Soil Scientist

Date: 2-22-94

EHD 539 (Revised: 6/82)

1H


179'
75'
Creek Line
75'
179

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
5300 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28213

SIR. NO. 20596
T.C. NO. 059-145-10
DATE: 2-23-84

Michael D. Ammons
5723 Rowan Way
Charlotte, NC 28214

Re: Property located at Rowan Way, Lots 28-30

Dear Mr. Ammons:

At your request, a field investigation was conducted on the property designated above. The soils on the property were found to contain a limited area of provisionally suitable soil for the installation of a ground absorption sewage disposal system. A copy of the site evaluation report is enclosed for your information.

Should you desire to file for permission to install a ground absorption sewage disposal system, please submit plot plans for the proposed construction, well, and ground absorption sewage disposal system to this office. They will be reviewed and if it is found that there is an adequate area of provisionally suitable soil to accommodate the proposed installation, an Improvements Permit will be issued by this office.

If I may be of assistance, please feel free to call.

Sincerely,

Bill D. Hardister

Bill D. Hardister, Jr.
Environmental Health Supervisor

BDH/kbg

Enclosure