Date Received 9-17-73

MECK COUNTY HEALTH DEPT.
RECEIVED
SEP 1 1973
ENVIRONMENTAL HEALTH DIVISION

APT No 7001

T C No 198-331-06

Map Date 9-24-71

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER Klutts Realty & Construction Co., Inc.
(LAST FIRST MIDDLE)

2) ADDRESS OF OWNER 1433 Emerywood Drive Charlotte, N. C. ZIP 28210

3) PHONE NO Home 525-5265 Office Same


4) LOCATION OF PROPERTY 2531 Gum Wood Court
(STREET OR COUNTY ROAD)

5) SUBDIVISION Wood Hollow LOT NO 14 BLOCK NO 3

MAP BOOK NO 17 PAGE NO 71

6) DEED REFERENCE DEED BOOK PAGE NO

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

OWNER
Vice-President
Klutts Realty & Const. Co., Inc.

FORM NO E-1-9-1-72

HEALTH DEPARTMENTS COPY

Serial No. 3893

PTR No 7001
P.O.
T C No 193-331-06
Map Date 9-24-71

Date Issued November 7, 1973

Do Not Issue A Building Permit Based On This Form

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION


PERCOLATION TEST REPORT

NAME OF OWNER Klutts Realty & Construction Co., Inc.
LAST FIRST MIDDLE

ADDRESS OF OWNER 1433 Ferncrest Drive ZIP 28210

LOCATION OF PROPERTY 6231 Jim Wood Court
STREET OR COUNTY ROAD

SUBDIVISION Wood Hollow LOT NO 14 BLOCK NO 3



PLOT PLAN

This is to certify that a percolation test has been run and an on-site inspection made by the Mecklenburg County Health Department on the lot described above. The said test was conducted on that portion of the lot as indicated on above plot.

The percolation rate determined by the test was 60 min/in. The said lot is approved for the installation of an individual septic tank wastewater treatment system with sub-surface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter, or repair the specific system shall be obtained from the Mecklenburg County Health Department prior to the beginning of any construction of buildings, or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Health Department prior to installation based on the percolation rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area where the percolation test was run.
4. This approval is void if any grading, filling, or construction, including the drilling of a well, is performed on the lot which, in the opinion of the Health Department, renders the area where the percolation test was run unsuitable for the installation, construction, alteration, and/or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina State Board of Health and the Mecklenburg County Board of Health which were in effect on the date of issuance and is void if at any time in the future prior to the completion of the system, these laws, rules, and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

John Robinson
Director, Environmental Health Division or
Authorized Section Head

FORM NO E-2-9-1-72

HEALTH DEPARTMENT'S COPY

SEE INSTRUCTIONS ON BACK

Date Received 11-9-73

ICAR (S) Application No 7001

T C No 173-3.31-06

Map Date 9 24 73


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

Application for an
Installation, Construction, Alteration, and/or Repair Permit
Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge

The owner of that property described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to:

1) X Install or Construct 2) ___ Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption, effluent discharge



3) PLOT PLAN (ACCURATELY DIMENSIONED)

4) No of Bedrooms 3

5) Business Use Max No Employees ___

6) Washing Machine ✓ Yes ___ No

7) Garbage Disposal ✓ Yes ___ No

8) Dishwasher ✓ Yes ___ No

9) Water Supply
A Individual Well ✓
B Government ___
C Community ___
1 Well source ___
2 Government ___

10) Sewage System
House located within 200 feet of public sewer ___ Yes ✓ No
House located within 200 feet of community sewer ___ Yes ___ No

11) FHA Case No N/A

12) VA Case No APPLIED FOR

13) NAME OF OWNER KLUTTS (LAST) REALTY & CONSTRUCTION (FIRST) CO., INC (MIDDLE)

14) ADDRESS OF OWNER 1433 CEMETERY WOOD DRIVE

15) PHONE NO. Home 525-2864 Office Same

16) LOCATION OF SYSTEM 2531 GUM WOOD COURT (STREET OR COUNTY ROAD)

17) SUBDIVISION WOOD HOLLOW Lot No 14 Block No 3

Map Book No 17 Page No 71

18) DEED REFERENCE — DEED BOOK ___ AT PAGE ___

19) HAS A PERCOLATION TEST BEEN RUN? ✓ YES ___ NO DATE RUN 9-24-73 PR 760

20) PTR NUMBER (See Instructions) 7001

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

DATE OF APPLICATION 11/8/73

OWNER Charles P. Beam KLUTTS REALTY & CONST. CO., INC.

FORM NO E-4-9-1-72

HEALTH DEPARTMENT'S COPY

Serial No. 3703

LA No. 7001
P.O.

Date Issued December 12, 1973

T C No 193-331-06

Improvements permit

Map Date 9-24-73

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Klutts Realty & Construction Co., Inc.
(LAST / FIRST / MIDDLE)

ADDRESS OF OWNER 1433 Emerywood Drive ZIP

LOCATION OF LOT 2531 Gumwood Court
(STREET OR COUNTY ROAD)

SUBDIVISION Wood Hollow LOT NO. 14 BLOCK NO. 3

MAP BOOK NO. PAGE NO.

The above specified lot is approved by the Mecklenburg County Health Department for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the percolation test results which yielded a percolation rate of 60 min/inch on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 7001. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered, and/or repaired in the same area where the percolation test was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altred, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

Environmentalist

John R. Adkisson
Director, Environmental Health Division or Authorized Section Head

FORM NO E-3-4-1-71

HEALTH DEPARTMENT'S COP

Serial No.

Date Issued 20 Apr 24

ICAR(S) Permit No 7001

P & T C No 173-331-06

Map Date 24 Apr 73


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ~~Install~~ or Construct, Alter or Repair the individual septic tank waste water treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 7001 dated 8 Nov 73 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 30 May 74 after which date this permit shall be null and void.



PLOT OF SYSTEM

Percolation Rate 60

Liquid Capacity of Tank 1500

Tank Construction PC

Absorption and/or Nitrification Lines

Total Line Lenght 600' + 150' (4 lines)
3 (75' X 50' lines)

Number of Lines 6 (15' X 100' X 17")

Distance from House 15'

Distance from Property Line 15'

Distance from Well 100'

NAME OF OWNER Piety Poultry & Const. Co. Inc.

LOCATION OF PROPERTY 2531 Shamrock [redacted] (Cotton)

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Board of Health which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Health Director before any system can be covered up or otherwise rendered uninspectable or can be used.

Comments County - Septic (Conv.)

Division or Section Head

Environmentalist

If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Environmental Health Division in order to be valid. Only the signature of the Environmental Health Specialist is required where an existing system is being altered or repaired.

E-5-8-1-72

Serial 4739

C of A (s) No. 7001

Date Issued 3 May 74

F.O T C No. 193-334-06

Map Date 24 Apr 73

CERTIFICATE OF CORRECTION

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner _____ (LAST) _____ (FIRST) _____ (MIDDLE)

Location of Property 2531 _____ Court (Lot 14-3)

Application Number 7001 Permit Number 7001

Inspection Data:

Liquid Capacity of Tank 1500 Tank Material PC

Total Length of Drain Tile 600' + 150' conn. Number of Lines 3 (24"x50"x17") 6 (15"x100"x10")

Depth of Filter Material 17" Cover Depth 18"

Water Supply Source Ind. Well Distance from Water Source 100'

Excavation Inspected 2 May 74 (DATE) Tank Inspected 2 May 74 (DATE)

Nitrification Field Inspected 2 May 74 (DATE)

Washing Machine Line Inspected, If Applicable 3 May 74 (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ✓ installed or constructed, _____ altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Board of Health in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments: County Septic (Cont.)

_____

_____

_____

_____

_____ (ENVIRONMENTALIST)

FORM NO. E-6-61-71

HEALTH DEPARTMENT'S COPY

NORTH CAROLINA DEPARTMENT OF NATURAL AND ECONOMIC RESOURCES
OFFICE OF WATER AND AIR RESOURCES
GROUND WATER DIVISION
P. O. BOX 27687 – RALEIGH, N. C. 27611

WELL RECORD

File

DRILLING CONTRACTOR: Crawford Well Drilling REG. NO. 270 WELL CONSTRUCTION PERMIT NO. A-

1. WELL LOCATION: (Show a sketch of the location on back of form)
   Nearest Town: Matthews County: Mecklenburg
   2527 Oak Knoll Court, Lot 15, Block 3 Quadrangle No.
2. OWNER: Klutts Realty & Const. Co. Inc.
3. ADDRESS: 2433 Sharpwood Dr. Charl. 28210
4. TOPOGRAPHY: (draw, valley, slope, ridge, flat)
5. USE OF WELL: Domestic DATE: 2/27/74
6. DOES THIS WELL REPLACE AN EXISTING WELL?
7. TOTAL DEPTH: 105 RIG TYPE OR METHOD: Rotary
8. FORMATION SAMPLES COLLECTED: ☐ YES No. of Bags
9. CASING:

Depth From	Depth To	Inside Diam.	Wall Thick. or weight/ft.	Type
0	75 ft.	6"		PVC

10. GROUT:

Depth From	Depth To	Material	Method
0	20 ft.		Bakrite

11. SCREEN:

Depth From	Depth To	Diam.	Type and Opening
	ft.		

12. GRAVEL:

Depth From	Depth To	Size	Material
	ft.		

13. WATER ZONES (depth): 105
14. STATIC WATER LEVEL: 20 ft. below top of casing.
    Casing is 1 ft above land surface. ELEV.
    DATE MEASURED: 2/27/74
15. YIELD (gpm): 20 METHOD OF TESTING: Air
16. PUMPING WATER LEVEL: 100 ft. after 8 hours
    at 20 gpm.
17. CHLORINATION: Type: NTH Amount
18. WATER QUALITY: TEMPERATURE (°F)
19. PERMANENT PUMP: (Show a sketch of well head on back of form)
    Date Installed 2/27/74 Type Deepwell Make Myers
    Capacity 10 (gpm) HP 1
    Intake Depth Airline Depth
20. HAVE YOU INFORMED THE WELL OWNER OF THE DEPARTMENTS REQUIREMENTS AND RECOMMENDATIONS? Yes
21. REMARKS:

DRILLING LOG

Depth From	Depth To	Formation Description
0	30	Red Clay
30	75	Yellow Shale
75	105	Blue & White Granite Rock

I do hereby certify that this well record is true and exact

Charles R Crawford 2/27/74
SIGNATURE OF CONTRACTOR OR AGENT DATE

Form GW-1 White Copy - Office of Water and Air Resources; Blue - Drillers Copy; Green - Owners Copy