CERTIFICATE OF COMPLETION/OPERATION PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

77-B
FILE: 7967-A DATE: 11-19-92
PO
TC: 137-132-03 ☐ L ☑ CRT
SERIAL Nº 15118

Name of Owner Cherry Homes Juris.:
Address of Property 9643 Edwards Place

Inspection Data:

Tank Material PCC
Total Length of Drainfield 400'
Number of Lines 5 @ 80'
Cover Depth 12" - 18"
Water Supply Source Comm.
Distance to Water Source –
Excavation Inspected 11-19-92
Tank(s) Inspected 11-19-92
Wash Line Inspected
High Water Alarm Inspected

PLOT

Design: 1992, 1500ST, CON, 1200SFT, 12G, Cecil CTR# 113

The undersigned has inspected the Septic Tank System described above, and certifies it has been
☑ installed or constructed ☐ altered or repaired
☑ in accordance with the permit issued ☐ as detailed in the plot above
and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this
☑ Certificate of Completion ☐ Operation Permit
does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS: Installed for 3 bedrooms TYPE II

B. R. Ferguson
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

D40 D **INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT**

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603


77-B

FILE: 7967-A DATE: 10-26-92

PO TC: 137-132-03 ☒ L

SERIAL Nº 15109

Permission is hereby given to ✓ Install or Construct, _____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 7-24-92. All work shall be completed on or before 11-26-92, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Health Department before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



Edwards Pl

PLOT OF SYSTEM

Liquid Capacity of Septic Tank 1500 gallons

Liquid Capacity of Dosing Tank _____ gallons

Tank Construction Pcc

Absorption and/or Nitrification Lines:

Trench Width 3 feet

Total Line Length 400 feet

Number of Lines 5

Depth of Stone 12 inches

Distance from House 5 feet

Distance from Property Line 10 feet

Distance from Well Comm feet

NAME OF OWNER Cherry Homes

LOCATION OF PROPERTY 9643 Edwards Place

Comments: 5 lines 3'X80'X12" stone

Division or Section Head

B. R. Ferguson
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Mecklenburg County Health Department in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - HEALTH DEPARTMENT'S COPY • CANARY - ENVIRONMENTALIST'S COPY • PINK - OWNER OR AGENT'S COPY

LA

#2127 $200.00 07/29/92 7967A | 7968 CRT

INDIVIDUAL WATER AND WASTEWATER SYSTEMS PROGRAM
APPLICATION FOR SERVICES

Mecklenburg County Health Dept.
Environmental Health Division
c/o Hal Marshall Ctr., Suite 211
700 N. Tryon St.
Charlotte, NC 28202

(704)336-5102

Date: 7-29-92

PROPERTY INFORMATION (FROM ENGINEERING FORM):

TAX/PARCEL NUMBER: 137-132-03 PO

STREET ADDRESS: ~~10426~~ 9643 EDWARDS PL

PERSON FILING APPLICATION:

NAME: Cherry Homes
(last) (first) (mi)

ADDRESS: 11407 E IND BLVD PHONE: (__) 847 8300

CITY: Matthews STATE: NC ZIPCODE: 28105

PROPERTY OWNER:

NAME: Same
(last) (first) (mi)

ADDRESS: _____ PHONE: (__) _____

7967A

0077B

9643 EDWARD'S PL

13724101

12/17/07

duponbj


PROPOSED PLOT PLAN

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON STREET
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 77B/7967-A

TC: 137-132-03

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



☐ = 10'

APPROVAL DATE _____

White - Original Canary - Environmentalist's Copy Pink - Owner's Copy

DATE 8/6/92

TO: CHARLOTTE-MECKLENBURG BUILDING STANDARDS
PERMIT ISSUING SECTION

FROM: MECKLENBURG COUNTY ENGINEERING

JURISDICTION Mint

137-132-03
PARCEL NUMBER

9643 Edwards Pl
ASSIGNED STREET ADDRESS (ADDRESS OF RECORD)

10426 Edwards Pl
EXISTING STREET ADDRESS (IF DIFFERENT FROM ASSIGNED)

Bainbridge 3
PROJECT NAME (IF APPLICABLE)

THE ABOVE DESCRIBED LOCATION HAS BEEN CHECKED CONCERNING:

1. SUBDIVISION REGULATIONS	**APPROVED**	**NOT APPROVED**
2. FLOODWAY REGULATIONS	**APPROVED**	**NOT APPROVED**
3. EROSION CONTROL REGULATIONS	**APPROVED**	**NOT APPROVED**
4. COMMERCIAL DRAINAGE PLAN	**APPROVED**	**NOT APPROVED**
5. PUBLIC UTILITY EASEMENT	**PRESENT**	**NOT PRESENT**
6. PROPERTY FRONTS ON THOROUGHFARE	**YES**	**NO**
7. DRIVEWAY PERMIT REQUIRED	**YES**	**NO**
8. DOES PROJECT CONFLICT WITH ROAD PROJECT?	**YES**	**NO**

REMARKS: S. J Home

NOTE: THIS FORM MUST BE TURNED IN AT THE CASHIERS OFFICE WHEN PAYING PERMIT FEE. CERTIFICATE OF OCCUPANCY WILL NOT BE GRANTED UNTIL TRANSPORTATION DIVISION GRANTS FINAL APPROVAL ON DRIVEWAY(S).

ALL OTHER FORMS OBSOLETE

☐ NEW ADDRESS

SIGNED: Pence

REVISED 1/91

TO: ENVIRONMENTAL HEALTH DEPT.
BUILDING STANDARDS DEPT.
DEPT. OF ENVIRONMENTAL PROTECTION/
SOLID AND HAZARDOUS WASTE

DATE 8/6/92

FROM: COUNTY ENGINEERING DEPARTMENT

EHD FILE _____ JURISDICTION CODE Mint

PARCEL NUMBER # 137-132-03

ASSIGNED ADDRESS 9643 Edwards PL

EXISTING ADDRESS 10426 Edwards PL

PROJECT NAME Bainbridge 3

THE ABOVE DESCRIBED LOCATION HAS BEEN CHECKED CONCERNING:

	APPROVED	DISAPPROVED
1. SUBDIVISION REGULATIONS	/ /	/ /*
2. FLOODWAY REGULATIONS	/ /	/ /*
3. EROSION CONTROL REGULATIONS	/ /	/ /*
4. PUBLIC UTILITY EASEMENT	/ /	/ /*

	PRESENT	NOT PRESENT
5. PUBLIC UTILITY EASEMENT	/ /*	/ /
6. PROPERTY FRONTS ON THOROUGHFARE	/ /*	/ /
7. DRIVEWAY PERMIT REQUIRED	/ /*	/ /

*If checked, further investigation will be required to determine whether a building permit can be issued by Building Standards for the site.

REMARKS: (S. Tibre) Addres Verified

NOTE: THIS FORM MUST BE TURNED IN AT THE CASHIER'S OFFICE AT BUILDING STANDARDS WHEN PAYING PERMIT FEES.
A CERTIFICATE OF OCCUPANCY WILL NOT BE GRANTED UNTIL THE TRANSPORTATION DIVISION GRANTS FINAL APPROVAL ON DRIVEWAY(S).

SIGNED: _____

OPWEAR 06-88

NEW ADDRESS / /*

FORM 100

MECKLENBURG COUNTY
ENGINEERING DEPARTMENT

MEMORANDUM

To: Records

From: House Numbering/Mapping Section

Subject: Change of Address

Date: 8/6/92

Please change your records to correspond with the following corrected addresses:

From: 10426 Edwards Pl /**Jurisdiction** Mint

To: 9643 Edwards Pl /**Jurisdiction** Mint

Tax Parcel No: 137-132-03

Remarks:

Thank you for your cooperation.

Pace

D400 LA File: 7967A / 713

$100.00 Transferred to Prest 760 pd $200-625-92 #30286

INDIVIDUAL WATER AND WASTEWATER SYSTEMS PROGRAM
APPLICATION FOR SERVICES

[X] CRT

Mecklenburg County Health Dept
Environmental Health Division
c/o Hal Marshall Ctr., Suite 211
700 N. Tryon St.
Charlotte, NC 28202

(704)336-5102

Date: 6/25/92

PERSON FILLING APPLICATION:

NAME: MOSER (last) DAN (first) L. (mi)

ADDRESS: 2101 SARDIS RD. N. # 110 PHONE: (704) 845-1378

CITY: CHARLOTTE STATE: NC ZIPCODE: 28227

PROPERTY INFORMATION (FROM ENGINEERING FORM):

TAX/PARCEL NUMBER: PO 137-132-03

STREET ADDRESS: 10426 Edward's Pl

BAINBRIDGE III

ZONING: R 30

PROPERTY OWNER:

NAME: MOSER (last) DAN (first) L. (mi)

ADDRESS: 2101 SARDIS RD.N. #110 PHONE: (704) 845-1378

CITY CHARLOTTE STATE: NC ZIPCODE: 28227

SUBDIVISION OR MOBILE HOME PARK NAME:
BAINBRIDGE III

Township (check one):
[X] 0 Mecklenburg County [ ] 2 Davidson [ ] 4 Pineville [ ] 6 Huntersville
[ ] 1 Charlotte [ ] 3 Cornelius [ ] 5 Matthews [X] 7 Mint Hill

LOT NUMBER: 30 B-1 LOT SIZE (in acres): 1.10

TYPE APPLICATION (check one):

[X] SOIL TEST - INDIVIDUAL LOT (D)
[ ] NEW CONSTRUCTION ON VACANT LOT - 4 BEDROOMS OR LESS (N)
[ ] EXCHANGE MOBILE HOME - SAME # BEDROOMS (Y)
[ ] ADDITION - INCREASE ROOMS/OCCUPANCY/MOBILE HOME SIZE (A or M)
[ ] COMMERCIAL OR INDUSTRIAL (N)
[ ] SOIL TEST DEVELOPMENT (P)
[ ] ADDITION - GARAGE OR RENOVATION/NO MAJOR CHANGES (X)
[ ] MODIFIED /ALTERNATIVE/ OR RESIDENCE > 4 BEDROOMS (Z)
[ ] REPAIR TO SYSTEM (R)

RESIDENTIAL PROPERTY (Type Building, check one):
[ ] SINGLE MOBILE HOME (S) [X] HOUSE (H) [ ] MULTIPLE FAMILY (U)
[ ] DOUBLE WIDE (D) [ ] MODULAR HOME (M) [ ] OTHER _____ (O)

NUMBER BEDROOMS: 3 NUMBER OCCUPANTS: 3-6

SYSTEM CLASSIFICATION: CONVENTIONAL

COMMERCIAL/INDUSTRIAL PROPERTY:
Type Business _____ # Employees ___ Per Shift ___ ___ ___
Industrial Wastes (Y/N) ___
Underground Storage Tanks On Property (Y/N) ___ Type _____

WATER SUPPLY (check one):
[X] Community (C) [ ] Shared Well (S)
[ ] Municipal (M) [ ] Other 'spring' (O)
[ ] Private Well (P)

FUTURE ADDITIONS - ALL PLANNED ADDITIONS MUST BE ENTERED (check all that apply): initial building phase.
[ ] Swimming Pool [ ] Jacuzzi [ ] Stable/Barn [ ] Workshop [ ] None
[ ] Garage [ ] Storage Building [ ] Deck/Patio [ ] Bedrooms [ ] Other

The undersigned, owner, or legal agent for the owner, of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: Dan L Moser Date: 6/25/92

NOTICE:

The undersigned, an authorized agent of the MECKLENBURG COUNTY HEALTH DEPARTMENT, certifies that the Department has approved the the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

...No work shall be conducted on the septic tank system until an installation, Construction, Alteration and/or Repair approval is granted by this Department.

...This permit is not transferable.

...

[ ] IMPROVEMENT PERMIT - VALID 60 MONTHS FROM ISSUANCE
[ ] MOBILE HOME EXCHANGE APPROVAL - VALID 6 MONTHS FROM ISSUANCE
[ ] ADDITION/RENOVATION APPROVAL - VALID 1 YEAR FROM ISSUANCE

B. R. Ferguson
Environmentalist — 7-16-92 Date

Director or Authorized Section Head — 7-17-92 Date

WWATER : 122791


PROPOSED PLOT PLAN

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON STREET
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 77B/7967-A

TC: 137-132-03

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



☐ = 10'

APPROVAL DATE _____

White - Health Department's Copy Canary - Environmentalist's Copy Pink - Owner's Copy

DAN L. MOSER CO.
2101 SARDIS RD. N.
SUITE 110
CHARLOTTE, N.C. 28227
845-1378 - 847-9027
FAX: 845-1378

1992-559



I heard it through the FAX LINE



TELECOPIER COVER LETTER

DATE: 7/20/92

TO: Lorraine

FROM: Shara to Lot 30 B-1

RE: Lot 29 B-1

TOTAL NUMBER OF PAGES (INCLUDING COVER SHEET): 1



PLEASE CALL US IMMEDIATELY IF THE TELECOPY YOU RECEIVE IS INCOMPLETE OR ILLEGIBLE.

Dan Moser Company

July 20, 1992

Mecklenburg County
Charlotte, NC

Attn: Lorraine

Our check number 30286 dated July 23, 1992 for the water and wastewater systems on Lot 30 Block 1 Bainbridge III needs to be transfer to Lot 29 Block 1 Bainbridge III, 10410 Edwards Place.

If you have any questions, please contact our office.

Thanks very much.

Very truly yours,

DAN MOSER COMPANY

Dan L. Moser
President

DLM/cw

9101 Sardis Road North, Suite 110 • Charlotte, N. C. 28227 • (704) 815-1378

Mecklenburg County
Health Department

February 3rd, 1992

Dan L. Moser
2101 Sardis Road North #110
Charlotte, NC 28227

RE: Property located at 10426 Edward's Place 30/1
FILE: 7967A/77B
PARCEL: 137-132-03PO

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. The property was found to contain a limited area of soils which were classified as PROVISIONALLY SUITABLE for such an installation. A copy of the Site Evaluation Report (Serial Number 12446) is enclosed for your information.

Should you desire to file for permission to install a ground absorption sewage disposal system, please submit an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems to this office. The plan will be reviewed and if it is found that the area of provisionally suitable soils is adequate for the proposed construction, an Improvement Permit will be issued by this Department.

If there are any questions concerning this matter, contact Bill Marlin, Soil Scientist, at 336-5574.

Sincerely,

Gene Vaughan, R.S., Supervisor
Individual Water and Wastewater Systems

Enclosure

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 12446

File: 7967A/77B Action 1

Parcel: PO 137-132 03

☑ PC

Location: 10426 Edwards Place

Subdivision: Bainbridge III


Lot: 30 Block: 1 Acres: 1.1

Owner: Dan L. Moser
Address: 2101 Sardis Road N. #110
Charlotte, N.C. 28227

Comments: 100% Repair
system may need lift
pump

Described by: William A. Marlin

Date: 1-29-92



***** EVALUATION KEY *****

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	(S) PS U 2-10%	S PS (U) >2' cut	S PS (U) complex slopes	S PS (U) Drainageway/Depression	S PS U	S PS U
Texture	slightly Expansive clay S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U subblocky	S PS U	S PS U	S PS U	S PS U	S PS U
Drainage	S (PS) U >40" to water	S PS U	S PS U	S PS U	S PS U	S PS U
Depth	S (PS) U >40"	S PS U	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U >40"	S PS U	S PS U	S PS U	S PS U	S PS U
Available Space	S (PS) U limited	S PS U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IV Cecil-like	>2' cut	Complex slopes	Drainageway/Depression		
Area Classification	S (PS) U	S PS (U)	S PS (U)	S PS (U)	S PS U	S PS U

APPLICATION FOR SOIL INVESTIGATION

LDCR

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 1967A (71B)

TC: 137-132.03

☐ PC ☐ REPT

JOB LOCATION

① ADDRESS: 10426 Edward's Place Mint Hill

② SUBDIVISION: Bainbridge III ③ LOT: 30 ④ BLOCK: 1

⑤ PARCEL REFERENCE: BOOK NO.: 137 PAGE NO.: 132 PARCEL NO.: 43

⑥ DEED REFERENCE: BOOK NO.: PAGE NO.:

OWNER


⑦ NAME: Dan (FIRST) L (MIDDLE) Moon (LAST)

⑧ MAILING ADDRESS: 2101 Sardis Rd N. #110

⑨ CITY: Charlotte ⑩ STATE: NC ⑪ ZIP: 28227

⑫ PHONE: (WORK) 845-1378 (HOME) 845-1293

⑬ Accurately diagram and dimension lot.



⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: Dan L Moon

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

Date: 1/9/92

WHITE - HEALTH DEPARTMENT'S COPY • CANARY - ENVIRONMENTALIST'S COPY • PINK - OWNER'S COPY

APPLICATION FOR SOIL INVESTIGATION

$75.00

DLH

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 7967A (7B)

TC: 137-132-03

☐ PC ☐ REPT

CK #29681
11/09/92

JOB LOCATION

① ADDRESS: 10426 Edward's Place Mint Hill

② SUBDIVISION: Bainbridge III ③ LOT: 30 ④ BLOCK: 1

⑤ PARCEL REFERENCE: BOOK NO.: 137 PAGE NO.: 132 PARCEL NO.: 13

⑥ DEED REFERENCE: BOOK NO.: _____ PAGE NO.: _____

OWNER


⑦ NAME: Dan (FIRST) L (MIDDLE) Moss (LAST)

⑧ MAILING ADDRESS: 2101 Sardis Rd N. #110

⑨ CITY: Charlotte ⑩ STATE: NC ⑪ ZIP: 28227

⑫ PHONE: (WORK) 845-1378 (HOME) 845-1293

⑬ Accurately diagram and dimension lot.



⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: Dan L Moss

Date: 11/9/92

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

WHITE - HEALTH DEPARTMENT'S COPY • CANARY - ENVIRONMENTALIST'S COPY • PINK - OWNER'S COPY

Mecklenburg County
Health Department

February 3rd, 1992

Dan L. Moser
2101 Sardis Road North #110
Charlotte, NC 28227

RE: Property located at 10426 Edward's Place 30/1
FILE: 7967A/77B
PARCEL: 137-132-03PO

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. The property was found to contain a limited area of soils which were classified as PROVISIONALLY SUITABLE for such an installation. A copy of the Site Evaluation Report (Serial Number 12446) is enclosed for your information.

Should you desire to file for permission to install a ground absorption sewage disposal system, please submit an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems to this office. The plan will be reviewed and if it is found that the area of provisionally suitable soils is adequate for the proposed construction, an Improvement Permit will be issued by this Department.

If there are any questions concerning this matter, contact Bill Marlin, Soil Scientist, at 336-5574.

Sincerely,

Gene Vaughan, R.S., Supervisor
Individual Water and Wastewater Systems

Enclosure


PROPOSED PLOT PLAN

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON STREET
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 77B/7967-A

TC: 137-132-03

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



APPROVAL DATE _____

White - Health Department's Copy Canary - Environmentalist's Copy Pink - Owner's Copy

ONE/TWO FAMILY, MODULAR, MOBILE HOME OR ZONING USE

LOCATION

STREET # (N,S,E,W) 10426 STREET NAME Edwards (AV,RD,ST, etc) D


SUITE/UNIT(S):

PERMIT # B160257

TAX JURISDICTION: (Check One)
☒ 0-Mecklenburg ☐ 1-Charlotte ☐ 2-Davidson ☐ 3-Cornelius
☐ 4-Pineville ☐ 5-Matthews ☐ 6-Huntersville ☐ 7-Mint Hill

TAX PARCEL # 137-132-02 JOB # 2061

EXAMPLES/PLOT PLAN




- INSTRUCTIONS -

In the space provided below, draw plot plan as neatly and accurately as possible, from survey if available.

1. Draw street(s) and right-of-way(s).
2. Draw property lines with dimensions.
3. Draw proposed and existing buildings showing any attached porch(es), deck(s), chimney(s), carport(s), or garage(s), etc...
4. Show distances of buildings from property lines or other structures.
5. Separate application and plot plan required for each building.

- PLOT PLAN - Oc - 1.10 ac



ALL EXISTING AND PROPOSED BUILDING(S) ON LOT ARE SHOWN WITH MEASUREMENTS INDICATED

APPLICANT'S SIGNATURE DATE 4/12 PRINT APPLICANT'S NAME Dan Moser

APPROVED BY HP

CHARLOTTE-MECKLENBURG BUILDING STANDARDS DEPARTMENT
P.O. BOX 31097 • CHARLOTTE, NC 28231-1097 • 704/336-2831

B-83

PERMIT DAN MOSER CONST. 17048451378 P.04

CHARLOTTE-MECKLENBURG COUNTY ENVIRONMENTAL HEALTH File: 79-9-7A/1979 Action 1

SITE EVALUATION REPORT

SITE EVALUATION REPORT
SERIAL NUMBER № 12446

Parcel: PO 137-132-03

☑ PC

Location: 10426 Edwards Mill

Subdivision: Shadowridge III


Lot: 30 Block: 1 Acres: 1.1

Owner: Dan Z. Mazer
Address: 2101 Sardis Road N. #110
Charlotte, N.C. 28227

Comments: 10% Appeal
Typical easy excav. lift
groups

Described by: Phillip A. Mueller

Date: 1-29-97



***** EVALUATION KEY *****

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	(S) PS U 2-10%	S PS (U) >2' cut	S PS (U) complex slopes	S PS (U) Diversion/	S PS U Depression	S PS U
Texture	S (PS) U slightly Erosion prone	S PS U	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U subangular	S PS U	S PS U	S PS U	S PS U	S PS U
Drainage	S (PS) U >24" to water	S PS U	S PS U	S PS U	S PS U	S PS U
Depth	S (PS) U >40"	S PS U	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U >40"	S PS U	S PS U	S PS U	S PS U	S PS U
Available Space	S (PS) U limited	S PS U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	TL Cecil like	>2' cut	complex slopes	Diversionary Appears		
Area Classification	S (PS) U	S PS (U)	S PS (U)	S PS (U)	S PS U	S PS U