

7916 WHITE CLIFFS DR

13904137

1/3/2008

duponbj

Groundwater and Wastewater Services File Imaging Project

May 2007

Barcode Font = IDAutomationHC39M

CERTIFICATE OF COMPLETION/OPERATION PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON ST., SUITE 211
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 3731B DATE: 5/8/96

TC: 139 04/04 ☐ L ☐ CRT

SERIAL Nº 16570

Name of Owner Dublin Homes Juris.:

Address of Property 7916 White Cliffs Dr

Inspection Data:

Tank Material PCC

Total Length of Drainfield 300'

Number of Lines 3 @ 133'

Cover Depth 12"

Water Supply Source well

Distance to Water Source > 75'

Excavation Inspected 5/8/96

Tank(s) Inspected 5/7/96

Wash Line Inspected plumbed to Tank

High Water Alarm Inspected 5/8/96

PLOT

Design 1996, 1500ST, 1000PT, PI, INO, 300' Chamber cecil CTR# RLS

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☒ installed or constructed ☐ altered or repaired

☒ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of 15A NCAC 18A. 1900, "Laws And Rules For Sewage Treatment and Disposal Systems" in effect on the date of issuance of the permit. This issuance of this

☐ Certificate of Completion ☒ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 15A NCAC 18A. 1990 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Notice: Disturbance of the designated repair area may result in the suspension/revocation of this permit.

COMMENTS: Septic system designed for 3 bedroom residence Type III

Philip S. Walker R.S
Environmental Health Specialist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR APPROVAL


HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON ST., SUITE 211
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 3731B DATE: 4/2/96 (400)

TC: 139 041 04 ☐ L

SERIAL № 16717

Permission is hereby given to ✓ Install or Construct, _____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 1/1/95. All work shall be completed on or before 5/2/96, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 15A NCAC 18A. 1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Health Department before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank 1500 gallons

Liquid Capacity of Dosing Tank 1000 gallons

Tank Construction PCC

Trench Depth 24"

Absorption and/or Nitrification Lines:

Trench Width 3' feet

Trench Walls Scored and Porous -

Total Line Length 400' feet

Number of Lines 3 (133')

Depth of Stone NA inches

Distance from House 15' feet

Distance from Property Line 10' feet

Distance from Well >100' feet (50' min)

NOTICE: This system shall not be installed while soils are in a wet condition.

NAME OF OWNER Dublin Homes

LOCATION OF PROPERTY 7916 White Cliffs Dr

Comments: 1500 ST, 1000 DT, Chamber system 3 lines x 133' long x 3' wd
Keep septic system >100' (50' min) from well

Thela S. Walker R.S.
Environmental Health Specialist

Permit Number: 3731B

CONDITIONS OF IMPROVEMENT PERMIT

Tax Number: 139 041 04

- The IMPROVEMENT PERMIT is subject to revocation if site plans or the intended use change. There is to be **NO** grading, filling or disturbance of the soil in the area of the septic tank system or repair area.
- CONSTRUCTION AUTHORIZATION must be obtained prior to receiving a Building Permit. The Construction Authorization is **NOT** transferable. Do *not clear, grade, fill or disturb soil prior to obtaining a Construction Authorization.*
- Domestic-type wastewater only. No industrial process wastewater may be discharged into the system.

Basement	___ Yes	✓ No	___ Partial Basement
Type Primary Wastewater System Type (circle one): I II (III) IV V VI	___ Conventional ___ Prefabricated, permeable block panel system ___ Shallow Placed Conventional	___ Low Pressure Pipe ___ Large Diameter Pipe ___ Fill ___ Other	___ Innovative or Experimental: ___ IWWS-93-1 ✓ IWWS-93-2 ___ IWWS-94-1

.3 Long-term acceptance rate	480 Max gallons/day wastewater flow	1200 Absorption Area (sq ft)	9' Trench spacing (min. on centers)
YES Serviced by private well	1500 Gallon septic tank	400' Total trench length (ft)	24" Maximum trench depth (At least 12" of provisionally suitable soil must remain between trench bottom and unsuitable soil conditions)
4 Bedrooms in residence	1000 Gallon pump tank	NA Depth of stone	

Any surface waters present: NO Type: Minimum separation distance:

Site modifications required: Front entry garage

Additional Conditions: IWWS 93-2-R1, Original plan altered
Need copys of wastewater Treatment and Disposal System Design Agreement form and Replacement system agreement form in file. 2" additional soil cover to be installed for repair area.

Repair Area System Type Type (circle one): I II (III) IV V VI	___ Conventional ___ Prefabricated, permeable ✓ block panel system ___ Shallow Placed Conventional	___ Low Pressure Pipe ___ Large Diameter Pipe ___ Fill ___ Other	___ Innovative or Experimental: ___ IWWS-93-1 ✓ IWWS-93-2 ___ IWWS-94-1

~~1200~~ 1605 Absorption Area (Sq ft) ~~460~~ 535 Total Trench Length (Ft)	~~NA~~ 12" Depth of Stone Trench	9 Trench spacing (min. on centers)	~~24~~ 16" Maximum Trench Depth
For existing system, enter the year originally installed:			

The undersigned, an authorized agent of the MECKLENBURG COUNTY HEALTH DEPARTMENT, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws and Rules For Sewage, Treatment and Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

- No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and/or Repair Approval is granted by this Department.
- This Improvement permit is transferable.

Thilo A-Walker 11/30/95
DEHNR Authorized Agent Date

[signature] 11/30/95
Owner/Agent Signature Date

MECKLENBURG COUNTY
HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
c/o HAL MARSHALL CTR.
SUITE 211
700 N. TRYON ST.
CHARLOTTE, N.C. 28202.
(704) 336-5102

NORTH CAROLINA DEPARTMENT OF
ENVIRONMENTAL, HEALTH,
AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

41 4WW

3731B

INDIVIDUAL WATER AND WASTEWATER SYSTEMS PROGRAM
APPLICATION FOR SERVICES

#150.00 9/14/95
CR#7708 (1) CRT

Mecklenburg County Health Dept.
Environmental Health Division
c/o Hal Marshall Ctr., Suite 211
700 N. Tryon St.
Charlotte, NC 28202

(704)336-5102

Date: 9/14/95

PERSON FILING APPLICATION:
NAME: JOHN McNANIE (last) (first) (mi)
ADDRESS: 1221 IVERLEIGH PHONE: 704, 846-6706
CITY: Charlotte STATE: NC ZIPCODE: 28270

PROPERTY INFORMATION (FROM ENGINEERING FORM):
TAX/PARCEL NUMBER: 139-041-04
STREET ADDRESS: 7916 WHITE CLIFFS DRIVE
ZONING:

PROPERTY OWNER:
NAME: DUBLIN HOMES (last) (first) (mi)
ADDRESS: 1221 IVERLEIGH PHONE: 704, 846 6706
CITY: Charlotte STATE: NC ZIPCODE: 28270

SUBDIVISION OR MOBILE HOME PARK NAME: MORGAN GLEN

Township (check one):
[X] 0 Mecklenburg County [] 2 Davidson [] 4 Pineville [] 6 Huntersville
[] 1 Charlotte [] 3 Cornelius [] 5 Matthews [] 7 Mint Hill

LOT NUMBER: 41 LOT SIZE (in acres): 3/4

TYPE APPLICATION (check one):

[] SOIL TEST - INDIVIDUAL LOT (D)
[X] NEW CONSTRUCTION ON VACANT LOT - 4 BEDROOMS OR LESS (N)
[] EXCHANGE MOBILE HOME - SAME # BEDROOMS (Y)
[] ADDITION - INCREASE ROOMS/OCCUPANCY/MOBILE HOME SIZE (A or M)
[] COMMERCIAL OR INDUSTRIAL (N)
[] SOIL TEST DEVELOPMENT (P)
[] ADDITION - GARAGE OR RENOVATION/NO MAJOR CHANGES (X)
[] MODIFIED /ALTERNATIVE/ OR RESIDENCE > 4 BEDROOMS (Z)
[] REPAIR TO SYSTEM (R)

RESIDENTIAL PROPERTY (Type Building, check one):
[] SINGLE MOBILE HOME (S) [X] HOUSE (H) [] MULTIPLE FAMILY (U)
[] DOUBLE WIDE (D) [] MODULAR HOME (M) [] OTHER ____ (O)

NUMBER BEDROOMS: 4 NUMBER OCCUPANTS: 4
SYSTEM CLASSIFICATION:

COMMERCIAL/INDUSTRIAL PROPERTY:
Type Business _____ # Employees ___ Per Shift __ __ __
Industrial Wastes (Y/N) ___
Underground Storage Tanks On Property (Y/N) ___ Type _____

WATER SUPPLY (check one):
[] Community (C) [] Shared Well (S)
[] Municipal (M) [] Other 'spring' (O)
[X] Private Well (P)

FUTURE ADDITIONS - ALL PLANNED ADDITIONS MUST BE ENTERED (check all that apply):
[] Swimming Pool [] Jacuzzi [] Stable/Barn [] Workshop [X] None
[] Garage [] Storage Building [] Deck/Patio [] Bedrooms [] Other

The undersigned, owner, or legal agent for the owner, of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: John C McNanie Date: 9-14-95

NOTICE:

The undersigned, an authorized agent of the MECKLENBURG COUNTY HEALTH DEPARTMENT, certifies that the Department has approved the the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

...No work shall be conducted on the septic tank system until an installation, Construction, Alteration and/or Repair approval is granted by this Department.

...This permit is not transferable.

... IWWS 93-2-R1

[X] IMPROVEMENT PERMIT - VALID 60 MONTHS FROM ISSUANCE
[] MOBILE HOME EXCHANGE APPROVAL - VALID 6 MONTHS FROM ISSUANCE
[] ADDITION/RENOVATION APPROVAL - VALID 1 YEAR FROM ISSUANCE

Philo A Walker R.S. 11/30/95
Environmentalist Date

Director or Authorized Section Head Date

WWATER : 122791

ck#7570 Pd Dinsmore G.O. 160.00

FEE: 150.00 **AUTHORIZATION FOR WASTEWATER SYSTEM CONSTRUCTION**
DATE: 2-20-96 **VOID SIXTY (60) MONTHS FROM DATE OF ISSUANCE**

DATE: 11/30/95 **PERMIT NO:** 3731B
PARCEL NO: 139 041 04

JOB LOCATION ADDRESS: 7916 White Cliffs Dr
PROPERTY OWNER: Dublin Homes
BUILDING CONTRACTOR: John McNanie
SUBDIVISION NAME: Morgan Glen
AUTHORIZATION ISSUED BY: Philo T. Walker **DATE:** 11/30/95
DEHNR AUTHORIZED AGENT

AUTHORIZATION CONDITIONS

1. WASTEWATER SYSTEM CONSTRUCTION AND INSTALLATION MUST MEET ALL CONDITIONS AND SPECIFICATIONS AS SET FORTH IN IMPROVEMENT PERMIT NO. 3731B, AND THE ATTACHED SITE PLAN WITH SYSTEM DETAILS. CONSTRUCTION AND INSTALLATION MUST ALSO MEET ALL REQUIREMENTS SET FORTH IN THE RULES GOVERNING SANITARY SEWAGE COLLECTION, TREATMENT, AND DISPOSAL AND ANY OTHER APPLICABLE RULES AND LAWS.

2. AN INSTALLATION, CONSTRUCTION, ALTERATION AND/OR REPAIR APPROVAL MUST BE SECURED **PRIOR** TO INSTALLATION OF THE SEPTIC TANK SYSTEM. THE INSTALLER OF THE SYSTEM SHALL BE A REGISTERED SEPTIC TANK CONTRACTOR WITH MECKLENBURG COUNTY HEALTH DEPARTMENT.

3. ANY ALTERATION IN SITE OR SOIL CONDITIONS (INCLUDING LOCATION OF STRUCTURES AND APPURTENANCES) OR MODIFICATION IN USE, DESIGN WASTEWATER FLOW, OR WASTEWATER CHARACTERISTICS AS SPECIFIED IN THE ASSOCIATED IMPROVEMENT PERMIT AND APPLICATION, MAY SUBJECT THIS AUTHORIZATION AND ASSOCIATED PERMIT(S) TO REVOCATION.

4. OTHER CONDITIONS: IWWS 93-2-R1 septic system
Copy of wastewater Treatment and Disposal System Design Agreement form and Replacement system agreement form in file.

OWNER CERTIFICATION

I CERTIFY THAT THERE HAVE BEEN NO ALTERATIONS IN SITE OR SOIL CONDITIONS OR MODIFICATIONS TO FACILITY, WASTEWATER FLOW, OR WASTEWATER CHARACTERISTICS FROM THOSE SPECIFIED IN THE ORIGINAL APPLICATION OR ASSOCIATED IMPROVEMENT PERMIT UNLESS AUTHORIZED IN WRITING BY THE MECKLENBURG COUNTY HEALTH DEPARTMENT. I ALSO UNDERSTAND THAT ANY SUCH ALTERATIONS, MODIFICATIONS, OR FALSE INFORMATION ARE GROUNDS FOR REVOCATION OF PERMITS AND AUTHORIZATION TO CONSTRUCT.

John M McNanie 11/30/95
SIGNATURE OF OWNER/OWNER'S REPRESENTATIVE DATE

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

OWNER'S ACKNOWLEDGMENT OF MODIFIED/ALTERNATIVE REPLACEMENT SYSTEM REQUIREMENT

Site Address: 7916 White Cliff Drive.

File Number: 7731B

Parcel Number: 139 04104

Owner/Agent Name: SUSAN McNANIE
(Please print)

Date: 11/30/95 Number of Bedrooms: 4

Receipt of the plan and specifications for a conventional system of sewage disposal for the above property is hereby acknowledged. Upon receipt of the information, a review was made of the material on file and a site evaluation was conducted. The plan was then reviewed in conjunction with provisions of 15A NCAC 18A .1900 - "Sewage Treatment and Disposal Systems." The plan as submitted is disapproved because there is not sufficient available space for a repair area for a conventional replacement system.

This site may be developed if the repair area is found to be acceptable for either a modified system (Rule .1956) or an alternative system (Rule .1957) for the replacement system as allowed by the following Rule 15A NCAC 18A .1945(b).

(b) Sites shall have sufficient available space for a repair area separate from the area determined in Paragraph (a) of this Rule. The repair area shall be based upon the area of the nitrification field required to accommodate the installation of a replacement system as specified in Rule .1955, .1956, or .1957 of this Section. Prior to issuance of the initial Improvement Permit for a site, the local health department shall designate on the permit the original system layout, the repair area, and the type of replacement system.

Please be advised that you have the right of an informal review by this Department and the right of appeal under G.S. 130A-335(g) and 130A-24, which appeal can be held in Mecklenburg County.

By signing this form, and signing and recording in the Mecklenburg County Register of Deeds Office the attached reclassification form entitled, **WASTEWATER TREATMENT AND DISPOSAL SYSTEM DESIGN AGREEMENT: 15A NCAC 18A .1948 AND ANY OF THE FOLLOWING RULES: .1956; .1957(a); .1957(b); or .1957(c), or .1969,** you the property owner, understand and acknowledge your option to develop this site initially with a

conventional sewage system and when needed, subsequently to repair or replace said system with a modified or alternative system as described in Rules .1956 "Modification to Septic Tank Systems," or .1957(a), (b), or (c) "Design Criteria for Design of Alternative Sewage Systems." The completed reclassification form must be approved by this office before it can be recorded.

In addition, you the property owner, also understand that the following conditions will apply:

- Any changes on the property may make the Improvement Permit null and void and may make the Improvement Permit subject to revocation.

- Do not grade, cut, fill, pave, construct a building or deck, dig a well, install a swimming pool or otherwise cover or disturb the soil (except for planting and maintaining grass or other ground covers) in a manner which will adversely affect the repair area or area where the septic tank system is located.

- When a private certified operator is required, no improvement permit for the designated repair shall be issued unless there is a private certified operator to carry out this management program in the service area where the proposed system is to be located. (Refer to Rule .1961, "Maintenance of Sewage Systems," for further information.)

- Additional fees will be required according to the Mecklenburg County user fee schedule applicable at the time for the issuance of a repair permit for any subsequent repairs to the sewage treatment and disposal system or for installation of a replacement system.

- At the time repairs to the sewage treatment and disposal system are to be made or a replacement system installed, the regulations in effect at that time will govern the repairs or installation of a replacement system.

Philo A. Walker — 11/30/95


Environmental Health Specialist — Date

I have reviewed this document and understand its provisions and implications concerning the issuance of the Improvement Permit for the above-referenced site.

Property Owner Signature — 11/30/95

Date

700 North Tryon Street, Suite 211, Charlotte, North Carolina 28202,
(704) 336-5102


Surveyed By: Ben M. Flowe & Son,
11316 Brief Road
Charlotte, N.C.
28227
(704) 545-3060
Lot 40
Lot 41
Lot 43
3731-B
N 33°09'18" E
223.06'
233.06'
S 62°15'51" W
193.00'
N 22°05'49" W
67.10'
20' Public Drainage Easement
30' Setback Line
R=50.00'
L=113.25'
N 58°15'36" E
90.55'
10.00
S 67°54'11" W
184.37'
N 67°54'11" E
71.58'
S 22°05'49" E
214.47'
204.47'
10.00'
50.0'
30.25'
N 30°38'16" E
R = 25.00'
L = 32.52'
Plat North
M.B. 26 / 897
White Cliffs L
45' R/W
Wetland
Joe Dennis
5228 / 278
Lot 1
Lot 2
Lot 3
Lot 4
Lot 5
Lot 6
Lot 7
Lot 8
Lot 9
Lot 10
Lot 11
Lot 12
Lot 13
Lot 14
Lot 15
Lot 16
Lot 17
Lot 18
Lot 19
Lot 20
Lot 21
Lot 22
Lot 23
Lot 24
Lot 25
Lot 26
Lot 27
Lot 28
Lot 29
Lot 30
Lot 31
Lot 32
Lot 33
Lot 34
Lot 35
Lot 36
Lot 37
Lot 38
Lot 39
Lot 42
Lot 44
Lot 45
Lot 46
Lot 47
Lot 48
Lot 49
Lot 50
Lot 51
Lot 52
Lot 53
Lot 54
Lot 55
Lot 56
Lot 57
Lot 58
Lot 59
Lot 60
Lot 61
Lot 62
Lot 63
Lot 64
Lot 65
Lot 66
Lot 67
Lot 68
Lot 69
Lot 70
Lot 71
Lot 72
Lot 73
Lot 74
Lot 75
Lot 76
Lot 77
Lot 78
Lot 79
Lot 80
Lot 81
Lot 82
Lot 83
Lot 84
Lot 85
Lot 86
Lot 87
Lot 88
Lot 89
Lot 90
Lot 91
Lot 92
Lot 93
Lot 94
Lot 95
Lot 96
Lot 97
Lot 98
Lot 99
Lot 100
Lot 101
Lot 102
Lot 103
Lot 104
Lot 105
Lot 106
Lot 107
Lot 108
Lot 109
Lot 110
Lot 111
Lot 112
Lot 113
Lot 114
Lot 115
Lot 116
Lot 117
Lot 118
Lot 119
Lot 120
Lot 121
Lot 122
Lot 123
Lot 124
Lot 125
Lot 126
Lot 127
Lot 128
Lot 129
Lot 130
Lot 131
Lot 132
Lot 133
Lot 134
Lot 135
Lot 136
Lot 137
Lot 138
Lot 139
Lot 140
Lot 141
Lot 142
Lot 143
Lot 144
Lot 145
Lot 146
Lot 147
Lot 148
Lot 149
Lot 150
Lot 151
Lot 152
Lot 153
Lot 154
Lot 155
Lot 156
Lot 157
Lot 158
Lot 159
Lot 160
Lot 161
Lot 162
Lot 163
Lot 164
Lot 165
Lot 166
Lot 167
Lot 168
Lot 169
Lot 170
Lot 171
Lot 172
Lot 173
Lot 174
Lot 175
Lot 176
Lot 177
Lot 178
Lot 179
Lot 180
Lot 181
Lot 182
Lot 183
Lot 184
Lot 185
Lot 186
Lot 187
Lot 188
Lot 189
Lot 190
Lot 191
Lot 192
Lot 193
Lot 194
Lot 195
Lot 196
Lot 197
Lot 198
Lot 199
Lot 200
Lot 201
Lot 202
Lot 203
Lot 204
Lot 205
Lot 206
Lot 207
Lot 208
Lot 209
Lot 210
Lot 211
Lot 212
Lot 213
Lot 214
Lot 215
Lot 216
Lot 217
Lot 218
Lot 219
Lot 220
Lot 221
Lot 222
Lot 223
Lot 224
Lot 225
Lot 226
Lot 227
Lot 228
Lot 229
Lot 230
Lot 231
Lot 232
Lot 233
Lot 234
Lot 235
Lot 236
Lot 237
Lot 238
Lot 239
Lot 240
Lot 241
Lot 242
Lot 243
Lot 244
Lot 245
Lot 246
Lot 247
Lot 248
Lot 249
Lot 250
Lot 251
Lot 252
Lot 253
Lot 254
Lot 255
Lot 256
Lot 257
Lot 258
Lot 259
Lot 260
Lot 261
Lot 262
Lot 263
Lot 264
Lot 265
Lot 266
Lot 267
Lot 268
Lot 269
Lot 270
Lot 271
Lot 272
Lot 273
Lot 274
Lot 275
Lot 276
Lot 277
Lot 278
Lot 279
Lot 280
Lot 281
Lot 282
Lot 283
Lot 284
Lot 285
Lot 286
Lot 287
Lot 288
Lot 289
Lot 290
Lot 291
Lot 292
Lot 293
Lot 294
Lot 295
Lot 296
Lot 297
Lot 298
Lot 299
Lot 300
Lot 301
Lot 302
Lot 303
Lot 304
Lot 305
Lot 306
Lot 307
Lot 308
Lot 309
Lot 310
Lot 311
Lot 312
Lot 313
Lot 314
Lot 315
Lot 316
Lot 317
Lot 318
Lot 319
Lot 320
Lot 321
Lot 322
Lot 323
Lot 324
Lot 325
Lot 326
Lot 327
Lot 328
Lot 329
Lot 330
Lot 331
Lot 332
Lot 333
Lot 334
Lot 335
Lot 336
Lot 337
Lot 338
Lot 339
Lot 340
Lot 341
Lot 342
Lot 343
Lot 344
Lot 345
Lot 346
Lot 347
Lot 348
Lot 349
Lot 350
Lot 351
Lot 352
Lot 353
Lot 354
Lot 355
Lot 356
Lot 357
Lot 358
Lot 359
Lot 360
Lot 361
Lot 362
Lot 363
Lot 364
Lot 365
Lot 366
Lot 367
Lot 368
Lot 369
Lot 370
Lot 371
Lot 372
Lot 373
Lot 374
Lot 375
Lot 376
Lot 377
Lot 378
Lot 379
Lot 380
Lot 381
Lot 382
Lot 383
Lot 384
Lot 385
Lot 386
Lot 387
Lot 388
Lot 389
Lot 390
Lot 391
Lot 392
Lot 393
Lot 394
Lot 395
Lot 396
Lot 397
Lot 398
Lot 399
Lot 400
Lot 401
Lot 402
Lot 403
Lot 404
Lot 405
Lot 406
Lot 407
Lot 408
Lot 409
Lot 410
Lot 411
Lot 412
Lot 413
Lot 414
Lot 415
Lot 416
Lot 417
Lot 418
Lot 419
Lot 420
Lot 421
Lot 422
Lot 423
Lot 424
Lot 425
Lot 426
Lot 427
Lot 428
Lot 429
Lot 430
Lot 431
Lot 432
Lot 433
Lot 434
Lot 435
Lot 436
Lot 437
Lot 438
Lot 439
Lot 440
Lot 441
Lot 442
Lot 443
Lot 444
Lot 445
Lot 446
Lot 447
Lot 448
Lot 449
Lot 450
Lot 451
Lot 452
Lot 453
Lot 454
Lot 455
Lot 456
Lot 457
Lot 458
Lot 459
Lot 460
Lot 461
Lot 462
Lot 463
Lot 464
Lot 465
Lot 466
Lot 467
Lot 468
Lot 469
Lot 470
Lot 471
Lot 472
Lot 473
Lot 474
Lot 475
Lot 476
Lot 477
Lot 478
Lot 479
Lot 480
Lot 481
Lot 482
Lot 483
Lot 484
Lot 485
Lot 486
Lot 487
Lot 488
Lot 489
Lot 490
Lot 491
Lot 492
Lot 493
Lot 494
Lot 495
Lot 496
Lot 497
Lot 498
Lot 499
Lot 500
Lot 501
Lot 502
Lot 503
Lot 504
Lot 505
Lot 506
Lot 507
Lot 508
Lot 509
Lot 510
Lot 511
Lot 512
Lot 513
Lot 514
Lot 515
Lot 516
Lot 517
Lot 518
Lot 519
Lot 520
Lot 521
Lot 522
Lot 523
Lot 524
Lot 525
Lot 526
Lot 527
Lot 528
Lot 529
Lot 530
Lot 531
Lot 532
Lot 533
Lot 534
Lot 535
Lot 536
Lot 537
Lot 538
Lot 539
Lot 540
Lot 541
Lot 542
Lot 543
Lot 544
Lot 545
Lot 546
Lot 547
Lot 548
Lot 549
Lot 550
Lot 551
Lot 552
Lot 553
Lot 554
Lot 555
Lot 556
Lot 557
Lot 558
Lot 559
Lot 560
Lot 561
Lot 562
Lot 563
Lot 564
Lot 565
Lot 566
Lot 567
Lot 568
Lot 569
Lot 570
Lot 571
Lot 572
Lot 573
Lot 574
Lot 575
Lot 576
Lot 577
Lot 578
Lot 579
Lot 580
Lot 581
Lot 582
Lot 583
Lot 584
Lot 585
Lot 586
Lot 587
Lot 588
Lot 589
Lot 590
Lot 591
Lot 592
Lot 593
Lot 594
Lot 595
Lot 596
Lot 597
Lot 598
Lot 599
Lot 600
Lot 601
Lot 602
Lot 603
Lot 604
Lot 605
Lot 606
Lot 607
Lot 608
Lot 609
Lot 610
Lot 611
Lot 612
Lot 613
Lot 614
Lot 615
Lot 616
Lot 617
Lot 618
Lot 619
Lot 620
Lot 621
Lot 622
Lot 623
Lot 624
Lot 625
Lot 626
Lot 627
Lot 628
Lot 629
Lot 630
Lot 631
Lot 632
Lot 633
Lot 634
Lot 635
Lot 636
Lot 637
Lot 638
Lot 639
Lot 640
Lot 641
Lot 642
Lot 643
Lot 644
Lot 645
Lot 646
Lot 647
Lot 648
Lot 649
Lot 650
Lot 651
Lot 652
Lot 653
Lot 654
Lot 655
Lot 656
Lot 657
Lot 658
Lot 659
Lot 660
Lot 661
Lot 662
Lot 663
Lot 664
Lot 665
Lot 666
Lot 667
Lot 668
Lot 669
Lot 670
Lot 671
Lot 672
Lot 673
Lot 674
Lot 675
Lot 676
Lot 677
Lot 678
Lot 679
Lot 680
Lot 681
Lot 682
Lot 683
Lot 684
Lot 685
Lot 686
Lot 687
Lot 688
Lot 689
Lot 690
Lot 691
Lot 692
Lot 693
Lot 694
Lot 695
Lot 696
Lot 697
Lot 698
Lot 699
Lot 700
Lot 701
Lot 702
Lot 703
Lot 704
Lot 705
Lot 706
Lot 707
Lot 708
Lot 709
Lot 710
Lot 711
Lot 712
Lot 713
Lot 714
Lot 715
Lot 716
Lot 717
Lot 718
Lot 719
Lot 720
Lot 721
Lot 722
Lot 723
Lot 724
Lot 725
Lot 726
Lot 727
Lot 728
Lot 729
Lot 730
Lot 731
Lot 732
Lot 733
Lot 734
Lot 735
Lot 736
Lot 737
Lot 738
Lot 739
Lot 740
Lot 741
Lot 742
Lot 743
Lot 744
Lot 745
Lot 746
Lot 747
Lot 748
Lot 749
Lot 750
Lot 751
Lot 752
Lot 753
Lot 754
Lot 755
Lot 756
Lot 757
Lot 758
Lot 759
Lot 760
Lot 761
Lot 762
Lot 763
Lot 764
Lot 765
Lot 766
Lot 767
Lot 768
Lot 769
Lot 770
Lot 771
Lot 772
Lot 773
Lot 774
Lot 775
Lot 776
Lot 777
Lot 778
Lot 779
Lot 780
Lot 781
Lot 782
Lot 783
Lot 784
Lot 785
Lot 786
Lot 787
Lot 788
Lot 789
Lot 790
Lot 791
Lot 792
Lot 793
Lot 794
Lot 795
Lot 796
Lot 797
Lot 798
Lot 799
Lot 800
Lot 801
Lot 802
Lot 803
Lot 804
Lot 805
Lot 806
Lot 807
Lot 808
Lot 809
Lot 810
Lot 811
Lot 812
Lot 813
Lot 814
Lot 815
Lot 816
Lot 817
Lot 818
Lot 819
Lot 820
Lot 821
Lot 822
Lot 823
Lot 824
Lot 825
Lot 826
Lot 827
Lot 828
Lot 829
Lot 830
Lot 831
Lot 832
Lot 833
Lot 834
Lot 835
Lot 836
Lot 837
Lot 838
Lot 839
Lot 840
Lot 841
Lot 842
Lot 843
Lot 844
Lot 845
Lot 846
Lot 847
Lot 848
Lot 849
Lot 850
Lot 851
Lot 852
Lot 853
Lot 854
Lot 855
Lot 856
Lot 857
Lot 858
Lot 859
Lot 860
Lot 861
Lot 862
Lot 863
Lot 864
Lot 865
Lot 866
Lot 867
Lot 868
Lot 869
Lot 870
Lot 871
Lot 872
Lot 873
Lot 874
Lot 875
Lot 876
Lot 877
Lot 878
Lot 879
Lot 880
Lot 881
Lot 882
Lot 883
Lot 884
Lot 885
Lot 886
Lot 887
Lot 888
Lot 889
Lot 890
Lot 891
Lot 892
Lot 893
Lot 894
Lot 895
Lot 896
Lot 897
Lot 898
Lot 899
Lot 900
Lot 901
Lot 902
Lot 903
Lot 904
Lot 905
Lot 906
Lot 907
Lot 908
Lot 909
Lot 910
Lot 911
Lot 912
Lot 913
Lot 914
Lot 915
Lot 916
Lot 917
Lot 918
Lot 919
Lot 920
Lot 921
Lot 922
Lot 923
Lot 924
Lot 925
Lot 926
Lot 927
Lot 928
Lot 929
Lot 930
Lot 931
Lot 932
Lot 933
Lot 934
Lot 935
Lot 936
Lot 937
Lot 938
Lot 939
Lot 940
Lot 941
Lot 942
Lot 943
Lot 944
Lot 945
Lot 946
Lot 947
Lot 948
Lot 949
Lot 950
Lot 951
Lot 952
Lot 953
Lot 954
Lot 955
Lot 956
Lot 957
Lot 958
Lot 959
Lot 960
Lot 961
Lot 962
Lot 963
Lot 964
Lot 965
Lot 966
Lot 967
Lot 968
Lot 969
Lot 970
Lot 971
Lot 972
Lot 973
Lot 974
Lot 975
Lot 976
Lot 977
Lot 978
Lot 979
Lot 980
Lot 981
Lot 982
Lot 983
Lot 984
Lot 985
Lot 986
Lot 987
Lot 988
Lot 989
Lot 990
Lot 991
Lot 992
Lot 993
Lot 994
Lot 995
Lot 996
Lot 997
Lot 998
Lot 999
Lot 1000

MECKLENBURG COUNTY HEALTH DEPARTMENT
SITE EVALUATION REPORT
SERIAL NUMBER 028750

File: 37318 of 00 Action 2


Parcel: 00 139-041-04 ☐ PC

Location: 7916 White Cliffs Dr.
Subdivision: Morgan Glenn
Lot: 41 Block: Acres: .75

Owner: Dublin Homes
Address: 1221 Overleigh Tr.
Charlotte, N.C. 28270 ✓

Comments: 100% Repair, .3 gal/ft/day by LTAR

Described by: William R. Medlin
Date: 10-2-95



***** EVALUATION KEY *****
S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	(S) PS U 2-8%	(S) PS U 2-8%	S PS (U) Depression	S PS U	S PS U	S PS U
Texture	S (PS) U Slightly Exp. clay	S (PS) U Slightly Exp Clay	S PS U —	S PS U	S PS U	S PS U
Structure	S (PS) U Blocky	S (PS) U Blocky	S PS U —	S PS U	S PS U	S PS U
Drainage	S (PS) U >43" To soil wetness	S (PS) U 36" To soil wetness	S PS U	S PS U	S PS U	S PS U
Depth	S (PS) U 36-43"	S PS (U) 28-31"	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U >43"	S (PS) U >36"	S PS U	S PS U	S PS U	S PS U
Available Space	S PS (U) Restricted	S PS (U) Restricted	S PS U —	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IV Cecil/Vance	IV Pacolet-Lilly	Depression			
Area Classification	S PS (U)	S PS (U)	S PS (U)	S PS U	S PS U	S PS U

MECKLENBURG COUNTY HEALTH DEPARTMENT
SITE EVALUATION REPORT
SERIAL NUMBER 028750

File: 37318 Action 2


Parcel: 00 139-041-04 ☐ PC

Location: 7916 White Cliffs Dr.
Subdivision: Morgan - Glenn
Lot: 41 Block: Acres: .75

Owner: Dublin Homes
Address: 1221 Overleigh Tr.
Charlotte, N.C. 28216

Comments: 100% Repair, .3 gal/ft/day LTAR


Described by: William A. Marlin
Date: 10-2-95



*** EVALUATION KEY ***
S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	(S) PS U 2-8%	(S) PS U 2-8%	S PS (U) Depression	S PS U	S PS U	S PS U
Texture	S (PS) U Slightly Exp. Clay	S (PS) U Slightly Exp clay	S PS U —	S PS U	S PS U	S PS U
Structure	S (PS) U Blocky	S (PS) U Blocky	S PS U —	S PS U	S PS U	S PS U
Drainage	S (PS) U >43" To Soil Wetness	S (PS) U >36" To Soil Wetness	S PS U	S PS U	S PS U	S PS U
Depth	S (PS) U 36-43"	S PS (U) 28-31"	S PS U —	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U >43"	S (PS) U >36"	S PS U —	S PS U	S PS U	S PS U
Available Space	S PS (U) Restricted	S PS (U) Restricted	S PS U —	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IV Cecil-Lilo	IV Pacolet-Lilo	Depression			
Area Classification	S PS (U)	S PS (U)	S PS (U)	S PS U	S PS U	S PS U

Surveyed By: Ben M. Flowe & Son,
11316 Brief Road
Charlotte, N.C.
28227
(704) 545-3060



STATE OF NORTH CAROLINA

COUNTY OF MECKLENBURG

WASTEWATER TREATMENT AND DISPOSAL SYSTEM DESIGN AGREEMENT: 15A NCAC 18A .1948 AND ANY OF THE FOLLOWING RULES: .1956; .1957(a); .1957(b); or .1957(c); OR .196

FILE COPY

FILE # 41-3731-13
PARCEL # OUT OF 139-041-04

The undersigned, THE DUBLIN BUILDING GROUP, LTD., owner of property located at 7916 White Cliffs Drive, Charlotte, NC 28227; (the "site") and described in an instrument recorded in Book 5228 at Page 280, Mecklenburg Public Registry, hereby acknowledges that the undersigned applied to the Mecklenburg County Health Department (the "Department") for a permit to install a septic tank sewage disposal system on the site; that the Department evaluated the site for suitability for such a system in accordance with the regulations promulgated by the North Carolina Commission for Health Services as 15A NCAC 18A .1900 et seq.; that the Department originally classified the site as "unsuitable" pursuant to the standards set forth in the regulations; that the undersigned requested that the Department reclassify the site as "provisionally suitable" in light of the particular septic tank system proposed by the undersigned; that the Department considered various studies, data, and other information which indicate to the Department that the septic tank system proposed by the undersigned is allowed by the rules; and that the Department therefore reclassified the site as "provisionally suitable" and issued an appropriate permit for such proposed septic tank system.

The undersigned further acknowledges that the proper design, construction, operation and maintenance of such septic tank system is the responsibility of the designer, owner, developer, installer, or user of the system, as applicable, and that neither the Department nor its officials, employees, or agents warrant or guarantee that the said system installed pursuant to the permit issued by the Department will function in a satisfactory manner for any given period of time or that the Department, its officials, employees or agents assume any liability for any damages of any kind which are caused, or which may be caused, by a malfunction of such system.

The undersigned further acknowledges that the following conditions will apply to the site:

- Any changes on the property may make the Improvement Permit Null and void and may make the Improvement Permit subject to revocation.

This instrument was prepared by: THE DUBLIN BUILDING GROUP, LTD.
Mail after recording to: THE DUBLIN BUILDING GROUP, LTD.
1221 Iverleigh Trail, Charlotte, NC 28270

BK: 08379 PG: 0523/0526 #:0180 15.05
JUDITH A GIBSON REG OF DEEDS MECK NC
FILED FOR REGISTRATION 11/30/95 12:25

- Do not grade, cut, fill, pave, construct a building or deck, dig a well, install a swimming pool or otherwise cover or disturb the soil (except for planting and maintaining grass or other ground covers) in a manner which will adversely affect the repair area or area where the septic tank system is located.

- When a private certified operator is required, no improvement permit for the designated repair shall be issued unless there is a private certified operator to carry out this management program in the service area where the proposed system is to be located. (Refer to Rule .1961, "Maintenance of Sewage Systems," for further information.)

- Additional fees will be required according to the Mecklenburg County user fee schedule applicable at the time for the issuance of a repair permit for any subsequent repairs to the sewage treatment and disposal system or for installation of a replacement system.

- At the time repairs to the sewage treatment and disposal system are to be made or a replacement system installed, the regulations in effect at that time will govern the repairs or installation of a replacement system.

The undersigned further agrees for himself, his heirs and assigns that he shall indemnify and hold harmless the Department, its employees, and officials, as well as Mecklenburg County and its employees and officials, for any damages or other claims of any person or persons whatsoever arising out of the installation, operation, or failure of said septic tank system.

Use of the singular masculine pronoun forms herein shall be deemed to also include the plural and feminine forms as the context may require.

This document shall be placed on the public records of the Register of Deeds of Mecklenburg County and indexed therein under the Grantor Index in the name or names of the undersigned, and the foregoing acknowledgements shall henceforth be binding on all persons claiming any right, title, or interest in the site.

IN WITNESS WHEREOF, the undersigned has hereunto set his hand and seal, or if corporate, has caused this instrument to be signed in its corporate name by its duly authorized officers and its seal to be hereunto affixed by authority of its Board of Directors, this 30th day of November, 1995.

THE DUBLIN BUILDING GROUP, LTD.
(Corporate Name)

By: _____

John C. McNanie, President

ATTEST:

_____

Susan McNanie, Secretary

(Corporate Seal)

_____ (SEAL)

_____ (SEAL)

_____ (SEAL)

_____ (SEAL)

STATE OF NORTH CAROLINA
COUNTY OF _____

I, _____, a Notary Public for said County and State, do hereby certify that _____ personally appeared before me this date and acknowledged the due execution of the foregoing instrument.

WITNESS my hand and notarial seal, this _____ day of _____, 199__.

_____
Notary Public

My Commission Expires:

_____

STATE OF NORTH CAROLINA
COUNTY OF MECKLENBURG

I, AMY D. FARRAR, a Notary Public for said County and State, do hereby certify that Susan McNanie personally came before me this day and acknowledged that s/he is _____ Secretary of THE DUBLIN BUILDING GROUP, LTD., a North Carolina corporation, and that by authority duly given and as the act and deed of said corporation, the foregoing instrument was signed in its name by its _____ President, sealed with its corporate seal and attested by her as its Assistant Secretary.

WITNESS my hand and notarial seal, this 30th day of November, 1995.

★ NOTARY PUBLIC ★
AMY D. FARRAR
GASTON COUNTY, N. C.
My Commission Expires March 24, 1996

Amy D. Farrar
Notary Public

My Commission Expires:

_____

TO: ENVIRONMENTAL HEALTH DEPT.
BUILDING STANDARDS DEPT.
DEPT. OF ENVIRONMENTAL PROTECTION/
SOLID AND HAZARDOUS WASTE

DATE: 9/14/95

FROM: COUNTY ENGINEERING DEPARTMENT

EHD FILE _____ JURISDICTION CODE Meck

PARCEL NUMBER 139-041-04

ASSIGNED ADDRESS 7916 White Cliffs Dr

EXISTING ADDRESS Lot 41

PROJECT NAME Morgan Glenn

THE ABOVE DESCRIBED LOCATION HAS BEEN CHECKED CONCERNING:

		APPROVED	DISAPPROVED
1.	SUBDIVISION REGULATIONS	_____	_____*
2.	FLOODWAY REGULATIONS	_____	_____*
3.	EROSION CONTROL REGULATIONS	_____	_____*
4.	PUBLIC UTILITY EASEMENT	_____	_____*

		PRESENT	NOT PRESENT
5.	PUBLIC UTILITY EASEMENT	_____*	_____
6.	PROPERTY FRONTS ON THOROUGHFARE	_____*	_____
7.	DRIVEWAY PERMIT REQUIRED	_____*	_____

*If checked, further investigation will be required to determine whether a building permit can be issued by Building Standards for the site.

REMARKS: Septic tank

NOTE: THIS FORM MUST BE TURNED IN AT THE CASHIER'S OFFICE AT BUILDING STANDARDS WHEN PAYING PERMIT FEES.

A CERTIFICATE OF OCCUPANCY WILL NOT BE GRANTED UNTIL THE TRANSPORTATION DIVISION GRANTS FINAL APPROVAL ON DRIVEWAYS.

SIGNED: Rob

OPWEAR 06-88

NEW ADDRESS _____*

FORM 100

Mecklenburg County
Health Department

October 25, 1995

Dublin Homes
1221 Iverleigh Trail
Charlotte, NC 28215

Re: 7916 White Cliffs Drive
File: 3731B
Parcel: 139-041-04

Dear Mr. McNanie:

Receipt of the plans and specifications for a conventional system of sewage disposal for the above property is hereby acknowledged. Upon receipt of the information, a review was made of the material on file and a site evaluation was conducted. The plan was then reviewed in conjunction with provisions of 15 NCAC 18A, .2900, "Laws and Rules for Sanitary Sewage Collection, Treatment and Disposal". Our comments are listed below:

.1945 AVAILABLE SPACE
(a) Sites shall have sufficient available space to permit the installation and proper functioning of ground absorption sewage treatment and disposal systems, based upon the square footage of nitrification field required for the application rate determined in accordance with these Rules.
(b) Sites shall have sufficient available space for a repair area equal to the area determined in Rule .1945 (a) of this Section.

For these reasons, the plans as submitted are disapproved: However, state regulations provide that sites originally classified unsuitable may be utilized for the installation of alternate or modified sewage disposal systems provided the requirements of 15 NCAC 18A .1948 (c) are met.

Should you desire to file for permission to install an alternate or modified sewage treatment system on the property, please submit an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems to this office. They will be reviewed, and if it is determined that the proposed system may reasonably be expected to function satisfactorily, an Improvement Permit will be issued by the Department upon completion by you, of a formal request for lot reclassification.

If I may be of any assistance, please feel free to contact me at 336-5570.

Sincerely,

Philo S. Walker R.S.


Philo S. Walker, R.S.
Individual Water and Wastewater Systems

PW:gf

* (4) Bedrm. Gravity Infiltrator/split
Washer Line Plan.

MCHD
File: 3731-B
Morgan Glen, Lot 41

* Primary Plan
1,500 gal. Septic Tank
(5) 56' lines off Tank
(3) 50' Washer Lines




T. Whittaker
866-9540
Scale 40

MCHD

File: 3731-B


Lot 41

(4) Bedrm. Infiltrator Plan / Gravity / Split Washer Line. (69 units for ENTIRE SEPTIC PLAN)




* Primary Sys.
1,500 gal. Tank
(5) 56' LINES
(9) UNITS PER LINE
(45) UNITS Total

* Trench Profile if Shallow Placement Required



16" Trench Depth
12" Total Cover Approved
by M.C.H.D.

* Washer Lines *



(3) 50' LINES
(8) UNITS PER LINE
(24) UNITS Total

NO SCALE

THE INFILTRATOR™

SEPTIC SYSTEM INSTALLATION INSTRUCTIONS

1 Excavate and level 3' wide trenches.

2 Prepare trench bottom and sides in accordance with state and local regulations. (Infiltrator Systems recommends raking sidewall and bottom infiltrative surfaces to eliminate smearing.)

3 Screw splash plate on bottom of open end plate.

4 Screw open end plate into inlet end (without interlocks) of first INFILTRATOR™ chamber with splash plate extending into unit.



5 Place first unit in the inlet end of trench with interlocks downstream.

6 Run distribution pipe through inlet opening in end plate but not beyond splash plate. Single screw may be used to hold in place. **Pipe does not normally run the length of system.**



7 Connect INFILTRATOR™ units together, fully engaging interlocks to form desired trench length.

a. The joints may be screwed together for ease in construction.


b. Trench grade should be checked with a level or surveying equipment.

8 Screw closed end plate in downstream end of last unit to hold in place. **NOTE:** For serial distribution, or to loop the trenches together, use an open end plate at the downstream end of the trench, and run a pipe from the opening to the next trench.

9 Fill side wall area to top of slots with native soil. "Walk" fill into place to give proper support of sides. **THIS IS VERY IMPORTANT TO ACHIEVE FULL STRENGTH.**



10 Backfill to a minimum of 12" of cover after compaction and settling for H-10 units and 18" for H-20 units. Avoid large rocks in the backfill material. **CAUTION:** Avoid vehicle traffic on system during construction since soil has not settled. This is particularly important in sand, since loose sand offers very little structural support. Most states advise avoiding vehicle traffic to prevent compaction of the infiltrative surface. (After proper depth of cover is compacted and settled, INFILTRATOR™ leaching chambers will then support vehicle weight not to exceed 16,000 lbs. per axle for H-10 units and 32,000 lbs. per axle for H-20 units.)



INFILTRATOR™ is a trademark of Infiltrator Systems, Inc.


PROPOSED PLOT PLAN

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON STREET
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 3731B

TC: 139-041-04 LOT 41

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



OWNER/AGENT SIGNATURE John C McNamee

DATE 9/14/95

APPROVAL DATE _____

White - Health Department's Copy Canary - E.H.S. Copy Pink - Owner's Copy

LOT 41


PROPOSED PLOT PLAN

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON STREET
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 37315

TC: _____

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



APPROVAL DATE _____