C of A (s) No. 3620

Serial 3316

T. C No 053-12278

Date Issued 7 Dec 1979

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Barefoot, Jerry C. (LAST, FIRST, MIDDLE)

Location of Property 10517 Harbor Drive

Application Number

Permit Number

Inspection Date:

Liquid Capacity of Tank 1000 gal

Total Length of Drain Tile 330 ft

Depth of Filter Materia 12"

Water Supply Source community well

Excavation Inspected — DATE

Nitrification Field Inspected 7 Dec 1979 DATE

Washing Machine Line Inspected If Applicable 7 Dec 1979 DATE

Tank Material pre-cast

Number of Lines 5 & 2

Cover Depth 18"


Distance from Water Source —

Tank Inspected 7 Dec 1979 DATE

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ✓ installed or constructed, altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect at the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit and in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments

2 beds
15 x 33
wash line
6 x 2 1/2 x 36"



John R Atkinson
Environmentalist

EHD-S-76

Environmental Health Department's Copy