Serial No. 3997

PTR No. 17699

Date Issued March 13, 1981

T C No. po 217-021-16

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Hanks, Hall Smith, Jr.
(LAST, FIRST, MIDDLE)

ADDRESS OF OWNER 3717 Flowerfield Road, Charlotte, NC 28210

LOCATION OF PROPERTY off: Youngblood Road
(STREET OR COUNTY ROAD)

SUBDIVISION LOT NO BLOCK NO



PLOT PLAN

[illegible] was conducted

Provisionally Suitable

[illegible] approved

[illegible] the Mecklenburg County Depar[illegible]

[illegible] the Mecklenburg [illegible]

[illegible] system must [illegible]

[illegible] the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission in effect at the date of issuance and is void at any time in the future prior to completion of the system if said laws, rules and regulations are changed such that the approval would not have been granted had the new or revised laws, rules and regulations been in effect on the issue date.

Soil Scientist

Environmental Health Director or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

S.I.R. No. 17699
T.C. No. P.O 217

(Ground Absorption Sewage Disposal)

OWNER: Smith HANKS, Jr.
ADDRESS: 2417 Flowerfield Rd
COUNTY: Charlotte 28210
LOCATION OF SITE: off your Eleva Rd on Smith Rd -

DATE REQUESTED: 3-3-81
PLAT NO:
LOT SIZE: 8A

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) 2 - 15 U	S (PS) U	S (PS) 4 - 20 U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2:1 Clay)	S PS U	S PS U	S PS (U) Sandy loam clayey sand	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) U	S (PS) U	S PS (U) Single Grain to Massive	S PS U
4. SOIL DEPTH (inches)	S (PS) U	S (PS) U	S (PS) 48 U	S PS U
5. RESTRICTIVE HORIZONS (inches) (Impervious strata, Rock)	S (PS) U	S (PS) U	S PS (U) Clay at 48 inches	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S (PS) U	S (PS) U	S PS (U) Internal	S PS U
7. SOIL PERMEABILITY (percolation rate)	S (PS) U	S (PS) U	S PS (U) Fast To Slow	S PS U
8. OTHER (specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	✓		Unsuitable	
10. SOIL SERIES			complex of Wilkes, Helena Saprolite	

S - Suitable PS - Provisionally Suitable U - Unsuitable


** See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope)

Recommendations/Comments:

Described By: W. B. Ramsey
Title: Soil Scientist
DHS Form 2601
Sanitation
EHD 539 (2/80)

Date: 3-13-81

✓


3A
site 1
X
Central
2-15
Existing
site 3
X
site 2
X
Central
2-15

Date Received 3/3/01

APT No. 17699
portion of
T. D No. 217-021

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Hanks, Jr. (LAST) Hall (FIRST) South (MIDDLE)

2) ADDRESS OF OWNER 3717 Flintfield Rd ZIP 28216

3) PHONE NO Home 535-1624 Office 332-5102


4) LOCATION OF PROPERTY off Sharon Amity Rd
(STREET OR COUNTY ROAD)

5) SUBDIVISION _____ LOT NO _____ BLOCK NO _____

MAP BOOK NO _____ PAGE NO _____

6) DEED REFERENCE DEED BOOK 4274 PAGE NO 511

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation on the property described for the purpose of determining the site suitability for the installation of an individual sewage disposal system with subsurface soil absorption effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

H B Hanks Jr
OWNER

EHD-5-76

Environmental Health Department's Copy