Date Received 1-16-74

MECK COUNTY HEALTH DEPT.

APT No 7422

T C No

Map Date

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER [illegible] (LAST) JOSEPH (FIRST) S. (MIDDLE)

2) ADDRESS OF OWNER 6221 Montpelier Drive ZIP 28209

3) PHONE NO Home 523-2031 Office


4) LOCATION OF PROPERTY 417 MONTPELIER DRIVE (STREET OR COUNTY ROAD)

5) SUBDIVISION CARMEL PARK ESTATES LOT NO K BLOCK NO

MAP BOOK NO 2095 PAGE NO 417

6) DEED REFERENCE DEED BOOK 2140 PAGE NO 211

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Joseph S. Turner
OWNER

FORM NO E-1-9-1-72

HEALTH DEPARTMENT'S COPY

MECKLENBURG COUNTY
Department of Public Health

1200 Blythe Boulevard
Charlotte, North Carolina 28203

Telephone 374-2113

Date Issued
1. 3-13-74
2. _____
3. _____

1 SITE DISAPPROVAL REPORT
INDIVIDUAL SEPTIC TANK SYSTEM WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

SDR No. 7422
T.C. No. 211-191-11
12-14-73

NAME OF OWNER Turner, Joseph S.

ADDRESS OF OWNER 6221 Montpelier Drive ZIP 28209

LOCATION OF LOT 417 Sherwood Drive, Lot K

The lot described above has been disapproved for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge due to the following:

FAILURE TO PASS PERCOLATION TEST (60 minutes per inch or less)

	Test No.	Date of Test	Percolation Rate
____	1.	_____	_____ min/in
____	2.	_____	_____ min/in
____	3.	_____	_____ min/in

X ON SITE INSPECTION REVEALED LOT TO BE UNSUITABLE FOR THE FOLLOWING REASON(S) 3-13-74 - Percolation test holes were too close together. Holes must be 10 feet apart.

Environmentalist

(Stencil No.)
EHD 398
8/70

FORM NO.
E-19-8-14-70

Serial No. 4152

PTR No 7422

T C No 211-191-11

Date Issued March 15, 1974

Map Date

Do Not Issue A Building Permit Based On This Form

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION


PERCOLATION TEST REPORT

NAME OF OWNER Turner (LAST) Joseph (FIRST) S. (MIDDLE)

ADDRESS OF OWNER 6221 Montpelier Drive ZIP 28209

LOCATION OF PROPERTY 417 Merrymount Drive (STREET OR COUNTY ROAD)

SUBDIVISION Carmel Club Estates LOT NO K BLOCK NO



PLOT PLAN

This is to certify that a percolation test has been run and an on site inspection made by the Mecklenburg County Health Department on the lot described above. The said test was conducted on that portion of the lot as indicated on above plot

The percolation rate determined by the test was 60 min/in The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter, or repair the specific system shall be obtained from the Mecklenburg County Health Department prior to the beginning of any construction of buildings, or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Health Department prior to installation based on the percolation rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area where the percolation test was run.
4. This approval is void if any grading, filling, or construction (including the drilling of a well) is performed on the lot which in the opinion of the Health Department, renders the area where the percolation test was run unsuitable for the installation, construction, alteration, and/or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina State Board of Health and the Mecklenburg County Board of Health which were in effect on the date of issuance and is void if at any time in the future, prior to the completion of the system, these laws, rules, and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

Director, Environmental Health Division or Authorized Section Head

FORM NO. E-2-9-1-72

HEALTH DEPARTMENT'S COPY