Date Received 7/5/17

MECK COUNTY DEPARTMENT OF
RECEIVED
JUL 2 1917
ENVIRONMENTAL HEALTH


APT No. 13199
T C No. 219-091-07
Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Lawrence (LAST) Nellie (FIRST) Stroup Widow (MIDDLE)
2) ADDRESS OF OWNER Rt 4, Ft Mill, S.C. (Highway #160 in N.C.) ZIP 29715
3) PHONE NO. Home 588-0178 Office 889-7621 or 588-0890
4) LOCATION OF PROPERTY N.C. Highway #160 (STREET OR COUNTY ROAD)
5) SUBDIVISION None LOT NO 7 BLOCK NO. ———
MAP BOOK NO 219 PAGE NO 9
6) DEED REFERENCE DEED BOOK 2116 PAGE NO 147

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATE & DETAILED DIMENSIONAL LOT

✓ Nellie Lawrence
OWNER

EHD 5-76

Environmental Health Department's Copy

DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES

APPENDIX H

SITE EVALUATION

(Ground Absorption Sewage Disposal) Pc 111-091-07

APPL 12 799

OWNER: Nellie Strong Lawrence

DATE REQUESTED: July 5, 1977

ADDRESS: Rt. 4, Fort Mill, S.C.

PLAT NO.:

COUNTY:

LOT SIZE: 2.36 Ac.

LOCATION OF SITE: Highway 160 South of Hamster Rd

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS U 2-6%	(S) PS U 2-6%	S PS U —	S PS U
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1 clay)	S (PS) U clay	S (PS) U clay	S PS U —	S PS U
3. SOIL STRUCTURE (12-36 in.) (Clayey soils)	S (PS) U Blocky	S (PS) U Blocky	S PS U —	S PS U
4. SOIL DEPTH (In.)	(S) PS U >40"	(S) PS U >40"	S PS U —	S PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, rock)	S PS U —	S PS U	S PS U —	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	(S) PS U >6' To water table	(S) PS U >6' To water Table	S Seasonal PS perched high water U Table	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S (PS) U Moderate 60 Min/in	S (PS) U Moderate 60 Min/in	S PS (U) subject To Flooding	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION*	Provisionally suitable	Provisionally suitable	unsuitable	
SOIL SERIES	Appling	Cecil	Chewacla	

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc.)


Recommendations/Comments: Based on this investigation, an adequate area of provisionally suitable soil for the installation of a septic tank system was found on the lot. System design should be based on a percolation rate of 60 min/in and system location in area of provisionally suitable soils

Described By: William J Martin

Title: Soil Scientist

Date: July 7, 1977

DHS Form 2601 (2/77)
Sanitation


Highway 16C
355
LAKE
channel
Apple
1315
1150
Ext. 1
50

Serial No. 1091

PTR No. 12799

T C No P.0.219-091-07

Date Issued July 13, 1977

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Lawrence (LAST) Nellie (FIRST) Stroup (MIDDLE)

ADDRESS OF OWNER Rt.4, Fort Mill, South Carolina ZIP 29715

LOCATION OF PROPERTY Highway 160 (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO 7 BLOCK NO



PLOT PLAN

This [illegible], that a soil and site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot **Provisionally**

The permeability rate determined by the investigation was **Suitable** The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge subject to the following terms and conditions

A permit for the installation of the proposed system shall be issued by the Mecklenburg County Department of Environmental Health upon the payment of the construction permit fee and the approval of the wastewater treatment system on the lot plot

1. The use of the septic tank with a sewage treatment system which must be installed as determined by the Mecklenburg County Department of Environmental Health prior to the issuance of the permit at the rate obtained above, and on the size and type of building for which it is proposed.
3. The approval is valid only for the system as specified. Any immediate deviation from an acceptable system installation on the above lot
4. This approval and the granting of a permit is based on the percolation test performed on the lot which is on file in the Mecklenburg County Department of Environmental Health for the area indicated as acceptable for system installation. Any subsequent modification, construction or repair to this system

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules and regulations been in effect on the issue date

William A. Marion
Soil Scientist

John C. Hobbson
Environmental Health Director or Authorized Section Head

EHD 5-76

Environmental Health Department's Copy