#14136

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

(Ground Absorption Sewage Disposal)

OWNER: Allison, R. S.
ADDRESS: 2904 Little Rock Rd
COUNTY:
LOCATION OF SITE: Hwy 160 N.C. Lot #1

DATE REQUESTED: 15 May 1978
PLAT NO.: P.B. 199-192-17
LOT SIZE: 40,000

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS U 2.8%	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S (PS) U clayey	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S (PS) U blocky	S PS U	S PS U	S PS U
4. SOIL DEPTH (In.)	S (PS) U >48"	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Imprevious Strata, Rock)	S (PS) U none noted	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	S (PS) U fair	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S (PS) U slow 90 min/in	S PS U	S PS U	S PS U
8. OTHER (Specify)	S (PS) U adequate area	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	→ provisionally suitable			
SOIL SERIES				


S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc)

Recommendations/Comments:

Described By: John R. Atkinson
Title: Sanitarian I Date: 25 May 1978

DHS Form 2601 (2/77)
Sanitation


Hwy 160
103
1
311
268
150

Serial No. 1908

PTR No. 14136

Date Issued 5/30/78

T C No. P.O. 199-192-14

Map Date -


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Allison (LAST) David (FIRST) S. (MIDDLE)

ADDRESS OF OWNER 2904 Little Rock Road, Charlotte, N. C. ZIP 28214

LOCATION OF PROPERTY Highway 160 (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO 1 BLOCK NO



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot **PROVISIONALLY SUITABLE**

The permeability rate determined by the investigation was The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions

1. A permit to install construct alter or repair the specific system shall be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction of buildings or of the wastewater treatment system on the said lot
2. The size of the septic tank and the wastewater treatment system which must be installed will be determined by the Mecklenburg County Department of Environmental Health at the time of application based on the permeability rate obtained above, and on the size and type of building constructed thereon
3. This approval is valid only at the location and for the system as indicated on the above plot
4. This approval is void if any grading filling or construction including the drilling of wells performed on the lot which, in the opinion of the Mecklenburg County Department of Environmental Health renders the area indicated as acceptable for system installation unsuitable for installation construction alteration and/or repair of such a system

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

John A. Johnson
Environmentalist

EHD-3-76

Environmental Health Director or Authorized Section Head

Environmental Health Department's Copy

SEE INSTRUCTIONS ON BACK

Date Received 8/22/78

ICAR (S) Application No 14136 ~~14087~~

T C No. 199-19214


Map Date 5-15-78

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to

X Install or Construct 2 Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption effluent discharge



Mobile Home Yes No
Residence X
No. of Bedrooms 3
Business Use Max. No. Employees
Washing Machine Yes No
Garbage Disposal Yes No
Dishwasher Yes No
Water Supply
A. Individual well
B. Government system
C. Community system
1. Well inside
2. Government outside
Sewage System
Property within 200 feet of public sewer Yes No
Property within 200 feet of community sewer Yes No
FHA Case No.
VA Case No.

3) PLOT PLAN (ACCURATELY DIMENSIONED)

(13) NAME OF OWNER HUSS (LAST) GEORGE (FIRST) BRICE (MIDDLE)

(14) ADDRESS OF OWNER 7600 ALTACREST PL.

(15) PHONE NO Home 525-0683 Office

(16) LOCATION OF SYSTEM STEELE CREEK RD (STREET OR COUNTY ROAD) HWY 160

(17) SUBDIVISION Lot No. 1 Block No

Map Book No Page No.

(18) DEED REFERENCE — DEED BOOK 11 AT PAGE 193

19) HAS A SOIL INVESTIGATION BEEN RUN? X YES NO DATE RUN 5-15-78

20) PTR NUMBER (See Instructions) 14087

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

DATE OF APPLICATION

X GB Huss
OWNER

EHD-5-76

Environmental Health Department's Copy

Serial No. 2155

LA No. 14136

Date Issued August 22, 1978

T. C. No. 199-192-14

Map Date 5-15-78

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

IMPROVEMENT PERMIT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Huss (LAST) George (FIRST) Brice (MIDDLE)

ADDRESS OF OWNER 7600 Altacrest Place, Charlotte, NC ZIP _____

LOCATION OF LOT Steele Creek Road (STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO. 1 BLOCK NO. _____

MAP BOOK NO. _____ PAGE NO. _____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 14067. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Aiteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altred, and/or repaired and that the system be installed in accordance with same

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit

John R. Thomson

Environmentalist

Environmental Health Director, or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy