Date Received 10-4-83

RECEIVED
OCT 4 1983
ENV

SIR No. 20116

T. C. No. 059-141-04

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Noblett (LAST) Jimmie A. & Sara F. (FIRST, MIDDLE)

2) ADDRESS OF OWNER 4036 Teakwood Drive, Charlotte, N. C. ZIP 28210

3) PHONE NO. Home 525-6676 Office 523-3571

4) LOCATION OF PROPERTY Lakeway Drive (STREET OR COUNTY ROAD)

5) SUBDIVISION West View Hills LOT NO 149-152 BLOCK NO.

MAP BOOK NO 6 PAGE NO. 671 TAX CODE NO: 059-141-04

6) DEED REFERENCE DEED BOOK 3057 PAGE NO 635

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

OWNER James A Noblett

END-5-74

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SIR. NO. 20116
T.C. NO. 059-141-04
DATE: 10-14-83

Jimmie A. & Sara P. Noblett
4036 Teakwood Drive
Charlotte, NC 28210

Re: Property located at Lakeway Drive, Lots 149-152

At your request, a field investigation was conducted on the property designated above. The soils on the property were found to contain a limited area of provisionally suitable soil for the installation of a ground absorption sewage disposal system. A copy of the site evaluation report is enclosed for your information.

Should you desire to file for permission to install a ground absorption sewage disposal system, please submit plot plans for the proposed construction, well, and ground absorption sewage disposal system to this office. They will be reviewed and if it is found that there is an adequate area of provisionally suitable soil to accommodate the proposed installation, an Improvements Permit will be issued by this office.

If I may be of assistance, please feel free to call.

Sincerely,

Bill D. Hardister, Jr.
Environmental Health Supervisor

BDH/kbg

Enclosure

DEPARTMENT OF
ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 20116

T.C. NO. 059-141-04

(Ground Absorption Sewage Disposal)

OWNER: Jimmy & Sara Noblett
ADDRESS: 4036 Teakwood Dr. Charlotte, N.C. 28210
PLAT NO: Lots 149-852
LOT SIZE: 18,295
LOCATION OF SITE: Takeway Dr.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S PS 2-8% U	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S PS clay U	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S PS Blocky U	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	S PS 36-40" U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S PS >36" U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S PS >36" to ground U water	S PS U	S PS U	S PS U
7. OTHER (Specify)	S PS see Note U	S PS U	S PS U	S PS U
8. SOIL GROUP	IVA			
9. SITE CLASSIFICATION	provisionally suitable			
10. SOIL SERIES	Cecil Like			

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments: Road culvert dumps water onto the lot at front. system should be located away from this Area lot is less than 20,000 sq. ft. Adjacent houses are on well water

Described by: William A. Martin
Title: Soil Scientist

Date: 10-14-83

EHD 539 (Revised: 6/82)

1+


100'
Creek Like
182'
185
Lake Way
100'