DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 21123

T.C. NO. 037-022-23

(Ground Absorption Sewage Disposal)

OWNER: GROVER PENCE
ADDRESS: 206 RIDGE ROAD MT. HOLLY, N.C. 28120
LOCATION OF SITE: END of THOMPSON AVE.

PLAT NO:
LOT SIZE: 1.84 A

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U — 2-4	S (PS) U — 2-6	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S PS (U) — Mixed Clay	S PS (U) — Mixed Clay	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S PS (U) — Week Structure	S PS (U) — Week Structure	S PS U	S PS U
4. SOIL DEPTH (inches)	S PS (U) — 20-30	S PS (U) — 20-25	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S (PS) U — None	S (PS) U — None	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S PS (U) — Slow	S (PS) U — Slow	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	IVe	IVe		
9. SITE CLASSIFICATION	Unsuitable	Unsuitable		
10. SOIL SERIES	Iredell	Wilkes ENP		

S - Suitable PS - Provisionally Suitable U - Unsuitable


**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments:

Described by: W. B. Ramsey
Title: Soil Scientist

Date: 7-9-84

2H


Thompson Avenue
250 Dead End
543
250

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE NORTH CAROLINA 28203

SIR. NO. 21123
T.C. NO. 037-022-23
DATE: 7-10-84

Grover Pence
205 Ridge Drive
Mt. Holly, NC 28120

RE: Property located at Thompson Avenue

Dear Mr. Pence:

At your request, a field investigation was conducted on the property designated above and was classified unsuitable for the installation of a ground absorption sewage disposal system. A copy of the site evaluation report is enclosed for your information.

Sites classified as unsuitable may be utilized for soil absorption disposal systems provided engineering, hydrogeologic, soil and environmental studies indicate that a suitable septic tank system or a suitable alternate system can be reasonably expected to function satisfactorily.

Should you desire to file for permission to install an alternate system, plans and specifications prepared by a person with a demonstrated knowledge of ground absorption sewage treatment disposal systems, soil and rock characteristics, groundwater hydrology and drainage systems should be submitted to this office. They will be reviewed and if it is found that the system may be reasonably expected to function satisfactorily, approval will be given upon the execution by you of "Septic Tank Agreemnt Form" provided by this office.

If I may be of assistance, please feel free to call.

Sincerely,

Bill D. Hardister, Jr.
Environmental Health Supervisor

BDH/kbg

Enclosure