Date Received 7/12/77

APT No. 12837

T. C. No. 141 055 42

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Kahala Corp. (LAST / FIRST / MIDDLE)

2) ADDRESS OF OWNER P.O. Box 17576, Charlotte, N.C. ZIP 28211

3) PHONE NO Home _____ Office 366 2585


4) LOCATION OF PROPERTY Timberley Place (STREET OR COUNTY ROAD)

5) SUBDIVISION _____ LOT NO 6 BLOCK NO. _____

MAP BOOK NO 10 PAGE NO 37

6) DEED REFERENCE DEED BOOK _____ PAGE NO _____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

H. W Martin, Secy.
OWNER

EHD-5-76

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

(Ground Absorption Sewage Disposal)

APT 12837
TC 141-055-42
L-146

OWNER: Jehala Corp
ADDRESS: P.O. Box 1175
COUNTY: Charlotte, N.C. 28211
LOCATION OF SITE: Turtle Cove

DATE REQUESTED: 7-12-77
PLAT NO.:
LOT SIZE: 27,500

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) 2-6 PS U	S PS — U	S PS U	S PS U +
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S (PS) clay U	S PS — U	S PS U	S PS U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S (PS) Blocky U	S PS — U	S PS U	S PS U
4. SOIL DEPTH (In.)	(S) 48" PS U	S PS — U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In. (Inprevious Strata, Rock)	S PS — U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	(S) 7-8' to PS water U Table	S Seasonal PS Perched (U) high water Table	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S Moderate (PS) 60 min/in U	S subject PS to Flood (U)	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	Provisionally suitable	unsuitable		
SOIL SERIES	Cecil	Chewacla		

S - Suitable PS - Provisionally Suitable U - Unsuitable


* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc)

Recommendations/Comments: Based on this investigation, the designated area is provisionally suitable for the installation of a septic tank system. It was found that the system design should be based on percolation rate of 60 min/in and system located in provisionally suitable soils

Described By: William A. Marler

Title: Soil Scientist Date: 7-20-77

DHS Form 2601 (2/77)
Sanitation


100'
Chevrolet
275
275
160'
Corral
100'
Timberly Place

Serial No. 122

PTR No. 12837

Date Issued July 27, 1977

T C No 141-055-42

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Kahala Corporation
(LAST) (FIRST) (MIDDLE)

ADDRESS OF OWNER P.O. Box 17576, Charlotte, NC ZIP 28211

LOCATION OF PROPERTY Timberley Place
(STREET OR COUNTY ROAD)

SUBDIVISION LOT NO 6 BLOCK NO



PLOT PLAN

This is to certify that a soil investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The soil investigation was conducted on that portion of the lot indicated on the above plat **Provisionally**

The soil at the site determined by the investigation was **Suitable** The said lot is approved for the installation of an individual subsurface tank wastewater treatment system with subsurface soil absorption effluent discharge subject to the following terms and conditions:

1. [illegible] the Mecklenburg County Department of Environmental Health [illegible] the wastewater treatment system [illegible]
2. [illegible] the Mecklenburg County Department of Environmental Health [illegible] the rate obtained above and in the use of [illegible]
3. [illegible] the system installation in the above plat.
4. [illegible] the Mecklenburg County Department of Environmental Health [illegible] system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future prior to completion of the system these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules and regulations been in effect on the issue date

William A. Mailon
EHD-5-76 Soil Scientist

John R. Adkisson
Environmental Health Director or Authorized Section Head

Environmental Health Department's Copy