Date Received 12-11-84

RECEIVED
DEC 11 '84
ENVIRONMENTAL HEALTH

SIR No. 21693
T.C.No. 157-161-01
Map Date L

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Rube W. Williams
(LAST, FIRST, MIDDLE)

2) ADDRESS OF OWNER 322 Todville Rd. Charlotte NC ZIP 28214

3) PHONE NO. Home 377-7012 Office


4) LOCATION OF PROPERTY Corner of Craig + Harding Sts.
(STREET OR COUNTY ROAD)

5) SUBDIVISION LOT NO. BLOCK NO.

MAP BOOK NO [redacted] PAGE NO. [redacted]

6) DEED REFERENCE DEED BOOK 4603 PAGE NO 73

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Rube W. Williams
OWNER

EHD-5-76

Environmental Health Department's Copy

C of A (s) No. 21693

Date Issued 8-27-85 **Serial** 7824 T. C. No. 057-161-01 L CRT

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF COMPLETION
CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Reynolds Jr. Everette
LAST FIRST MIDDLE

Location of Property ~~[illegible]~~ 6534 Craig Street 8/26/85

Application Number 21693 Permit Number 21693

Inspection Data:

Liquid Capacity of Tank 1000 Tank Material PVC

Total Length of Drain Tile 400' Number of Lines Four

Depth of Filter Material 12" Cover Depth 12"

Water Supply Source [illegible] Distance from Water Source —

Excavation Inspected [illegible] DATE Tank Inspected 8-26-85 DATE

Nitrification Field Inspected [illegible] DATE

Washing Machine Line Inspected, If Applicable — DATE

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been installed or constructed, altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments [illegible]

Environmentalist

EHD-5-76

Date Issued 8-30-85

Serial No. 08441


ICAR(S) Permit No. 21693

T. C. No. 057-161-01

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 21693, dated 7-25-85 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 9-20-85, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate Rd

Liquid Capacity of Tank 1500

Tank Construction RCC

Absorption and/or Nitrification Lines:

Total Line Length 400'

Number of Lines 5

Distance from House 5'

Distance from Property Line 10'

Distance from Well City

NAME OF OWNER Everette Reynolds Jr.

LOCATION OF PROPERTY ~~323 Fairview St.~~ 6534 Craig St (on Eng. sht)

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

5 lines 3'X50'X12" stone

Comments:

Division or Section Head

B. A. Ferguson
Environmentalist

If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

Department Copy

Date Issued 1-15-85

Serial No. 8115

SIR No. 21693

T. C. No. PO 057-161-01

Map Date L CRT

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
IMPROVEMENT PERMIT

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Williams, (LAST) Rube (FIRST) Wilford (MIDDLE)

ADDRESS OF OWNER 322 Toddville Rd., Charlotte, NC ZIP 28214

LOCATION OF LOT ~~323 Lawing Street~~ 6534 Craig St. (Off Cty) (STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO _____ BLOCK NO. _____

MAP BOOK NO. _____ PAGE NO _____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number ~~21683~~. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altered, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

W. B. Ramsey
Environmentalist

Environmental Health Director, or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

SEE INSTRUCTIONS ON BACK

Date Received 1-15-85

ICAR (S) Application No. 21693

TVC No 057-161-01


Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) ___ ✓ Install or Construct 2) ___ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ___ Yes ___ No
Residence ✓ Yes ___ No

4) No of Bedrooms 3
5) Business Use — Max No Employees ___
6) Washing Machine ___ Yes ___ No
7) Garbage Disposal ___ Yes ___ No
8) Dishwasher ___ Yes ___ No
9) Water Supply
A) Individual Well ___
B) Governmental System ✓
C) Community System
1 Well source ___
2 Governmental source ___
10) Sewage System
House located within 200 feet of public sewer ___ Yes ___ No
House located within 200 feet of community sewer ___ Yes ___ No
11) FHA Case No ___
12) VA Case No ___

13) NAME OF OWNER ~~Williams~~ Reynolds Emmette E. ~~Wilford~~ (LAST / FIRST / MIDDLE)

14) ADDRESS OF OWNER 311 Idlewild Rd Indian Hts N.C 28214

15) PHONE NO. Home 394-7412 Office 332-3

16) LOCATION OF SYSTEM Corner of Park & Lansing St (STREET OR COUNTY ROAD)

17) SUBDIVISION ___ Lot No. ___ Block No. ___

Map Book No. ___ Page No. ___

18) DEED REFERENCE — DEED BOOK 4003 AT PAGE 73

19) HAS A SOIL INVESTIGATION BEEN RUN? ___ YES ✓ NO DATE RUN 11-15-84

20) PTR NUMBER (See Instructions) 21693

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

x 1/15/85
DATE OF APPLICATION

x R. W. Williams
OWNER

EHD-S-76

Environmental Health Department's Copy

Serial No. 6015

SIR No. 21693

T. C. No. PO 057-161-01

Date Issued 1-10-85

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Williams, (LAST) Rube (FIRST) H. (MIDDLE)

ADDRESS OF OWNER 322 Toddville Rd, Charlotte, NC ZIP 28214

LOCATION OF PROPERTY Corner of Craig & Lawing Streets (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO BLOCK NO.



PLOT PLAN

This is to certify that a soil investigation report for the above property is on file in the Mecklenburg County Department of Environmental Health and that the soil investigation was conducted on that portion of the lot as indicated on the plot plan. PROVISIONALLY SUITABLE

The permeability rate determined by the investigation was The said lot is approved for the installation of an individual sewage disposal system with subsurface, soil absorption effluent discharge subject to the following requirements:

1. A permit must be obtained from the Mecklenburg County Department of Environmental Health prior to the installation of the sewage disposal system on the said lot.
2. The [illegible] Mecklenburg County Department of Environmental Health.
3. The [illegible] installation of the disposal system.
4. [illegible]


This approval is granted subject to the applicable provisions of the State Laws and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commissioner which were in effect at the date of issuance and is valid at any time in the future, prior to completion of the system, unless laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules and regulations been in effect on the issue date.

William A. Martin
Soil Scientist


Brice D. Hardister, Jr.
Environmental Health Director or
Authorized Section Head

EHD-5-76

Environmental Health Department's Copy


PG.20
ROZZELLES
FERRY
SEABOARD
OLD
MOUNT
HOLLY
PG. 15
4
5.40 AC±P
CHURCH
163
162
GLENHAVEN DR
CRAIG
578.12
PG. 15

BK. 35



TAX LINE MAP	BOOK 57	PAGE 16
MECKLENBURG COUNTY, NORTH CAROLINA		
REVISED	SCALE 1" = 200'	

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 21693

T.C. NO. PLAT-16LL

(Ground Absorption Sewage Disposal)

OWNER: Ruth W. Williams
ADDRESS: 922 Scotsville Ave
Charlotte N.C. 28211
LOCATION OF SITE: Craig & Laurey Rds

PLAT NO:
LOT SIZE: Over 20,000 sq ft

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S PS 2 to 7% U	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S PS clay U	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S PS Blocky U	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	S PS 36-40" U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S PS 72" U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S PS U	S Depression PS Drainageway U	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP				
9. SITE CLASSIFICATION				
10. SOIL SERIES		Depression Drainageway		


S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)


Recommendations/Comments:

Described by: William McMackin
Title:

Date: 1-10-95


Lane
Diagonal
Depression
210'
100'
120'
210'
Craig St.

BK. 35



TAX LINE MAP BOOK 57 PAGE 16
MECKLENBURG COUNTY, NORTH CAROLINA
REVISED SCALE 1" = 200'