C of A (s) No. 2565

Date Issued 28 Dec 1979 Serial 3376

T C No. 053-151-16

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Porter, Daniel (LAST, FIRST, MIDDLE)

Location of Property Wilkinson Blvd

Application Number _____ Permit Number 2565

Inspection Data:

Liquid Capacity of Tank 1500 gal Tank Material pre cast

Total Length of Drain Tile 300 Lft Number of Lines 5

Depth of Filter Material 12" + Cover Depth 18"

Water Supply Source well Distance from Water Source 100'

Excavation Inspected — DATE

Tank Inspected 12-28-79 DATE

Nitrification Field Inspected 12-28-79 DATE

Washing Machine Drain Inspected If Applicable — DATE

The undersigned has inspected the Individual Septic Tank System with subsurface soil absorption of effluent discharge as described above and it has been ~~installed~~ or constructed, altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permits in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments 022 permitted

John D Adamson
Environmentalist

EHD-5-76

Environmental Health Department's Copy

Serial 3484

Date Issued 26 Dec 1975


ICAR (S) Permit No. 2565

T C No. 053-151-16

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, __ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 2565, dated 8-21-75 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 1-15-80, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate: permit

Liquid Capacity of Tank: 150 gal

Tank Construction: pre cast

Absorption and/or Nitrification Lines

Total Line Length: 300

Number of Lines: 5

Distance from House: 8'

Distance from Property Line: 10'

Distance from Well: 100'

NAME OF OWNER: Porter, Daniel

LOCATION OF PROPERTY: Wilkinson Blvd.

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning controlling or using such system from any liability resulting from the failure of the system to operate properly.

in bed 15'x60'x15" plus aeration pit

John P. Atkinson
Environmentalist

Division or Section Head

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

Environmental Health Department's Copy