Date Received 12-23-83

MECK COUNTY DEPARTMENT OF
RECEIVED
DEC 22 1983
ENVIRONMENTAL HEALTH

Job # 984

SIR No. 20442

T. C. No. 22-301-17

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER William Trotter Company
(LAST / FIRST / MIDDLE)

2) ADDRESS OF OWNER P. O. Box35269 , Charlotte, N. C. ZIP 28235

3) PHONE NO. Home _____ Office 333-8804


4) LOCATION OF PROPERTY 8020 Mattson Place, (Off Providence Road West)
(STREET OR COUNTY ROAD)

5) SUBDIVISION Providence West LOT NO. 10 BLOCK NO. 4

MAP BOOK NO. _____ PAGE NO. _____

6) DEED REFERENCE DEED BOOK _____ PAGE NO. _____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Kate F. Trotter
OWNER William Trotter Company

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SIR. NO. 20442
T.C. NO. PO 223-201-17
DATE: June 8, 1984

William Trotter Company
PO Box 35269
Charlotte, NC 28235

Dear Sir:

RE: Property located at 8020 Mattson Place

At your request, a field investigation was conducted on the property designated above and was classified unsuitable for the installation of a ground absorption sewage disposal system. A copy of the site evaluation report is enclosed for your information.

Sites classified as unsuitable may be utilized for soil absorption disposal systems provided engineering, hydrogeologic, soil and environmental studies indicate that a suitable septic tank system or a suitable alternate system can be reasonably expected to function satisfactorily.

Should you desire to file for permission to install an alternate system, plans and specifications prepared by a person with a demonstrated knowledge of ground absorption sewage treatment disposal systems, soil and rock characteristics, groundwater hydrology and drainage systems should be submitted to this office. They will be reviewed and if it is found that the system may be reasonably expected to function satisfactorily, approval will be given upon the execution by you of "Septic Tank Agreemnt Form" provided by this office.

If I may be of assistance, please feel free to call.

Sincerely,

Bill D. Hardister, Jr.
Environmental Health Supervisor

BDH/kbg

Enclosure

APPLICATION FOR AN IMPROVEMENT PERMIT

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: ~~20442 + 20441~~ 20442

TC# 223-201-17

Job #984

JOB LOCATION

① ADDRESS: 8020 Mattson Place (STREET NO / STREET)

② FILE: 20442 + 20441

③ CITY: Matthews, N. C.

④ TAX PARCEL NO.: 223-201-17

⑤ SUBDIVISION: Providence West, Map 4

⑥ LOT: 9 + 10

⑦ BLOCK: 4

OWNER

⑧ NAME: William Trotter Company (FIRST / MIDDLE / LAST)

⑨ MAILING ADDRESS: P. O. Box 35269

⑩ CITY: Charlotte

⑪ STATE: NC

⑫ ZIP: 28235

⑬ PHONE: (WORK) 333-8804

⑭ (HOME) N/A

REQUEST

This request is for a(n):

⑮ ☑ New installation permit

⑯ ☐ Repair or alteration permit

⑰ ☐ Authorization for mobile home exchange

⑱ ☐ Other (specify)

DESIGN CRITERIA

System will serve:

⑲ ☒ Residence

⑳ ☐ Mobile home

㉑ ☐ Business or place of public assembly

㉒ Number of bedrooms? 3


㉓ Maximum occupancy?

㉔ Basement? ☐ yes ☒ no

㉕ Type?

㉖ Maximum number of employees?

㉗ Maximum number of seats?



WATER SUPPLY

㉙ Water supply from (present or proposed):

A ☐ Individual well

B ☐ Municipal system

C ☒ Community well

D ☐ Community system

㉚ The undersigned, owner of the property described above or "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

WILLIAM TROTTER COMPANY

Signed: By:

Date: December 19, 1985

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER'S COPY

Date Issued 12-27-85

Serial No. 9183

SIR No. 20442

T. C. No. PO 223-201-17

Map Date CR1

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER William Trotter Co.
(LAST / FIRST / MIDDLE)

ADDRESS OF OWNER P. O. Box 35269, Charlotte, NC ZIP 28235

LOCATION OF LOT 8020 Mattson Place
(STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO. 9 & 10 (combined) BLOCK NO. 4

MAP BOOK NO. _____ PAGE NO. _____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 20442. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altered, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

*** AGREEMENT FORM ON FILE ***

Environmentalist

Environmental Health Director, or Authorized Section Head

EHD-5-74

Environmental Health Department's Copy

COPY

FILE NO. 20442

STATE OF NORTH CAROLINA

COUNTY OF MECKLENBURG

ACKNOWLEDGEMENT OF REQUEST BY OWNER FOR RECLASSIFICATION OF SITE FROM "UNSUITABLE" TO "PROVISIONALLY SUITABLE" UNDER 10 NCAC 10A .1948(c)

The undersigned, William Trotter Company,

owner of property located at 8020 Matrson Place, Matthews, North Carolina Lots 9 + 10, Block 4

("the site") and described in an instrument recorded in Book 4913 at Page 706, Mecklenburg Public Registry, hereby acknowledges that he applied to the Mecklenburg County Department of Environmental Health ("the Department") for a permit to install a septic tank sewage disposal system on the site; that the Department evaluated the site for suitability for such a system in accordance with the regulations promulgated by the North Carolina Commission for Health Services as 10 NCAC 10A .1934 et seq; that the Department originally classified the site as "unsuitable" pursuant to the standards set forth in the regulations; that the undersigned requested pursuant to 10 NCAC 10A .1948(c) that the Department reclassify the site as "provisionally suitable" in light of the particular septic tank system proposed by the undersigned; that the Department considered various studies, data and other information which indicate to the Department that the septic tank system proposed by the undersigned can reasonably be expected to function satisfactorily and thus that the findings specified in 10 NCAC 10A .1948(c)(1), (2), and (3) can be made; and that the Department therefore reclassified the site as "provisionally suitable" and issued an appropriate permit for such proposed septic tank system.

The undersigned further acknowledges that the proper design, construction, operation and maintenance of such septic tank system is his responsibility and that neither the Department nor its officials, employees or agents warrant or guarantee that the said system installed pursuant to the permit issued by the Department will function in a satisfactory manner for any given period of time or that the Department, its officials, employees or agents assume any liability for any damages of any kind which are caused, or which may be caused, by a malfunction of such system.

The undersigned further agrees for himself, his heirs and assigns that he shall indemnify and hold harmless the Department, its employees and officials, as well as Mecklenburg County and its employees and officials, for any damages or other claims of any person or persons whatsoever arising out of the installation, operation, or failure of said septic tank system.

The undersigned further agrees for his heirs and assigns that, in the event any septic tank system installed under authority of the aforesaid permit fails to perform adequately in any respect, he will take whatever measures are required to correct same; or if such is impossible he will discontinue use of said system immediately.

Use of the singular masculine pronoun forms herein shall be deemed to also include the plural and feminine forms as the context may require.

This document shall be placed on the public records of the Register of Deeds of Mecklenburg County and indexed therein under the Grantor Index in the name or names of the undersigned, and the foregoing acknowledgements shall henceforth be binding on all persons claiming any right, title, or interest in the site.

This 30th day of December, 1985.

Secretary

WILLIAM TROTTER COMPANY (SEAL)

By William Trotter (SEAL)
President

STATE OF NORTH CAROLINA
COUNTY OF MECKLENBURG

I, _____, a Notary Public for said County and State, do hereby certify that _____ personally appeared before me this date and acknowledged the due execution of the foregoing instrument.

WITNESS my hand and notarial seal, this _____ day of _____, 198__.

Notary Public

My Commission Expires: _____

PRESENTED FOR REGISTRATION JUN 9 2 11 PM 86 MECKLENBURG CO., N.C.

STATE OF NORTH CAROLINA
COUNTY OF MECKLENBURG

I, Terry Pressley, a Notary Public for said County and State, do hereby certify that Stoney E. Motsinger personally came before me this day and acknowledged that he is Secretary of William Trotter Company, and that by authority duly given and as the act and deed of said corporation, the foregoing instrument was signed in its name by its President, sealed with its corporate seal and attested by Stoney E. Motsinger.


WITNESS my hand and notarial seal, this 30th day of December, 1985.

Terry L. Pressley
Notary Public

My Commission Expires: October 22, 1989

File 20442

E17
Job 984



Mattson Place
Combine Lots 9+10, Block 4
Providence West, Map 4

William Trotter Company
P.O. Box 35269
Charlotte, N.C. 28235

PLOT PLAN

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 21442

T.C. NO. 00-323-201-17

(Ground Absorption Sewage Disposal)

OWNER: William Taylor Co.
ADDRESS: P.O. Box 35268
Charlotte, N.C. 28235

PLAT NO: 6-C-34
LOT SIZE: Approx 5 Acre

LOCATION OF SITE: 9020 Wilson Blvd

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	
1. SLOPE (%)	S (PS) U 2-10%	S (PS) U 8-10%	S PS (U) Complex Slopes	S (PS) U 2-10%	(S) 2-8%
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S (PS) U Clay	S (PS) U Clay	S PS— U	S PS (U) 2-1 Clay	(U) 2-1 Clay
3. SOIL STRUCTURE (12-36 inches)	S (PS) U Blocky	S (PS) U Blocky	S PS— U	S (PS) U Blocky	(PS) Blocky
4. SOIL DEPTH (inches)	S (PS) U 36-40"	S (PS) U 36-40"	S PS— U	S (PS) U 36-40"	(U) 24-36"
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S (PS) U 730"	S (PS) U 730"	S PS— U	S (PS) U 730"	(U) 730"
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S (PS) U 730" Ground Water	S (PS) U 730" Ground Water	S Eroded Areas Channel PS Runoff U	S Perched PS Water (U) 30-36"	(PS) 730" To Ground Water
7. OTHER (Specify)	S PS (U) Restricted Area	S PS (U) Restricted Area	S PS U	S PS U	
8. SOIL GROUP	II H	II H		II B	II B
9. SITE CLASSIFICATION	unsuitable	unsuitable	unsuitable	unsuitable	unsuitable
10. SOIL SERIES	Cecil Lithic	Appling Lithic	Complex Slopes	Helena Lithic	Enon

S - Suitable PS - Provisionally Suitable U - Unsuitable


**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments: _____

Described by: William R. Mackie
Title: Soil Scientist

Date: 1-7-84

2-A


250'
Helena Lime
35-2
247'
Entrada
Carmel Shale
Carmel Lime
Pompons Shale
Entrada
115'
Bedding

Date Issued 3-24-86

Serial No. 09060


ICAR(S) Permit No. 20442

T C No. 223-201-17

Map Date L

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, ___ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 20442, dated 12-19-85 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 4-24-86, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate IV-4

Liquid Capacity of Tank 1500

Tank Construction PCC

Absorption and/or Nitrification Lines:

Total Line Length 400'

Number of Lines Four

Distance from House 5'

Distance from Property Line 10'

Distance from Well >100'

NAME OF OWNER William Trotter Co.

LOCATION OF PROPERTY 8020 Mattson Pl.

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

Four Trenches 100'X3'X12" Stone

Comments:

B Sandifer
Division or Section Head

Jim Grissom
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-S-76

Environmental Health Department's Copy

C of A (s) No. 20442

Date Issued 3-28-86 **Serial** 8390 T. C. No. 223-201-17

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF COMPLETION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner William Trotter, Jr. (LAST, FIRST, MIDDLE)

Location of Property 8020 Mattson Rd

Application Number —

Permit Number —

Inspection Data:

Liquid Capacity of Tank 1500

Tank Material PCC

Total Length of Drain Tile 400'

Number of Lines 4

Depth of Filter Material 12"

Cover Depth 15" - 32"

Water Supply Source Comm.

Distance from Water Source —

Excavation Inspected 3-28-86 (DATE)

Tank Inspected 3-28-86 (DATE)

Nitrification Field Inspected 3-28-86 (DATE)

Washing Machine Line Inspected, If Applicable — (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ✓ installed or constructed, altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments 1986, 1526ST, CCA, 1260SFT, 12E, Helena

B. R. Ferguson
Environmentalist

EHD-S-76

Environmental Health Department's Copy

APPLICATION FOR AN IMPROVEMENT PERMIT

MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

Mecklenburg County services are available without regard to ethnic origin, sex, or disability

MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH
RECEIVED
APR 1 1987

(OFFICE USE ONLY)
FILE: 20442
TC:
SERIAL: № 12804
☑ L ☐ CRT

JOB LOCATION

① ADDRESS: 8020 (STREET NO) Mattson Place (STREET) ② FILE: 20442
③ JURISDICTION: ④ TAX PARCEL NO.: 223-201-17
⑤ SUBDIVISION: Providence West, Map 4 ⑥ LOT: 9 & 10 ⑦ BLOCK: 4

OWNER

⑧ NAME: George (FIRST) M. (MIDDLE) Morrow (LAST)
⑨ MAILING ADDRESS: 8020 Mattson Place
⑩ CITY: Matthews ⑪ STATE: NC ⑫ ZIP: 28105
⑬ PHONE: (WORK) 333-1266 ext 326 or 563 (Mike) 316 (Mary) ⑭ (HOME) 542-1272

REQUEST

This request is for a(n):

⑮ ☐ New permit
⑯ ☒ Repair or alteration permit
⑰ ☐ Authorization for mobile home exchange
⑱ ☐ Other (specify)

DESIGN CRITERIA

System will serve:

⑲ ☒ Residence ⑳ ☐ Mobile home ㉑ ☐ Business or place of public assembly
㉒ Number of bedrooms? 3 ㉕ Type?
㉓ Maximum occupancy? ㉖ Maximum number of employees?
㉔ Basement? ☐ yes ☒ no ㉗ Maximum number of seats?

WATER SUPPLY

㉘ Water supply from (present or proposed):

A ☐ Individual well
B ☐ Municipal system
C ☒ Community well
D ☐ Community system

㉙ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: George M. Morrow
Date: March 25, 1987

IMPROVEMENT PERMIT

The undersigned, an authorized agent of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws and Rules For Sanitary Sewage Collection, Treatment And Disposal in effect the time of issuance of the permit and is subject to the following provisions:

. . No work shall be conducted on the septic tank system until Installation, Construction, Alteration and or Repair permit is issued by the Department.

. . This permit is not transferable, and shall become null and void months from the date of issuance

Environmentalist — Date

Director or Authorized Section Head — Date


*This permit must be signed by the Director of Environmental Health or authorized section head in order to be valid.

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 20442 DATE: 5/20/87
TC: 223-201.17 D/L
SERIAL Nº 10908

Permission is hereby given to ____ Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 3/25/87. All work shall be completed on or before 6/20/87, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Department of Environmental Health before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Repair data

Liquid Capacity of Septic Tank _____ gallons
Liquid Capacity of Dosing Tank 1000 gallons
Tank Construction Pre Cast

Absorption and/or Nitrification Lines:
Trench Width (1) Bed 9' feet
Total Line Length 360 feet
Number of Lines 3
Depth of Stone 17" inches
Distance from House 10'+ feet
Distance from Property Line 10' feet
Distance from Well Community feet

NAME OF OWNER Morrow Homes
LOCATION OF PROPERTY 8020 MATTSON PLACE
Comments: INSTALL 1000gal lift Pump Station, 1 Bull-Run diversion Valve, one 9' Bed x 120' with 17" Stone, Stone Cover.

Jim Ensor
Division or Section Head

Judy J. Kiser R.S.
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER OR AGENTS COPY

CERTIFICATE OF COMPLETION/OPERATION PERMIT

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 20442 DATE: 10/7/87

TC 223 201-17 ☐ L ☐ CRT

SERIAL № 10540

Name of Owner Myrtle Dunlap Juris.:

Address of Property 8020 Mattson Place

Repair Dam

Inspection Data:

Tank Material Pre Cast Concrete

Total Length of Drainfield 300

Number of Lines 3 @ 100

Cover Depth 36"

Water Supply Source Community

Distance to Water Source —

Excavation Inspected 10/7/87

Tank(s) Inspected 10/7/87

Wash Line Inspected —

High Water Alarm Inspected Supplied to be written

PLOT

Design: 1981 Repair CTR# 5

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☐ installed or constructed ☒ altered or repaired

☒ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this

☐ Certificate of Completion ☒ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS: Bed Size Changed to 9' x 100' due to Power line location.

Myers Pump SRM 4M1C

Judy J Kiser R.S.
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.