Serial No. 5544

SIR No. 20305

Date Issued 3-26-84

T. C. No. PO 231-031-11

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT


Lots Combined

NAME OF OWNER Grimmer (LAST) Harry (FIRST)

ADDRESS OF OWNER P.O. Box 898 , Matthews, N.C. ZIP 28105 (MIDDLE)

LOCATION OF PROPERTY 3918 McKee Road (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO. 2 BLOCK NO.



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot **Provisionally**

The permeability rate determined by the investigation was **Suitable** . The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions.

1. A permit to install, construct, alter, or repair the specific system shall be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction of buildings or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Mecklenburg County Department of Environmental Health prior to installation based on the permeability rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area indicated as acceptable for system installation on the above plot.
4. This approval is void if any grading, filling, or construction including the drilling of a well is performed on the lot which, in the opinion of the Mecklenburg County Department of Environmental Health, renders the area indicated as acceptable for system installation unsuitable for installation, construction, alteration and or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

William R. Marlin
Soil Scientist

Environmental Health Director or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

Date Received 11-15-83

MECK CO NTY DEPARTMENT OF
RECEIVED
NOV 15 1983
ENVIRONMENTAL HEALTH

SIR No. 20306

T.P.O. 231-031-11

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Thomas Lamar & Co Inc
LAST FIRST MIDDLE

2) ADDRESS OF OWNER PO Box 875, Matthews ZIP 28105

3) PHONE NO. Home N/A Office 847-8823


4) LOCATION OF PROPERTY 3708 Mackenzie Rd.
STREET OR COUNTY ROAD

5) SUBDIVISION Providence Forest III LOT NO. 5 BLOCK NO. _____

MAP BOOK NO. _____ PAGE NO. _____

6) DEED REFERENCE DEED BOOK 4637 PAGE NO. 111 602

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface. soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Thomas Lamar
OWNER

END-5-76

Environmental Health Department's Copy

DEPARTMENT OF
ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 20306

T.C. NO. 82231-035-11

(Ground Absorption Sewage Disposal)

OWNER: Harry Zimmerman, Jr. PLAT NO: Lot #3
ADDRESS: P.O. Box 278 LOT SIZE: 44,220
Matthews, N.C.
LOCATION OF SITE: 7906 McKee Rd

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) 2-8% U	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S (PS) Clay U	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) Blocky U	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	S (PS) 36-40" U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S (PS) 36" U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S (PS) 36" Top soil U water	S PS U	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	1 U A			
9. SITE CLASSIFICATION	Provisionally Suitable			
10. SOIL SERIES	Appling Silt			


S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments: _____

Described by: William A. Thacker
Title: Soil Scientist Date: 5-22-82

END 539 (Revised: 6/82)


105'
Applin
440'
430
130
Mt Kinabalu

Serial No. 5375

SIR No. 20306

Date Issued 12-28-83

T. C. No. PO 231-031-11

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Harry Grimmer & Co.
(LAST) (FIRST) (MIDDLE)

ADDRESS OF OWNER P.O. Box 893, Matthews, NC ZIP 28105

LOCATION OF PROPERTY 3908 McKee Road,
(STREET OR COUNTY ROAD)

SUBDIVISION Providence Forest III LOT NO. 3 BLOCK NO.



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot. The permeability rate determined by the investigation was PROVISIONALLY SUITABLE. The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter or repair the septic system shall be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction of buildings or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Mecklenburg County Department of Environmental Health prior to installation based on the permeability rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area indicated as acceptable for system installation on the above plot.
4. This approval is void if any grading, filling, or construction including the drilling of a well, is performed on the lot which in the opinion of the Mecklenburg County Department of Environmental Health renders the area indicated as acceptable for system installation unsuitable for installation, construction, alteration, and/or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

William A. Marks
Soil Scientist

M. D. Bailey
Environmental Health Director or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy