

16300 MARVIN RD

22353113

4/30/08

marliwr

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

2223A

6 make folder

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

LOG NO: ___

REQUEST FOR APPROVAL AND RECORD OF LEGAL ACTION

DATE: 11 / 16 / 94 (MONTH / DAY / YEAR)

SECTION: IWS (AQ, WQ, FOOD, DC, MILK, POOL, S&HW, OPWD, VC)

TO: **DIRECTOR**

Request approval for initiation of (circle one): CS, CW, AI, CV, OTHER: ___

Against: WILLIAM EAKER

Violation: SEWAGE ON THE SURFACE OF THE GROUND

Circumstances: (Outline Briefly) Violation sited by a site evaluation. Sent violation notices. Mr. Eaker contacted by phone and indicated he couldn't get a contractor to come adjust the distribution box. I informed him other contractors could do the work and he was under a 30-day violation.

Dan H. Newell, RS.
ENVIRONMENTALIST

Violation Notices (Date & Results):

9-15-94 -

9-20-94 - Reinspection - Violation has not been corrected.

Other Contacts: ___

Approved for proceeding with action:

Supervisor: ___ DATE: ___

Division Manager: ___ DATE: ___

Director: ___ DATE: ___

THE ENTIRE FILE MUST ACCOMPANY THIS FORM.

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

LOG NO: [ ]

REQUEST FOR APPROVAL AND RECORD OF LEGAL ACTION

DATE: 11 / 16 / 94 (MONTH / DAY / YEAR)

SECTION: IWS (AQ, WQ, FOOD, DC, MILK, POOL, S&HW, OPWD, VC)

TO: **DIRECTOR**

Request approval for initiation of (circle one): CS, CW, AI, CV, OTHER: _____

Against: WILLIAM EAKER

Violation: SEWAGE ON THE SURFACE OF THE GROUND

Circumstances: (Outline Briefly) Violation sited by a site evaluation. Sent violation notices. Mr. Eaker contacted by phone and indicated he couldn't get a contractor to come adjust the distribution box. I informed him other contractors could do the work and he was under a 30-day violation.

Jon H Newell, RS.
ENVIRONMENTALIST

Violation Notices (Date & Results):

9-15-94 -

9-20-94 - Reinspection - Violation has not been corrected.

Other Contacts: _____

Approved for proceeding with action:

Supervisor: _____

_____ DATE: _____

Division Manager: _____

_____ DATE: _____

Director: _____

_____ DATE: _____

THE ENTIRE FILE MUST ACCOMPANY THIS FORM.

"FINAL NOTICE"

N. C. Department of Environment, Health, and Natural Resources/Division of Environmental Health

ON-SITE WASTEWATER VIOLATION NOTICE

OWNER Jon William Eaker

MAILING ADDRESS 16300 Marvin Rd. Charlotte 28277

OCCUPANT _____

LOCATION _____

☒ RESIDENCE ☐ BUSINESS ☐ OTHER tax parcel # 223-081-22

You are hereby notified that you are violating the Rules adopted by the North Carolina Commission for Health Services or Article 11 of Chapter 130A of the General Statutes of North Carolina by owning or controlling a residence, place of business, or place of public assembly which is not provided with an approved wastewater system. Your wastewater system is not in compliance; the following corrections must be made. Consult your Local Health Department for advice and required permits by calling telephone number 336-5572.

☒ Install/Repair wastewater system. You must obtain an Improvement Permit from the local health department prior to repairing your system.

☐ Other Repairs (*specify*) _____

☐ Eliminate wastewater discharge and connect to an approved wastewater system.

☐ Perform Maintenance (*specify*) _____

☐ Pit Privy must be repaired/constructed.

If the wastewater violation is not brought into compliance by September 20, 1994, appropriate legal action will be taken.

Notice Issued September 9, 1994 (Date) Signed Toni H. Newell, R.S. (Division of Environmental Health) Agent

Compliance _____ (Date) Signed _____ (Division of Environmental Health) Agent

DEHNR 1108 (Revised 9/92)
On-Site Wastewater Section (Review 10/94)

1/20/95 I spoke to Cathy Hudson with RCS. They adjusted the D-Box.

1/27/95 OSV w/ L. Thompson. Grandmother, Martez Harris, present. observed disturbed soil + fresh straw cover at D-Box area (per COC) + fresh straw over saturated soil - end(s) of lateral line(s). Need re-inspection in approx. 2 months to determine if problem resolved. JBH

3/23/95 OSV. No one present. ~12'×12' elevated deck w/ child's playhouse constructed over drainfield w/ 4-6"×6" supports; at least 2 supports appear to be constructed directly on/in? trench. No effluent on ground surface; however, suspicious area @ end of lateral drainline near woods. JBH left card @ door.

5-23-95 No visible evidence of any problem with septic system at the time of this inspection. I informed Mrs. Eaker that this service request would be abated. JBH

2223A

"FINAL NOTICE"

N. C. Department of Environment, Health, and Natural Resources/Division of Environmental Health

ON-SITE WASTEWATER VIOLATION NOTICE

OWNER Jon William Eaker MAILING ADDRESS 16300 Marvin Rd, Charlotte 28277

OCCUPANT _____ LOCATION _____

☒ RESIDENCE ☐ BUSINESS ☐ OTHER tax parcel # 223-081-22

You are hereby notified that you are violating the Rules adopted by the North Carolina Commission for Health Services or Article 11 of Chapter 130A of the General Statutes of North Carolina by owning or controlling a residence, place of business, or place of public assembly which is not provided with an approved wastewater system. Your wastewater system is not in compliance; the following corrections must be made. Consult your Local Health Department for advice and required permits by calling telephone number 336-5572.

☒ Install/Repair wastewater system. You must obtain an Improvement Permit from the local health department prior to repairing your system.

☐ Other Repairs *(specify)* _____

☐ Eliminate wastewater discharge and connect to an approved wastewater system.

☐ Perform Maintenance *(specify)* _____

☐ Pit Privy must be repaired/constructed.

If the wastewater violation is not brought into compliance by September 20, 1994, appropriate legal action will be taken.

Notice Issued September 9, 1994 (Date) Signed Toni H. Newell, R.S. (Division of Environmental Health) Agent

Compliance _____ (Date) Signed _____ (Division of Environmental Health) Agent

DEHNR 1108 (Revised 9/92)
On-Site Wastewater Section (Review 10/94)

1/20/95 I spoke to Cathy Hudson with RCS. They adjusted the D_Box.

1/27/95 OSV w/ L. Thompson. Grandmother, Martez Harris, present. observed disturbed soil + fresh straw cover at D Box area (per COC) + fresh straw over saturated soil - end(s) of lateral line(s). Need re-inspection in approx. 2 months to determine if problem resolved. JSH

3/23/95 OSV. No one present. ~12'x12' elevated deck w/ child's playhouse constructed over drainfield w/ 4-6"x6" supports; at least 2 supports appear to be constructed directly on/in(?) trench. No effluent on ground surface, however, suspicious area @ end of lateral drainline near woods. JSH left card @ door.

5-23-95 No visible evidence of any problem with septic system at the time of this inspection. I informed Mrs. Eaker that this service request would be abated. JSH

2223A

N. C. Department of Environment, Health, and Natural Resources/Division of Environmental Health

ON-SITE WASTEWATER VIOLATION NOTICE

OWNER Jon William Eaker

MAILING ADDRESS 16300 Marvin Rd, Charlotte 28277

OCCUPANT _____

LOCATION _____

☒ RESIDENCE ☐ BUSINESS ☐ OTHER tax parcel # 223-081-22

You are hereby notified that you are violating the Rules adopted by the North Carolina Commission for Health Services or Article 11 of Chapter 130A of the General Statutes of North Carolina by owning or controlling a residence, place of business, or place of public assembly which is not provided with an approved wastewater system. Your wastewater system is not in compliance; the following corrections must be made. Consult your Local Health Department for advice and required permits by calling telephone number 336-5572.

☒ Install/Repair wastewater system. You must obtain an Improvement Permit from the local health department prior to repairing your system.

☐ Other Repairs *(specify)* _____

☐ Eliminate wastewater discharge and connect to an approved wastewater system.

☐ Perform Maintenance *(specify)* _____

☐ Pit Privy must be repaired/constructed.

If the wastewater violation is not brought into compliance by September 15, 1994, appropriate legal action will be taken.

Notice Issued August 9, 1994 (Date) Signed Toni H. Newell, R.S. (Division of Environmental Health) Agent

Compliance _____ (Date) Signed _____ (Division of Environmental Health) Agent

DEHNR 1108 (Revised 9/92)
On-Site Wastewater Section (Review 10/94)

SERVICE REQUEST/WORK ORDER

Log No.: _____ Section: _____ Hazard? [ ] Yes [ ] No

Date: 7-6-94 Parcel: 223-081-22 <60 Days? [ ] Yes [ ] No

REQUESTING PERSON: _____ Phone _____

Address _____ City _____ Zip _____

PROPERTY CONCERNED: Facility Name JON William Esker 542-2690

Address 16300 Marvin Road City Charlotte Zip _____

SERVICE REQUESTED: Drainfield leaking in yard behind house

ASSIGNED TO: _____ TAKEN BY: W. A. Mace

DATE	ACTIVITY REPORT
	F.Io 2223A
7-6-94	Observed leaking drainfield in yard between house vehicle doing sit exam on adjoining property - probed drainfield - full of effluent - diversion of surface & roof runoff might solve problem
8/3/94	Observed leaking drainfield - will send violation notice. JN
5-20-95	No apparent problem with septic system at the time of this inspection. RLS reports recently advised D. Burr around Jan 20, 1995.

NOTIFICATION TO REQUESTING PERSON: ( ) Written ( ) Verbal (X) Not Applicable

COMPLETED BY: Tommy Thompson, R.S. , 5-23-95

REVIEWED BY: S Daniel for S Daniel, Program Chief , 5-31-95

CERTIFICATE OF COMPLETION/OPERATION PERMIT

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 2223 A DATE: 4/21/87

TC: 223-081.22 ☐ L ☒ CRT

SERIAL № 10025

Name of Owner Eaker, Jon William Juris.:

Address of Property 16300 Marvin Rd.

Inspection Data:

Tank Material Pre-Cast

Total Length of Drainfield 533

Number of Lines 5 @ 107

Cover Depth 12"

Water Supply Source Well - Community


Distance to Water Source 100'+

Excavation Inspected 4/21/87

Tank(s) Inspected 4/21/87

Wash Line Inspected N/A

High Water Alarm Inspected N/A



Design: 1987 1500 Sq Ft, Min 1599 SQ FT, 12" G, Cecil CTR#

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☒ Installed or constructed ☐ altered or repaired

☐ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this

☐ Certificate of Completion ☐ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS: System designed for 4 bedroom home

Bobby McCraven, Contractor

Judy J. Kiser R.S.
Environmentalist

N. C. Department of Environment, Health, and Natural Resources/Division of Environmental Health

ON-SITE WASTEWATER VIOLATION NOTICE

OWNER Jon William Esker MAILING ADDRESS 16300 Marvin Rd.

OCCUPANT _____ LOCATION Charlotte 28277

☒ RESIDENCE ☐ BUSINESS ☐ OTHER tax # 223-081-22

You are hereby notified that you are violating the Rules adopted by the North Carolina Commission for Health Services or Article 11 of Chapter 130A of the General Statutes of North Carolina by owning or controlling a residence, place of business, or place of public assembly which is not provided with an approved wastewater system. Your wastewater system is not in compliance; the following corrections must be made. Consult your Local Health Department for advice and required permits by calling telephone number 336-5572.

☒ Install/Repair wastewater system. You must obtain an Improvement Permit from the local health department prior to repairing your system.

☐ Other Repairs (*specify*) _____

☐ Eliminate wastewater discharge and connect to an approved wastewater system.

☐ Perform Maintenance (*specify*) _____

☐ Pit Privy must be repaired/constructed.

If the wastewater violation is not brought into compliance by 9-15-94, appropriate legal action will be taken.

Notice Issued 8-9-94 (Date) Signed JNewell (Division of Environmental Health) Agent

Compliance _____ (Date) Signed _____ (Division of Environmental Health) Agent

DEHNR 1108 (Revised 9/92)
On-Site Wastewater Section (Review 10/94)