

20624 BETHEL CHURCH RD

00112160

8/26/08

marliwr

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

File 20272

7/17/95
Per phone consult. with Mrs. Jay Young waterline will be run immediately adjacent to right property line.

JBM

CERTIFICATE OF COMPLETION/OPERATION PERMIT

D40

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON ST., SUITE 211
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 20272 DATE: 6/28/95

TC: 001-121-60 ☐ L ☐ ~~CAT~~

SERIAL No 16332

Name of Owner Jay Young Juris.: _____

Address of Property 20624 Bethel Church Road

Inspection Data:

Tank Material PCC

Total Length of Drainfield 400'

Number of Lines 4 @ 100' each

Cover Depth 16-24"

Water Supply Source municipal

waterline not installed as of 6/28/95


Distance to Water Source 10' min.

Excavation Inspected 6/28/95

Tank(s) Inspected 6/28/95

Wash Line Inspected NA

High Water Alarm Inspected NA



Design 1995 CON, 1500gST, 1200ft², 12"G, Cecil-like CTR# 84

Wayne Orbison

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☑ installed or constructed ☐ altered or repaired

☐ in accordance with the permit issued ☑ as detailed in the plot above

and meets the provisions of 15A NCAC 18A. 1900, "Laws And Rules For Sewage Treatment and Disposal Systems" in effect on the date of issuance of the permit. This issuance of this

☑ Certificate of Completion ☐ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 15A NCAC 18A. 1990 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Notice: Disturbance of the designated repair area may result in the suspension/revocation of this permit.

COMMENTS: Type II installation for 3 bedroom house;
PPBPS repair area behind house.

* Install waterline 10' minimum from any part of septic system → i.e. install immediately adjacent to right property line.

Joe B. Mialik RS
Environmental Health Specialist

for Daniel, Program Chief 7-3-95

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

Notarized + Reg
Register Deeds

JUDITH A GIBSON REG OF DEEDS MECK NC
FILED FOR REGISTRATION 06/14/95 15:48
BK: 08178 PG: 0143/0145 #:0426 13.05

STATE OF NORTH CAROLINA

COUNTY OF MECKLENBURG

ACKNOWLEDGEMENT OF REQUEST BY OWNER FOR RECLASSIFICATION OF SITE FROM *"UNSUITABLE" TO "PROVISIONALLY SUITABLE"* UNDER 15A NCAC 18A .1948 AND ANY OF THE FOLLOWING RULES: .1956; .1957(a); .1957(b); or .1957(c)

FILE # 20272
PARCEL # 201-121-60

The undersigned, JAY A YOUNG and wife MARGARET W. YOUNG, owner of property located at 20624 Bethel Church Rd., (the "site") and described in an instrument recorded in Book 6412 at Page 827, Mecklenburg Public Registry, hereby acknowledges that the undersigned applied to the Mecklenburg County Health Department (the "Department") for a permit to install a septic tank sewage disposal system on the site; that the Department evaluated the site for suitability for such a system in accordance with the regulations promulgated by the North Carolina Commission for Health Services as 15A NCAC 18A .1900 et seq.; that the Department originally classified the site as "unsuitable" pursuant to the standards set forth in the regulations; that the undersigned requested that the Department reclassify the site as "provisionally suitable" in light of the particular septic tank system proposed by the undersigned; that the Department considered various studies, data, and other information which indicate to the Department that the septic tank system proposed by the undersigned is allowed by the rules; and that the Department therefore reclassified the site as "provisionally suitable" and issued an appropriate permit for such proposed septic tank system.

The undersigned further acknowledges that the proper design, construction, operation and maintenance of such septic tank system is his responsibility and that neither the Department nor its officials, employees, or agents warrant or guarantee that the said system installed pursuant to the permit issued by the Department will function in a satisfactory manner for any given period of time or that the Department, its officials, employees or agents assume any liability for any damages of any kind which are caused, or which may be caused, by a malfunction of such system.

The undersigned further acknowledges that the following conditions will apply to the site:

- Any changes on the property may make the Improvement Permit Null and void and may make the Improvement Permit subject to revocation.

This instrument was prepared by: Jay Allan Young
Mail after recording to: Enviromental Health

- Do not grade, cut, fill, pave, construct a building or deck, dig a well, install a swimming pool or otherwise cover or disturb the soil (except for planting and maintaining grass or other ground covers) in a manner which will adversely affect the repair area or area where the septic tank system is located.

- When a private certified operator is required, no improvement permit for the designated repair shall be issued unless there is a private certified operator to carry out this management program in the service area where the proposed system is to be located. (Refer to Rule .1961, "Maintenance of Sewage Systems," for further information.)

- Additional fees will be required according to the Mecklenburg County user fee schedule applicable at the time for the issuance of a repair permit for any subsequent repairs to the sewage treatment and disposal system or for installation of a replacement system.

- At the time repairs to the sewage treatment and disposal system are to be made or a replacement system installed, the regulations in effect at that time will govern the repairs or installation of a replacement system.

The undersigned further agrees for himself, his heirs and assigns that he shall indemnify and hold harmless the Department, its employees, and officials, as well as Mecklenburg County and its employees and officials, for any damages or other claims of any person or persons whatsoever arising out of the installation, operation, or failure of said septic tank system.

The undersigned further agrees for his heirs and assigns that, in the event any septic tank system installed under authority of the aforesaid permit fails to perform adequately in any respect, he will take whatever measures are required to correct same; or if such is impossible he will discontinue use of said system immediately.

Use of the singular masculine pronoun forms herein shall be deemed to also include the plural and feminine forms as the context may require.

This document shall be placed on the public records of the Register of Deeds of Mecklenburg County and indexed therein under the Grantor Index in the name or names of the undersigned, and the foregoing acknowledgements shall henceforth be binding on all persons claiming any right, title, or interest in the site.

IN WITNESS WHEREOF, the undersigned has hereunto set his hand and seal, or if corporate, has caused this instrument to be signed in its corporate name by its duly authorized officers and its seal to be hereunto affixed by authority of its Board of Directors, this 14th day of June, 1995.

_____ _____ (SEAL)

~~(Corporate Name)~~

Margaret Winkler Young _____ (SEAL)

By: _____ _____ (SEAL)

_____ ~~President~~ _____ (SEAL)

ATTEST:

_____

_____ Secretary

(Corporate Seal)

STATE OF NORTH CAROLINA
COUNTY OF Mecklenburg

I, Sharlee T. Boyte, a Notary Public for said County and State, do hereby certify that Margaret Winkler Young and Jay Allan Young personally appeared before me this date and acknowledged the due execution of the foregoing instrument.

WITNESS my hand and notarial seal, this 14th day of June 1995.

Sharlee T. Boyte
Notary Public

My Commission Expires:
My Commission Expires 12/16/98

State of North Carolina, County of Mecklenburg
The foregoing certificate(s) of Sharlee T. Boyte

Notary(ies) Public is/are certified to be correct. This 14th day of June 19 95

JUDITH A. GIBSON, REGISTER OF DEEDS By: Carolyn W. Mayzik Deputy Register of Deeds

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR APPROVAL


HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON ST., SUITE 211
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 20272 DATE: 6/15/95

TC: 001-121-60 ☐ L

SERIAL Nº 16289

Permission is hereby given to ✓ Install or Construct, _____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 5/16/94. All work shall be completed on or before 7/15/95, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 15A NCAC 18A. 1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Health Department before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



Liquid Capacity of Septic Tank 1500 gallons

Liquid Capacity of Dosing Tank NA gallons

Tank Construction PCC

Trench Depth 24" - 36" (36" max @ start of lines)

Absorption and/or Nitrification Lines:

Trench Width 3 feet

Trench Walls Scored and Porous ✓

Total Line Length 400 feet

Number of Lines 4 @ 100' each

Depth of Stone 12 inches

Distance from House 5 feet

Distance from Property Line 10' feet

Distance from Well 750' Well feet

⑥ 20624 Bethel Church Rd to be served by municipal water. ⑤ Keep system >10' from waterline.

NOTICE: This system shall not be installed while soils are in a wet condition.

NAME OF OWNER Jay Young

LOCATION OF PROPERTY 20624 Bethel Church Road

Comments: ① System design altered from IP due to house design change (garage) & to avoid pump.

② Install septic tank as shallow as possible. ③ In case supply line portion between septic tank & D-Box that will lie under driveway with schedule 80 PVC or equivalent.

⑤ Keep lines on contour as much as possible; Maximum trench depth 36".

for Daniel Program Chief 6-15-95

Lisa B. Mialik
Environmental Health Specialist

⑤ PPBPS repair due to lack of available space.

WHITE - HEALTH DEPARTMENT's COPY • CANARY - E.H.S. COPY • PINK - OWNER OR AGENT's COPY

GIBSON REG OF DEEDS MECK NC
FOR REGISTRATION 06/14/95 15:48
08178-PG: 0143/0145 #:0426 13.05

FILE COPY

STATE OF NORTH CAROLINA

COUNTY OF MECKLENBURG

ACKNOWLEDGEMENT OF REQUEST BY OWNER FOR RECLASSIFICATION OF SITE FROM *"UNSUITABLE" TO "PROVISIONALLY SUITABLE"* UNDER 15A NCAC 18A .1948 AND ANY OF THE FOLLOWING RULES: .1956; .1957(a); .1957(b); or .1957(c)

FILE # 20272
PARCEL # 001-121-60

The undersigned, JAY A YOUNG and wife MARGARET W. YOUNG, owner of property located at 20624 Bethel Church Rd., (the "site") and described in an instrument recorded in Book 6412 at Page 827, Mecklenburg Public Registry, hereby acknowledges that the undersigned applied to the Mecklenburg County Health Department (the "Department") for a permit to install a septic tank sewage disposal system on the site; that the Department evaluated the site for suitability for such a system in accordance with the regulations promulgated by the North Carolina Commission for Health Services as 15A NCAC 18A .1900 et seq.; that the Department originally classified the site as "unsuitable" pursuant to the standards set forth in the regulations; that the undersigned requested that the Department reclassify the site as "provisionally suitable" in light of the particular septic tank system proposed by the undersigned; that the Department considered various studies, data, and other information which indicate to the Department that the septic tank system proposed by the undersigned is allowed by the rules; and that the Department therefore reclassified the site as "provisionally suitable" and issued an appropriate permit for such proposed septic tank system.

The undersigned further acknowledges that the proper design, construction, operation and maintenance of such septic tank system is his responsibility and that neither the Department nor its officials, employees, or agents warrant or guarantee that the said system installed pursuant to the permit issued by the Department will function in a satisfactory manner for any given period of time or that the Department, its officials, employees or agents assume any liability for any damages of any kind which are caused, or which may be caused, by a malfunction of such system.

The undersigned further acknowledges that the following conditions will apply to the site:

- Any changes on the property may make the Improvement Permit Null and void and may make the Improvement Permit subject to revocation.

This instrument was prepared by: Jay Allan Young
Mail after recording to: Enviromental Health

- Do not grade, cut, fill, pave, construct a building or deck, dig a well, install a swimming pool or otherwise cover or disturb the soil (except for planting and maintaining grass or other ground covers) in a manner which will adversely affect the repair area or area where the septic tank system is located.

- When a private certified operator is required, no improvement permit for the designated repair shall be issued unless there is a private certified operator to carry out this management program in the service area where the proposed system is to be located. (Refer to Rule .1961, "Maintenance of Sewage Systems," for further information.)

- Additional fees will be required according to the Mecklenburg County user fee schedule applicable at the time for the issuance of a repair permit for any subsequent repairs to the sewage treatment and disposal system or for installation of a replacement system.

- At the time repairs to the sewage treatment and disposal system are to be made or a replacement system installed, the regulations in effect at that time will govern the repairs or installation of a replacement system.

The undersigned further agrees for himself, his heirs and assigns that he shall indemnify and hold harmless the Department, its employees, and officials, as well as Mecklenburg County and its employees and officials, for any damages or other claims of any person or persons whatsoever arising out of the installation, operation, or failure of said septic tank system.

The undersigned further agrees for his heirs and assigns that, in the event any septic tank system installed under authority of the aforesaid permit fails to perform adequately in any respect, he will take whatever measures are required to correct same; or if such is impossible he will discontinue use of said system immediately.

Use of the singular masculine pronoun forms herein shall be deemed to also include the plural and feminine forms as the context may require.

This document shall be placed on the public records of the Register of Deeds of Mecklenburg County and indexed therein under the Grantor Index in the name or names of the undersigned, and the foregoing acknowledgements shall henceforth be binding on all persons claiming any right, title, or interest in the site.

IN WITNESS WHEREOF, the undersigned has hereunto set his hand and seal, or if corporate, has caused this instrument to be signed in its corporate name by its duly authorized officers and its seal to be hereunto affixed by authority of its Board of Directors, this 14th day of June, 1995.

_____ _____ (SEAL)

~~(Corporate Name)~~

Margaret Winkler Young _____ (SEAL)

By: _____ _____ (SEAL)

_____ ~~President~~ _____ (SEAL)

ATTEST:

_____

_____ Secretary

(Corporate Seal)

STATE OF NORTH CAROLINA
COUNTY OF Mecklenburg

I, Sharlee T. Boyte, a Notary Public for said County and State, do hereby certify that Margaret Winkler Young and Jay Allan Young personally appeared before me this date and acknowledged the due execution of the foregoing instrument.

WITNESS my hand and notarial seal, this 14th day of June 1996.

Sharlee T. Boyte
Notary Public

My Commission Expires:
My Commission Expires 12/16/98

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

OWNER'S ACKNOWLEDGMENT OF MODIFIED/ALTERNATIVE REPLACEMENT SYSTEM REQUIREMENT

Site Address: 20624 Bethel Church Rd.

File Number: 202 72

Parcel Number: 001-121-60

Owner/Agent Name: Jay Allan Young
(Please print)

Date: 6.14.95 Number of Bedrooms: 3

Receipt of the plan and specifications for a conventional system of sewage disposal for the above property is hereby acknowledged. Upon receipt of the information, a review was made of the material on file and a site evaluation was conducted. The plan was then reviewed in conjunction with provisions of 15A NCAC 18A .1900 - "Sewage Treatment and Disposal Systems." The plan as submitted is disapproved because there is not sufficient available space for a repair area for a conventional replacement system.

This site may be developed if the repair area is found to be acceptable for either a modified system (Rule .1956) or an alternative system (Rule .1957) for the replacement system as allowed by the following Rule 15A NCAC 18A .1945(b).

(b) Sites shall have sufficient available space for a repair area separate from the area determined in Paragraph (a) of this Rule. The repair area shall be based upon the area of the nitrification field required to accommodate the installation of a replacement system as specified in Rule .1955, .1956, or .1957 of this Section. Prior to issuance of the initial Improvement Permit for a site, the local health department shall designate on the permit the original system layout, the repair area, and the type of replacement system.

Please be advised that you have the right of an informal review by this Department and the right of appeal under G.S. 130A-335(g) and 130A-24, which appeal can be held in Mecklenburg County.

By signing this form, and signing and recording in the Mecklenburg County Register of Deeds Office the attached reclassification form entitled, "ACKNOWLEDGEMENT OF REQUEST BY OWNER FOR RECLASSIFICATION OF SITE FROM *"UNSUITABLE" TO "PROVISIONALLY SUITABLE"* UNDER 15A NCAC 18A .1948 AND ANY OF THE FOLLOWING RULES: .1956; .1957(a); .1957(b); or .1957(c), you, the property owner,

understand and acknowledge your option to develop this site initially with a conventional sewage system and when needed, subsequently to repair or replace said system with a modified or alternative system as described in Rules .1956 "Modification to Septic Tank Systems," or .1957(a), (b), or (c) "Design Criteria for Design of Alternative Sewage Systems." The completed reclassification form must be approved by this office before it can be recorded.

In addition, you the property owner, also understand that the following conditions will apply:

- Any changes on the property may make the Improvement Permit null and void and may make the Improvement Permit subject to revocation.

- Do not grade, cut, fill, pave, construct a building or deck, dig a well, install a swimming pool or otherwise cover or disturb the soil (except for planting and maintaining grass or other ground covers) in a manner which will adversely affect the repair area or area where the septic tank system is located.

- When a private certified operator is required, no improvement permit for the designated repair shall be issued unless there is a private certified operator to carry out this management program in the service area where the proposed system is to be located. (Refer to Rule .1961, "Maintenance of Sewage Systems," for further information.)

- Additional fees will be required according to the Mecklenburg County user fee schedule applicable at the time for the issuance of a repair permit for any subsequent repairs to the sewage treatment and disposal system or for installation of a replacement system.

- At the time repairs to the sewage treatment and disposal system are to be made or a replacement system installed, the regulations in effect at that time will govern the repairs or installation of a replacement system.

Lisa B. Mialik — Environmental Health Specialist

6/15/95 — Date

I have reviewed this document and understand its provisions and implications concerning the issuance of the Improvement Permit for the above-referenced site.

Jay Allan Young — Property Owner Signature

6-14-95 — Date

700 North Tryon Street, Suite 211, Charlotte, North Carolina 28202,
(704) 336-5102

~~2400~~ 00

Pd. $120 5/17/94 #3066 CRT

INDIVIDUAL WATER AND WASTEWATER SYSTEMS PROGRAM
APPLICATION FOR SERVICES

26272

Mecklenburg County Health Dept.
Environmental Health Division
c/o Hal Marshall Ctr., Suite 211
700 N. Tryon St.
Charlotte, NC 28202

(704)336-5102

PERSON FILING APPLICATION:

NAME: Young (last) Jay (first) D. (mi)

ADDRESS: P.O. Box 992 PHONE: (704) 875-8238

CITY: Huntersville STATE: N.C. ZIPCODE: 28078

Date: 5-16-94

PROPERTY OWNER:

NAME: Young (last) Jay (first) D. (mi)

ADDRESS: P.O. Box 992 PHONE: (704) 875-8338

CITY: Hunt. STATE: N.C. ZIPCODE: 28078

PROPERTY INFORMATION (FROM ENGINEERING FORM):

TAX/PARCEL NUMBER: 001-121-60

STREET ADDRESS: 20624 Bethel Ch. Rd

ZONING:

SUBDIVISION OR MOBILE HOME PARK NAME:

Township (check one):
[X] 0 Mecklenburg County [ ] 2 Davidson [ ] 4 Pineville [ ] 6 Huntersville
[ ] 1 Charlotte [ ] 3 Cornelius [ ] 5 Matthews [ ] 7 Mint Hill

LOT NUMBER: 1 LOT SIZE (in acres): .75 acres

TYPE APPLICATION (check one):

[ ] SOIL TEST - INDIVIDUAL LOT (D)
[X] NEW CONSTRUCTION ON VACANT LOT - 4 BEDROOMS OR LESS (N)
[ ] EXCHANGE MOBILE HOME - SAME # BEDROOMS (Y)
[ ] ADDITION - INCREASE ROOMS/OCCUPANCY/MOBILE HOME SIZE (A or M)
[ ] COMMERCIAL OR INDUSTRIAL (N)
[ ] SOIL TEST DEVELOPMENT (P)
[ ] ADDITION - GARAGE OR RENOVATION/NO MAJOR CHANGES (X)
[ ] MODIFIED /ALTERNATIVE/ OR RESIDENCE > 4 BEDROOMS (Z)
[ ] REPAIR TO SYSTEM (R)

RESIDENTIAL PROPERTY (Type Building, check one):

[ ] SINGLE MOBILE HOME (S) [X] HOUSE (H) [ ] MULTIPLE FAMILY (U)
[ ] DOUBLE WIDE (D) [ ] MODULAR HOME (M) [ ] OTHER _____ (O)

NUMBER BEDROOMS: 3 NUMBER OCCUPANTS:

SYSTEM CLASSIFICATION:

COMMERCIAL/INDUSTRIAL PROPERTY:

Type Business _____ # Employees ___ Per Shift ___ ___ ___
Industrial Wastes (Y/N) ___
Underground Storage Tanks On Property (Y/N) ___ Type _____

WATER SUPPLY (check one):

[ ] Community (C) [ ] Shared Well (S)
[X] Municipal (M) [ ] Other 'spring' (O)
[ ] Private Well (P)

FUTURE ADDITIONS - ALL PLANNED ADDITIONS MUST BE ENTERED (check all that apply):

[ ] Swimming Pool [ ] Jacuzzi [ ] Stable/Barn [ ] Workshop [ ] None
[ ] Garage [ ] Storage Building [ ] Deck/Patio [ ] Bedrooms [ ] Other

The undersigned, owner, or legal agent for the owner, of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: _____ Date: 5-16-94

NOTICE:

The undersigned, an authorized agent of the MECKLENBURG COUNTY HEALTH DEPARTMENT, certifies that the Department has approved the the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

...No work shall be conducted on the septic tank system until an installation, Construction, Alteration and/or Repair approval is granted by this Department.

...This permit is not transferable.

...

[X] IMPROVEMENT PERMIT - VALID 60 MONTHS FROM ISSUANCE
[ ] MOBILE HOME EXCHANGE APPROVAL - VALID 6 MONTHS FROM ISSUANCE
[ ] ADDITION/RENOVATION APPROVAL - VALID 1 YEAR FROM ISSUANCE

Philo S. Walker 5/25/94
Environmentalist Date

Director or Authorized Section Head Date

UWATER : 122791


PROPOSED PLOT PLAN

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON STREET
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 20272

TC: 001-121-60

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



APPROVAL DATE PJW 5/25/94

White - Health Department's Copy Canary - Environmentalist's Copy Pink - Owner's Copy

File 20272

DATE 5/16/94

TO: CHARLOTTE-MECKLENBURG BUILDING STANDARDS
PERMIT ISSUING SECTION

FROM: MECKLENBURG COUNTY ENGINEERING

JURISDICTION Meck

001-121-60
PARCEL NUMBER

20624 Bethel Church Rd
ASSIGNED STREET ADDRESS (ADDRESS OF RECORD)

EXISTING STREET ADDRESS (IF DIFFERENT FROM ASSIGNED)

N/A
PROJECT NAME (IF APPLICABLE)

THE ABOVE DESCRIBED LOCATION HAS BEEN CHECKED CONCERNING:

1. SUBDIVISION REGULATIONS	✓ APPROVED	____ NOT APPROVED
2. FLOODWAY REGULATIONS	✓ APPROVED	____ NOT APPROVED
3. WATERSHED PROTECTION	✓ APPROVED	____ NOT APPROVED
4. COMMERCIAL DRAINAGE PLAN	✓ APPROVED	____ NOT APPROVED
5. PUBLIC UTILITY EASEMENT	____ PRESENT	✓ NOT PRESENT
6. PROPERTY FRONTS ON THOROUGHFARE	____ YES	✓ NO
7. DRIVEWAY PERMIT REQUIRED	____ YES	✓ NO
8. DOES PROJECT CONFLICT WITH ROAD PROJECT?	____ YES	✓ NO

REMARKS: new home

NOTE: THIS FORM MUST BE TURNED IN AT THE CASHIERS OFFICE WHEN PAYING PERMIT FEE. CERTIFICATE OF OCCUPANCY WILL NOT BE GRANTED UNTIL TRANSPORTATION DIVISION GRANTS FINAL APPROVAL ON DRIVEWAY(S).

ALL OTHER FORMS OBSOLETE

☐ NEW ADDRESS

SIGNED: [signature]

REVISED 1/91

DEPARTMENT OF
ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 20272

T.C. NO. PC 6:1-1343

(Ground Absorption Sewage Disposal)

OWNER: Russell & Bobby Knox
ADDRESS: Po Box 4 Davidson NC 28036
PLAT NO: #1
LOT SIZE: 32,670
LOCATION OF SITE: Beckett Church Road

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) 2-10% U	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S (PS) clay U	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) Blocky U	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	S (PS) 30-48" U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S (PS) 30-48 U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S 7-48" to ground water PS U	S PS U	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	IVA			
9. SITE CLASSIFICATION	Provisionally Suitable			
10. SOIL SERIES	Cecil-Lloyd			

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments: Will locate on lot

Described by: William A. Mullis
Title: Soil Scientist
Date: 12-5-83

EHD 539 (Revised: 6/82)


Imaging Solutions and Services, Inc

The following is a

Poor Original

The following document has been identified as a poor quality original (insufficient contrast, inadequate definition, obscured information, etc.) Prior to final document capture, every manual, hardware and software effort has been applied (extra document preparation, modification of document capture device set-up paramenters and/or copying of the original) to obtain the highest possible image quality from this original.

ISSI Operations Center Staff


68'
351'
320'
113'
Bethel Church Road

Serial No. 5344

SIR No. 20272

Date Issued 12-6-83

T. C. No. PO 001-121-03

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Knox, (LAST) Russell (FIRST) B. (MIDDLE)
Knox, Bobby B.

ADDRESS OF OWNER P.O. Box 4, Davidson, NC ZIP 28036

LOCATION OF PROPERTY Bethel Church Road (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO. 1 BLOCK NO.



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot. PROVISIONALLY SUITABLE

The permeability rate determined by the investigation was . The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter, or repair the specific system shall be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction of buildings, or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Mecklenburg County Department of Environmental Health prior to installation based on the permeability rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed on the immediate area indicated as acceptable for system installation on the above plot.
4. This approval is void of any grading, filling, or construction including the drilling of a well, performed on the lot which, in the opinion of the Mecklenburg County Department of Environmental Health, renders the area indicated as acceptable for system installation unsuitable for installation, construction, alteration, and/or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

William R. Marlow
Soil Scientist

LHD-5-76

Environmental Health Director or Authorized Section Head

Environmental Health Department's Copy

Date Received 11-8-83

MECKLENBURG COUNTY DEPARTMENT OF
RECEIVED
NOV 7 1983
ENVIRONMENTAL HEALTH

SIR No 20272
T. C. No. 001-121-03
Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Knox Russell B
Knox (LAST) Bibby (FIRST) B. (MIDDLE)

2) ADDRESS OF OWNER PO Box 4 Davidson NC ZIP 28036

3) PHONE NO. Home 8920248 Office 8920196

4) LOCATION OF PROPERTY 20722 Bethel Church Rd
(STREET OR COUNTY ROAD)


5) SUBDIVISION _____ LOT NO. 1 BLOCK NO. _____

MAP BOOK NO. _____ PAGE NO _____

6) DEED REFERENCE: DEED BOOK _____ PAGE NO _____

001-121-03

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Bobby B Knox
OWNER

EHD-5-76


ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

APT. NO. 20272 YEAR 1983


TAX NO. 20722 Bethel Church Rd.

ST. ADDRESS 001-121-03

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH



RECORDAK APERTURE CARD, MANUFACTURED IN THE U.S.A. FOR EASTMAN KODAK COMPANY


210'