Date Received 7-9-82

SEE INSTRUCTIONS ON BACK

RECEIVED

AUG

ENVIRONMENTAL HEALTH

ICAR(S) Application No. 18912

T. C. No. 137-131-09


Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) _____ Install or Construct 2) ___ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ___ Yes ___ No
Residence X Yes ___ No

4) No. of Bedrooms 2

5) Business Use — Max No Employees _____

6) Washing Machine ✓ Yes ___ No

7) Garbage Disposal ___ Yes ✓ No

8) Dishwasher ___ Yes ✓ No

9) Water Supply:
A) Individual Well ✓
B) Governmental System _____
C) Community System:
1. Well source _____
2. Governmental source _____

10) Sewage System:
House located within 200 feet of public sewer ___ Yes ✓ No
House located within 200 feet of community sewer ___ Yes ✓ No

11) FHA Case No. _____

12) VA Case No. _____

13) NAME OF OWNER _____ (LAST) _____ (FIRST) _____ (MIDDLE)

14) ADDRESS OF OWNER _____

15) PHONE NO. Home _____ Office _____

16) LOCATION OF SYSTEM _____ (STREET OR COUNTY ROAD)

17) SUBDIVISION _____ Lot No. _____ Block No. _____

Map Book No. _____ Page No. _____

18) DEED REFERENCE — DEED BOOK _____ AT PAGE _____

19) HAS A SOIL INVESTIGATION BEEN RUN? _____ YES _____ NO DATE RUN _____

20) PTR NUMBER (See Instructions) _____

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

8/6/82
DATE OF APPLICATION

OWNER

EHD-5-76

✓ A


Date Issued Aug 10th 1982 Serial No. 5669 ICAR(S) Permit No. 18912

T. C. No. 137-131-09

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct, X Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 18912, dated Aug 9th 1982 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before Aug 31st 1982 after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate P.S.

Liquid Capacity of Tank —

Tank Construction cement block

Absorption and/or Nitrification Lines:

Total Line Length none

Number of Lines 10 ft

Distance from House ____

Distance from Property Line 80 ft

Distance from Well 80 ft

NAME OF OWNER JOHN ELLIOT CRAMER

LOCATION OF PROPERTY 10518 TRUELIGHT Church Rd.

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

Comments: replaced DIST BOX and TWO out LOT pipes 5 FT each - build concrete dam at leak at end of field.

_____ Ralph Nelles

Division or Section Head* Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-S-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

C of A (s) No. 18912

Date Issued Aug 16th 82 Serial 5308

T. C. No. 137-131-09

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF COMPLETION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner CRAMER (LAST) ELLIOTT (FIRST) (MIDDLE)

Location of Property 10518 TRUELIGHT CHURCH RD

Application Number 18912 Permit Number 18912

Inspection Date:

Liquid Capacity of Tank — Tank Material cement block.

Total Length of Drain Tile [redacted] Number of Lines Two

Depth of Filter Material — Cover Depth 12 inches

Water Supply Source well Distance from Water Source 80 ft

Excavation Inspected 8-10-82 (DATE) Tank Inspected 8-10-82 (DATE)

Nitrification Field Inspected 8-10-82 (DATE)

Washing Machine Line Inspected, If Applicable — (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been * ✓ installed or constructed, ✓ altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments: added two fine inspections of drain pipe on outlet side of Dist box - added new Dist Box - repaired broken tank lid - installed concrete dam at leak area & leak is stopped -

Ralph Miller
Environmentalist

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY