Date Received 8-17-82

SIR No. 18934
T. C. No. 047-032-13

Map Date

MECK COUNTY DEPARTMENT OF
RECEIVED
AUG 17 1982
ENVIRONMENTAL HEALTH

MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Jordan (LAST) Clarence (FIRST) A. (MIDDLE)

2) ADDRESS OF OWNER 3150 South Decatur Blvd. #146, Las Vegas, Nevada ZIP 89102

3) PHONE NO. Home 702/ 873-7195 Office


4) LOCATION OF PROPERTY Mineral Springs Road #2500 (STREET OR COUNTY ROAD)

5) SUBDIVISION None LOT NO Parcel B BLOCK NO.

MAP BOOK NO. PAGE NO.

6) DEED REFERENCE DEED BOOK 866 PAGE NO 152

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

X C. A. Jordan
OWNER

END-5-76

Environmental Health Department's Copy

Serial No. 4673

PTR No. 18934

Date Issued 8-30-82

T. C. No. PO 047-032-13

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Jordan, (LAST) Clarence (FIRST) A. (MIDDLE)

ADDRESS OF OWNER 3150 S. Decatur Blvd., #146, Las Vegas, Nevada ZIP 89102

LOCATION OF PROPERTY Mineral Springs Road (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO. Parcel B BLOCK NO.



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot. **Provisionally Suitable** The permeability rate determined by the investigation was . The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions.

1. A permit to install, construct, alter or repair the septic tank system shall be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction of buildings or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Mecklenburg County Department of Environmental Health prior to installation based on the permeability rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed on the improved area indicated as acceptable for system installation on the above plot.
4. This approval is void if any grading, filling, or construction, including the cutting of a well performed on the lot which, in the opinion of the Mecklenburg County Department of Environmental Health, renders the area indicated as acceptable for system installation unsuitable for installation, construction, alteration, and repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

William R. Martin
EHD-5-74 Soil Scientist

Mike Sexton
Environmental Health Director or Authorized Section Head

Environmental Health Department's Copy

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 18934

T.C. NO. 80-82-0323

(Ground Absorption Sewage Disposal)

OWNER: Clarence A. Jordan
ADDRESS: 3150 South Tryon Street Apt 2 Decatur Blvd Apts Apt 2 Legas, Nevada 89102
LOCATION OF SITE: Mineral Springs Rd

PLAT NO: Lot B
LOT SIZE: 21,924

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS U 2-8%	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S (PS) clay U	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) Blocky U	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	(S) PS 48" U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	(S) PS None U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	(S) PS Perched ground water U	S PS U	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	IVA			
9. SITE CLASSIFICATION	Provisionally Suitable			
10. SOIL SERIES	Cec. /			

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)


Recommendations/Comments: _____

Described by: William R. Martin
Title: Soil Scientist

Date: 8-27-82

EHD 539 (Revised: 6/82)

✓


160'
410'
Cecil
495'
100'
Mineral Springs
Rd