CWPA (s) No 16393

Date Issued 12 December 1979 Serial 3322

T C No 141152 19

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Johnston (LAST) Caldwell (FIRST) P. (agent) (MIDDLE)

Location of Property Dixie River Road

Application Number _____ Permit Number _____

Repair
Inspection Data:

Liquid Capacity of Tank 1000 gal Tank Material concrete

Total Length of Drain Tile 200 L/ft Number of Lines 2

Depth of Filter Material 17" Cover Depth 24"

Water Supply Source well Distance from Water Source 50'

Excavation Inspected — (DATE) _____ Tank Inspected — (DATE) _____

Nitrification Field Inspected 12 Dec 1979 (DATE)

Washing Machine Line Inspected, If Applicable — (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ____ installed or constructed, ____ altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments in bed 6 x 100 long

John A Jackson
Environmentalist

EHD-S-76

Environmental Health Department's Copy